

Installation Instructions

ArmorBlock Guard I/O DeviceNet Safety Modules

Catalog Numbers 1732DS-IB8X0BV4, 1732DS-IB8

Topic	Page
Important User Information	2
Environment and Enclosure	3
Preventing Electrostatic Discharge	4
Before You Begin	4
Module Identification and Dimensions	5
Observing Precautions for Correct Use	7
Observing Precautions for Safe Use	7
Install the Module	10
Set MAC ID	10
Wiring the Module	10
Working with I/O Connectors	11
Terminal Positions	12
Interpret the Status Indicators	14
Specifications	18
Additional Resources	23

Important User Information

Solid state equipment has operational characteristics differing from those of electromechanical equipment. Safety Guidelines for the Application, Installation and Maintenance of Solid State Controls (Publication [SGI-1.1](#) available from your local Rockwell Automation sales office or online at <http://www.rockwellautomation.com/literature/>) describes some important differences between solid state equipment and hard-wired electromechanical devices. Because of this difference, and also because of the wide variety of uses for solid state equipment, all persons responsible for applying this equipment must satisfy themselves that each intended application of this equipment is acceptable.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.

WARNING 	Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.
IMPORTANT	Identifies information that is critical for successful application and understanding of the product.
ATTENTION 	Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard and recognize the consequences.
SHOCK HAZARD 	Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present.
BURN HAZARD 	Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures.

Environment and Enclosure

ATTENTION

This equipment is intended for use in overvoltage Category II applications (as defined in IEC 60664-1), at altitudes up to 2000 m (6562 ft) without derating.

This equipment is considered Group 1, Class A industrial equipment according to IEC/CISPR Publication 11. Without appropriate precautions, there may be potential difficulties with electromagnetic compatibility in residential and other environments due to conducted and radiated disturbances.

This equipment is supplied as enclosed equipment. It should not require additional system enclosure when used in locations consistent with the enclosure type ratings stated in the Specifications section of this publication. Subsequent sections of this publication may contain additional information regarding specific enclosure type ratings, beyond what this product provides, that are required to comply with certain product safety certifications.

In addition to this publication, see:

- Industrial Automation Wiring and Grounding Guidelines, for additional installation requirements, publication [1770-4.1](#).
 - NEMA Standards 250 and IEC 60529, as applicable, for explanations of the degrees of protection provided by different types of enclosure.
-

Preventing Electrostatic Discharge

ATTENTION



This equipment is sensitive to electrostatic discharge, which can cause internal damage and affect normal operation. Follow these guidelines when you handle this equipment:

- Touch a grounded object to discharge potential static.
 - Wear an approved grounding wriststrap.
 - Do not touch connectors or pins on component boards.
 - Do not touch circuit components inside the equipment.
 - Use a static-safe workstation, if available.
 - Store the equipment in appropriate static-safe packaging when not in use.
-

ATTENTION



Make sure all connectors and caps are securely tightened to properly seal the connections against leaks and maintain IP enclosure type requirements.

ATTENTION



Personnel responsible for the application of safety-related Programmable Electronic Systems (PES) shall be aware of the safety requirements in the application of the system and shall be trained in using the system.

ATTENTION



If the devices (sensors) connected to the input connections require Class 2 power to operate, the auxiliary power connections of this equipment must be powered by a Class 2 source. To comply with the CE low-voltage directive (LVD), this equipment and all connected I/O must be powered from a source compliant with the following: safety extra low voltage (SELV) or protected extra low voltage (PELV).

Before You Begin

Before installing and operating the product, read these installation instructions to learn important installation-related information and the

precautions to follow as you install and operate the product. Keep these instructions for future reference.

Concerning suitability for use, note that we are not responsible for conformity with any standards, codes, or regulations that apply to the combination of the products in the customer's application or use of the product. Take all necessary steps to determine the suitability of the product for the systems, machines, and equipment with which it will be used. Know and observe all prohibitions of use applicable to this product.

Never use the products for an application involving serious risk to life or property without verifying that the system as a whole has been designed to address the risks and that the Rockwell Automation product is properly rated and installed for the intended use within the overall equipment or system.

Module Identification and Dimensions


See the table for identification information and figures for module dimensions.

Module Identification


Cat. No.	Name	Enclosure	Safety Inputs	Test Outputs ⁽¹⁾	Safety Outputs
1732DS-IB8	Safety input module	Meets IP67	8	8	-
1732DS-IB8XOBV4	Safety I/O module with solid state outputs		8	8	4 bipolar pairs

- ⁽¹⁾ Each test output can be set to function as a pulse test output or a standard output pulse. Test outputs are used in combination with a safety input. Broken wires in an external indicator can be detected for terminal T3 and T7 only.

1732DS-IB8X0BV4 Module Dimensions



1732DS-IB8 Module Dimensions



Observing Precautions for Correct Use

Read this for information related to operating directions after reading the Guard I/O DeviceNet Safety User Manual, publication [1791DS-UM001](#).

Do not use the unit in locations subject to the following:

- Direct sunlight
- Temperatures or humidity beyond the ranges noted in the Specifications section
- Corrosive or flammable gases
- Shock or vibration beyond the range noted in the Specifications section

Observing Precautions for Safe Use

Read this for a list of precautions for safe use.

- Wire conductors correctly and verify operation of the module before commissioning the system in which the module is incorporated, noting that incorrect wiring can lead to loss of safety function.
- Do not apply DC voltages exceeding rated voltages to the module.
- Apply properly specified voltages to the module inputs. Note that applying inappropriate voltages causes the module to fail to perform its specified function, which leads to loss of safety functions or damage to the module.
- Do not use test outputs as any safety output. Test outputs are not safety outputs.
- Be sure that qualified personnel confirm installation and conduct test operations and maintenance after installation of the module.
- Be sure that personnel familiar with machinery where the module is to be installed should conduct and verify installation.
- Do not dismantle, repair, or modify the module. This can lead to loss of its safety function.

- Use only appropriate components or devices complying with relevant safety standards corresponding to the required level of safety categories (safety integrity level). Conformity to requirements of safety category (safety integrity level) is determined as an entire system. We recommend you consult a certification body regarding assessment of conformity to required safety level.
- You are responsible for compliance with applicable standards for the entire system.
- Disconnect the module from the power supply when wiring.

ATTENTION

Safety state of the module and its data is defined as off state.

Serious injury can occur due to breakdown of safety outputs. Do not connect loads beyond the rated value of the safety outputs.

Serious injury can occur due to loss of required safety functions. Wire the module properly so that supply voltages or voltages for loads do not touch the safety outputs accidentally or unintentionally.

As serious injury can occur due to loss of safety functions, use appropriate devices as shown in the [Controlling Devices - Sample Requirements](#) table.

Controlling Devices - Sample Requirements


Device	Requirement	Allen-Bradley Bulletin Safety Components
Emergency stop switch	Use approved devices with direct opening mechanism complying with IEC/EN 60947-5-1.	Bulletin 800F, 800T
Door interlocking switch limit switch	Use approved devices with direct opening mechanism complying with IEC/EN 60947-5-1 and capable of switching microloads of 24V DC 5 mA.	Bulletin 440K, 440G, or 440H for interlock switch, Bulletin 440P or 802T for limit switch
Safety sensor	Use approved devices complying with the relevant product standards, regulations, and rules in the country where used.	Any Allen-Bradley Guardmaster product
Relay with forcibly guided contacts	Use approved devices with forcibly guided contacts complying with EN 50205. For feedback purposes, use devices with contacts capable of switching micro loads of 24V DC 5 mA.	Bulletin 700S, 100S
Other devices	Evaluate whether devices used are appropriate to satisfy requirements of safety category levels.	None

Install the Module

Read this section for installation-related information.

Set MAC ID

Set the MAC ID by using the rotary switches. The MAC ID is set to 63 by default.



Wiring the Module

Follow these guidelines when wiring the module:

- Do not share communication, input, or output lines with high voltage, referring to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).
- Wire correctly after confirming the signal names of all terminals.
- Follow wiring and installation guidelines for DeviceNet networks and be sure that you:
 - do not exceed a drop length of 5.7 m (19 ft).
 - note that the total drop length budget for the network is reduced by 0.30 m (1 ft) for each 1732DS module.


Working with I/O Connectors

See the figure that shows connectors. The modules have M12 female I/O connectors.

Input and Output Configuration

Input Configuration

Pin	Signal
1	Test Output n+1
2	Safe Input n+1
3	Input Common
4	Safe Input n
5	Test Output n



Output Configuration (1732DS-IB8XOBV4 module only)

Pin	Signal
1	Output +24V DC Power
2	Output n+1 (Sinking/Switch 24V DC Common)
3	Output Power Common
4	Output n (Sourcing/Switch 24V DC)
5	Output Power Common

The modules have mini-sealed DeviceNet In (male) and DeviceNet Out (female) connectors for daisy-chaining and a mini-sealed power (male) output connector.

DeviceNet and Power Configuration



DeviceNet Male and Female Configuration

Pin	Signal
1	Drain
2	V+
3	V-
4	CAN-H
5	CAN_L




Power Configuration

Pin	Signal
1	Output +24V DC Power ⁽¹⁾
2	Input +24V DC Power
3	Input Power Common
4	Output Power Common ⁽¹⁾

⁽¹⁾ 1732DS-IB8XOBV4 module only.

Terminal Positions

See the figure and table that show terminal positions.



44121

Terminal Positions

1732DS-IB8XOBV4 and 1732DS-IB8 Modules		1732DS-IB8XOBV4 Module Only	
A-1	Test Output 1	E-1	S+/24V DC ⁽¹⁾
A-2	Safety Input 1	E-2	Safety Output 1 ⁽²⁾ (Switch 24V DC Common)
A-3	Input Common	E-3	L-/24V DC Common ⁽³⁾
A-4	Safety Input 0	E-4	Safety Output 0 ⁽²⁾ (Switch 24V DC)
A-5	Test Output 0	E-5	L-/24V DC Common ⁽³⁾
B-1	Test Output 3	F-1	S+/24V DC ⁽¹⁾
B-2	Safety Input 3	F-2	Safety Output 3 ⁽²⁾ (Switch 24V DC Common)
B-3	Input Common	F-3	L-/24V DC Common ⁽³⁾
B-4	Safety Input 2	F-4	Safety Output 2 ⁽²⁾ (Switch 24V DC)
B-5	Test Output 2	F-5	L-/24V DC Common ⁽³⁾
C-1	Test Output 5	G-1	S+/24V DC ⁽¹⁾
C-2	Safety Input 5	G-2	Safety Output 5 ⁽²⁾ (Switch 24V DC Common)
C-3	Input Common	G-3	L-/24V DC Common ⁽³⁾
C-4	Safety Input 4	G-4	Safety Output 4 ⁽²⁾ (Switch 24V DC)
C-5	Test Output 4	G-5	L-/24V DC Common ⁽³⁾
D-1	Test Output 7	H-1	S+/24V DC ⁽¹⁾
D-2	Safety Input 7	H-2	Safety Output 7 ⁽²⁾ (Switch 24V DC Common)
D-3	Input Common	H-3	L-/24V DC Common ⁽³⁾
D-4	Safety Input 6	H-4	Safety Output 6 ⁽²⁾ (Switch 24V DC)
D-5	Test Output 6	H-5	L-/24V DC Common ⁽³⁾

⁽¹⁾ S+ denotes output return +24V DC.

⁽²⁾ Safety outputs can be used only as pairs. Safety outputs 0/1, 2/3, 4/5, and 6/7 must be controlled as a pair.

⁽³⁾ L- denotes output return common.

Interpret the Status Indicators

See the tables for information about how to interpret status indicators.

24V DC Input Power Indicator

State	Status	Description	Recommended Action
Off	No power	No power is applied.	Apply power to this section.
Solid green	Normal operation	The applied voltage is within specifications.	None.
Solid yellow	Input power out of specification	The input power is out of specification.	Check your configuration, wiring, and voltages and apply the changes.

24V DC Output Power Indicator (1732DS-IB8X0BV4 module only)

State	Status	Description	Recommended Action
Off	No power	No power is applied.	Apply power to this section.
Solid green	Normal operation	The applied voltage is within specifications.	None.
Solid yellow	Output power out of specification	The output power is out of specification.	Check your configuration, wiring, and voltages and apply the changes.

Module Status Indicator⁽¹⁾

State	Status	Description
Off	No power or autobauding	No power is applied to the DeviceNet connector.
Solid green	Normal operation	The module is operating normally.
Solid red	Unrecoverable fault	The module detected an unrecoverable fault.

Module Status Indicator⁽¹⁾

State	Status	Description
Flashing green	Module needs commissioning due to missing, incomplete, or incorrect configuration	Module is unconfigured.
Flashing red	Recoverable fault or user-initiated firmware update in progress	The module has detected a recoverable fault or user-initiated firmware update is in progress.
Flashing red and green	Device in self test	The module is performing its power-cycle diagnostic tests.

⁽¹⁾ For recommended action, refer to the user manual that covers these modules.

Network Status Indicator⁽¹⁾

State	Status	Description
Off	Module not online or no power	The module is not online with the network.
Flashing green	Module online with no connections in established state	The module identified the communication rate of the network but no connections are established.
Solid green	Module online with connections in established state	The module is operating normally.

Network Status Indicator⁽¹⁾

State	Status	Description
Flashing red	One or more I/O connections in timed-out state or user-initiated firmware update in progress	The module detected a recoverable network fault or user-initiated firmware update is in progress.
Solid red	Critical link failure	The module detected an error that prevents it from communicating on the network.
Flashing red and green	Communication faulted module	The module detected a network access error and is in communication faulted state. The module received and accepted an Identity Communication Faulted Request-long protocol message.

⁽¹⁾ For recommended action, refer to the user manual that covers these modules.

Safety Input Status Indicator

State	Status	Description	Recommended Action
Off	Safety input off or module being configured	The safety input is off or the module is being configured.	Turn the safety input on or wait for the module to be configured.
Solid yellow	Safety input on	The safety input is on.	None.
Solid red	Fault detected	A fault in the external wiring or input circuit detected.	Check configuration, field wiring, and devices. If no problem found, replace module.
Flashing red	Partner fault detected	A fault in the partner input circuit of a dual input configuration detected.	Check the field wiring and verify your configuration for the partner circuit. If no problem found, replace module.

Safety Output Status Indicator (1732DS-IB8XOBV4 module only)

State	Status	Description	Recommended Action
Off	Safety output off or module being configured	The safety output is off or the module is being configured.	Turn the safety output on or wait for the module to be configured.
Solid yellow	Safety output on	The safety output is on.	None.
Solid red	Fault detected	A fault in the output circuit was detected.	Check the circuit wiring and end device. If no problem found, replace module.
		Both tags in a dual channel circuit do not have the same value.	Make sure logic is driving tag values to the same state (off or on).
Flashing red	Partner fault detected	A fault in the partner of a dual output circuit was detected.	Check the circuit wiring and end device of the partner. If no problem found, replace module.

Configuration Lock Indicator⁽¹⁾

State	Status	Description	Recommended Action
Off	No configuration	Invalid configuration data.	None.
Solid yellow	Locked	Valid configuration, locked by a network configuration tool, such as RSNetWorx for DeviceNet software.	None.
Flashing yellow	Not locked	Valid configuration, owned by a network configuration tool, such as RSNetWorx for DeviceNet software.	None.

⁽¹⁾ Not applicable if owned by a GuardLogix controller.

Specifications

ArmorBlock Guard I/O DeviceNet Safety Module - 1732DS-IB8XOBV4, 1732DS-IB8

Attribute	Value
Safety Input	
Input type	Current sinking
Voltage, on-state input, min	11V DC
Current, on-state input, min	3.3 mA
Voltage, off-state input, max	5V DC
Current, off-state, max	1.3 mA
IEC 61131-2 (input type)	Type 3
Pulse Test Output	
Output type	Current sourcing
Pulse test output current	0.7 A
Residual voltage, max	1.2V
Output leakage current, max	0.1 mA
Short circuit protection	Yes
Current, max	25 mA - Current, max (to avoid fault when used as a muted lamp output)
Current, min	5 mA - Current, min (at which fault indication is generated when used as a muted lamp output)
Safety Output (1732DS-IB8XOBV4 module only)	
Output types	Current sourcing/current sinking - bipolar pair
Output current rating	2 A max per point 8 A total module @ 40 °C (104 °F) 6 A total module @ 60 °C (140 °F)
On-state voltage drop	±0.6V
Leakage current	±1.0 mA ⁽¹⁾

ArmorBlock Guard I/O DeviceNet Safety Module - 1732DS-IB8XOBV4, 1732DS-IB8


Attribute	Value
Internal resistance from P to M terminal	3.25 k Ω
Short circuit detection	Yes (short high and low and cross-circuit fault detect)
Short circuit protection	Electronic
Aggregate current of outputs per module	8 A @ 40 °C (104°F) 6 A @ 60 °C (140 °F)
Pilot duty rating	DC-14 Pilot Duty (1732DS-IB8XOBV4 module only)
Number of outputs	4 dual channel

⁽¹⁾ Includes the presence of a single P stuck-high or M stuck-low short.

General Specifications

Attribute	Value
Enclosure type rating	Meets IP65/66/67/69K (when marked)
Communication power supply voltage	11...25V DC (supplied from communication power supply)
Communication current consumption	85 mA at 24V DC
Operating voltage range	19.2...28.8V DC (24V DC, -20...20%)
Isolation voltage	50V (continuous), reinforced insulation type, I/O to DeviceNet network, I/O to power, and power to DeviceNet network, Tested at 750V DC for 60s

General Specifications

Attribute	Value
Product temperature versus current derating	 Product Temperature Versus Current Derating (combined current from both input and output supplies) 44199
Wiring category ⁽¹⁾	1 - on signal ports 1 - on power ports 2 - on communication ports
Weight, approx.	640 g (1.41 lb)
Dimensions (HxWxD), approx.	69 x 179 x 70 mm (2.7 x 7.0 x 2.8 in.)

⁽¹⁾ Use this Conductor Category information for planning conductor routing. Refer to Industrial Automation Wiring and Grounding Guidelines, publication [1770-4.1](#).


Environmental Specifications

Attribute	Value
Temperature, operating	IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock): -20...60 °C (-4...140 °F)
Temperature, storage	IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold) IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat) -45...85 °C (-49...185 °F)
Relative humidity	IEC 60068-2-30 (Test Db, Unpackaged Damp Heat): 5...95% noncondensing
Vibration	IEC 60068-2-6 (Test Fc, Operating): 5 g @ 10...500 Hz
Shock, operating	IEC 60068-2-27 (Test Ea, Unpackaged Shock): 30 g
Shock, nonoperating	IEC 60068-2-27 (Test Ea, Unpackaged Shock): 50 g
Emissions	CISPR 11: Group 1, Class A
ESD immunity	IEC 61000-4-2: 6 kV contact discharge 8 kV air discharge
Radiated RF immunity	IEC 61000-4-3: 10V/m with 1 kHz sine-wave 80%AM from 80...2000 MHz 10V/m with 200 Hz 50% Pulse 100%AM at 900 MHz 10V/m with 200 Hz 50% Pulse 100%AM at 1890 MHz 3V/m with 1 kHz sine-wave 80%AM from 2000...2700 MHz
Conducted RF immunity	IEC 61000-4-6: 10V rms with 1 kHz sine-wave 80%AM from 150 kHz...80 MHz
EFT/B immunity	IEC 61000-4-4: ±4 kV at 5 kHz on power ports ±3 kV at 5 kHz on signal ports ±2 kV at 5 kHz on communication ports

Environmental Specifications

Attribute	Value
Surge transient immunity	IEC 61000-4-5: ± 1 kV line-line (DM) and ± 2 kV line-earth (CM) on power ports ± 1 kV line-line (DM) and ± 2 kV line-earth (CM) on signal ports ± 2 kV line-earth (CM) on communication ports
Reaction Time	
Input reaction time, max	16.2 ms + set values of ON/OFF delays
Output reaction time, max	6.2 ms + (20 ms) relay response time (1732DS-IB8X0BV4 module)

Signal Sequence



While safety outputs are in an on state, the signal sequence shown in the figure is output continuously for fault diagnosis when output pulse testing is enabled. Confirm response time of device connected to safety outputs so the device does not malfunction due to off pulse.

Certifications

Certification	Value	
Certifications (when product is marked) ⁽¹⁾	c-UL-us	UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E65584.
	CE	European Union 2004/108/EC EMC Directive, compliant with: EN 61326-1; Meas./Control/Lab., Industrial Requirements EN 61000-6-2; Industrial Immunity EN 61000-6-4; Industrial Emissions EN 61131-2; Programmable Controllers (Clause 8, Zone A & B)
	C-Tick	Australian Radiocommunications Act, compliant with: AS/NZS CISPR 11; Industrial Emissions
	ODVA	ODVA conformance tested to DeviceNet specifications
	TÜV	TÜV Certified for Functional Safety up to and including Category 4 and SIL 3 ⁽²⁾

⁽¹⁾ See the Product Certification link at <http://www.ab.com> for Declarations of Conformity, Certificates, and other certification details.

⁽²⁾ When used with specified firmware revisions.

Additional Resources

For safe and correct use of the product, read these publications:

- DeviceNet Modules in Logix5000 Control Systems User Manual, publication [DNET-UM004](#)
- Guard I/O DeviceNet Safety Modules User Manual, publication [1791DS-UM001](#)

You can view or download publications at <http://literature.rockwellautomation.com>. To order paper copies of technical documentation, contact your local Rockwell Automation distributor or sales representative.

Rockwell Automation Support

Rockwell Automation provides technical information on the Web to assist you in using its products. At <http://www.rockwellautomation.com/support/>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnect support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://www.rockwellautomation.com/support/>.

Installation Assistance

If you experience a problem within the first 24 hours of installation, please review the information that's contained in this manual. You can also contact a special Customer Support number for initial help in getting your product up and running.

United States	1.440.646.3434 Monday – Friday, 8 a.m. – 5 p.m. EST
Outside United States	Please contact your local Rockwell Automation representative for any technical support issues.

New Product Satisfaction Return

Rockwell Automation tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning and needs to be returned, follow these procedures.

United States	Contact your distributor. You must provide a Customer Support case number (call the phone number above to obtain one) to your distributor in order to complete the return process.
Outside United States	Please contact your local Rockwell Automation representative for the return procedure.

Allen-Bradley, ArmorBlock Guard I/O, GuardLogix, GuardMaster, Logix5000, Rockwell Automation, TechConnect, and RSNetWorx for DeviceNet are trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444
Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640
Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 1732DS-IN001C-EN-P - April 2009

PN-44443

Supersedes Publication 1732DS-IN001B-EN-P - April 2007

Copyright © 2009 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.