

# **SYSMAC CS/CJ Series**

**CS1W-AD041-V1/AD081-V1/AD161**

**CS1W-DA041/DA08V/DA08C**

**CS1W-MAD44**

**CJ1W-AD041-V1/AD081-V1/AD042**

**CJ1W-DA021/DA041/DA08V/DA08C/DA042V**

**CJ1W-MAD42**

## **Analog I/O Units**

# **OPERATION MANUAL**

# **OMRON**



# **SYSMAC CS/CJ Series**

**CS1W-AD041-V1/AD081-V1/AD161**

**CS1W-DA041/DA08V/DA08C**

**CS1W-MAD44**

**CJ1W-AD041-V1/AD081-V1/AD042**

**CJ1W-DA021/DA041/DA08V/DA08C/DA042V**

**CJ1W-MAD42**

## **Analog I/O Units**

### **Operation Manual**

*Revised October 2010*



## Notice:

OMRON products are manufactured for use according to proper procedures by a qualified operator and only for the purposes described in this manual.

The following conventions are used to indicate and classify precautions in this manual. Always heed the information provided with them. Failure to heed precautions can result in injury to people or damage to property.

-  **DANGER** Indicates an imminently hazardous situation which, if not avoided, will result in death or serious injury. Additionally, there may be severe property damage.
-  **WARNING** Indicates a potentially hazardous situation which, if not avoided, could result in death or serious injury. Additionally, there may be severe property damage.
-  **Caution** Indicates a potentially hazardous situation which, if not avoided, may result in minor or moderate injury, or property damage.

## OMRON Product References

All OMRON products are capitalized in this manual. The word “Unit” is also capitalized when it refers to an OMRON product, regardless of whether or not it appears in the proper name of the product.

The abbreviation “Ch,” which appears in some displays and on some OMRON products, often means “word” and is abbreviated “Wd” in documentation in this sense.

The abbreviation “PLC” means Programmable Controller. “PC” is used, however, in some Programming Device displays to mean Programmable Controller.

## Visual Aids

The following headings appear in the left column of the manual to help you locate different types of information.

**Note** Indicates information of particular interest for efficient and convenient operation of the product.

**1,2,3...** 1. Indicates lists of one sort or another, such as procedures, checklists, etc.

## © OMRON, 1999

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form, or by any means, mechanical, electronic, photocopying, recording, or otherwise, without the prior written permission of OMRON.

No patent liability is assumed with respect to the use of the information contained herein. Moreover, because OMRON is constantly striving to improve its high-quality products, the information contained in this manual is subject to change without notice. Every precaution has been taken in the preparation of this manual. Nevertheless, OMRON assumes no responsibility for errors or omissions. Neither is any liability assumed for damages resulting from the use of the information contained in this publication.



# TABLE OF CONTENTS

## **PRECAUTIONS ..... xvii**

|   |                                        |       |
|---|----------------------------------------|-------|
| 1 | Intended Audience.....                 | xviii |
| 2 | General Precautions.....               | xviii |
| 3 | Safety Precautions.....                | xviii |
| 4 | Operating Environment Precautions..... | xix   |
| 5 | Application Precautions.....           | xx    |
| 6 | Conformance to EC Directives.....      | xxi   |

## **SECTION 1**

### **System Design ..... 1**

|     |                             |    |
|-----|-----------------------------|----|
| 1-1 | Features and Functions..... | 2  |
| 1-2 | Basic Configuration.....    | 11 |
| 1-3 | Function Applications.....  | 16 |

## **SECTION 2**

### **CS-series Analog Input Units**

#### **(CS1W-AD041-V1/081-V1/161) ..... 17**

|     |                                                      |    |
|-----|------------------------------------------------------|----|
| 2-1 | Specifications.....                                  | 18 |
| 2-2 | Operating Procedure.....                             | 24 |
| 2-3 | Components and Switch Settings.....                  | 31 |
| 2-4 | Wiring.....                                          | 36 |
| 2-5 | Exchanging Data with the CPU Unit.....               | 42 |
| 2-6 | Analog Input Functions and Operating Procedures..... | 56 |
| 2-7 | Adjusting Offset and Gain.....                       | 64 |
| 2-8 | Handling Errors and Alarms.....                      | 73 |

## **SECTION 3**

### **CJ-series Analog Input Units**

#### **(CJ1W-AD041-V1/081-V1)..... 81**

|     |                                                      |     |
|-----|------------------------------------------------------|-----|
| 3-1 | Specifications.....                                  | 82  |
| 3-2 | Operating Procedure.....                             | 87  |
| 3-3 | Components and Switch Settings.....                  | 93  |
| 3-4 | Wiring.....                                          | 97  |
| 3-5 | Exchanging Data with the CPU Unit.....               | 101 |
| 3-6 | Analog Input Functions and Operating Procedures..... | 108 |
| 3-7 | Adjusting Offset and Gain.....                       | 116 |
| 3-8 | Handling Errors and Alarms.....                      | 124 |

# TABLE OF CONTENTS

## SECTION 4

### **CJ-series Analog Input Units (CJ1W-AD042) . . . . . 131**

|     |                                                          |     |
|-----|----------------------------------------------------------|-----|
| 4-1 | Specifications . . . . .                                 | 132 |
| 4-2 | Operating Procedure . . . . .                            | 137 |
| 4-3 | Components and Switch Settings . . . . .                 | 142 |
| 4-4 | Wiring . . . . .                                         | 144 |
| 4-5 | Exchanging Data with the CPU Unit. . . . .               | 149 |
| 4-6 | Analog Input Functions and Operating Procedures. . . . . | 157 |
| 4-7 | Handling Errors and Alarms . . . . .                     | 166 |

## SECTION 5

### **CS-series Analog Output Units (CS1W-DA041/08V/08C) . . . . . 173**

|     |                                                            |     |
|-----|------------------------------------------------------------|-----|
| 5-1 | Specifications . . . . .                                   | 174 |
| 5-2 | Operating Procedure . . . . .                              | 178 |
| 5-3 | Components and Switch Settings . . . . .                   | 184 |
| 5-4 | Wiring . . . . .                                           | 187 |
| 5-5 | Exchanging Data with the CPU Unit. . . . .                 | 190 |
| 5-6 | Analog Output Functions and Operating Procedures . . . . . | 197 |
| 5-7 | Adjusting Offset and Gain . . . . .                        | 201 |
| 5-8 | Handling Errors and Alarms . . . . .                       | 211 |

## SECTION 6

### **CJ-series Analog Output Unit (CJ1W-DA021/041/08V/08C) . . . . . 217**

|     |                                                            |     |
|-----|------------------------------------------------------------|-----|
| 6-1 | Specifications . . . . .                                   | 218 |
| 6-2 | Operating Procedure . . . . .                              | 222 |
| 6-3 | Components and Switch Settings . . . . .                   | 230 |
| 6-4 | Wiring . . . . .                                           | 232 |
| 6-5 | Exchanging Data with the CPU Unit. . . . .                 | 236 |
| 6-6 | Analog Output Functions and Operating Procedures . . . . . | 245 |
| 6-7 | Adjusting Offset and Gain . . . . .                        | 252 |
| 6-8 | Handling Errors and Alarms . . . . .                       | 263 |

## SECTION 7

### **CJ-series Analog Output Unit (CJ1W-DA042V) . . . . . 269**

|     |                                                            |     |
|-----|------------------------------------------------------------|-----|
| 7-1 | Specifications . . . . .                                   | 270 |
| 7-2 | Operating Procedure . . . . .                              | 274 |
| 7-3 | Components and Switch Settings . . . . .                   | 278 |
| 7-4 | Wiring . . . . .                                           | 280 |
| 7-5 | Exchanging Data with the CPU Unit. . . . .                 | 283 |
| 7-6 | Analog Output Functions and Operating Procedures . . . . . | 289 |
| 7-7 | Handling Errors and Alarms . . . . .                       | 296 |



# TABLE OF CONTENTS

## SECTION 8

### **CS-series Analog I/O Unit (CS1W-MAD44) . . . . . 301**

|      |                                                            |     |
|------|------------------------------------------------------------|-----|
| 8-1  | Specifications . . . . .                                   | 302 |
| 8-2  | Operating Procedure . . . . .                              | 310 |
| 8-3  | Components and Switch Settings . . . . .                   | 317 |
| 8-4  | Wiring . . . . .                                           | 320 |
| 8-5  | Exchanging Data with the CPU Unit . . . . .                | 324 |
| 8-6  | Analog Input Functions and Operating Procedures . . . . .  | 332 |
| 8-7  | Analog Output Functions and Operating Procedures . . . . . | 339 |
| 8-8  | Ratio Conversion Function . . . . .                        | 342 |
| 8-9  | Adjusting Offset and Gain . . . . .                        | 345 |
| 8-10 | Handling Errors and Alarms . . . . .                       | 361 |

## SECTION 9

### **CJ-series Analog I/O Unit (CJ1W-MAD42) . . . . . 369**

|      |                                                            |     |
|------|------------------------------------------------------------|-----|
| 9-1  | Specifications . . . . .                                   | 370 |
| 9-2  | Operating Procedure . . . . .                              | 377 |
| 9-3  | Components and Switch Settings . . . . .                   | 384 |
| 9-4  | Wiring . . . . .                                           | 387 |
| 9-5  | Exchanging Data with the CPU Unit . . . . .                | 391 |
| 9-6  | Analog Input Functions and Operating Procedures . . . . .  | 400 |
| 9-7  | Analog Output Functions and Operating Procedures . . . . . | 409 |
| 9-8  | Ratio Conversion Function . . . . .                        | 415 |
| 9-9  | Adjusting Offset and Gain . . . . .                        | 418 |
| 9-10 | Handling Errors and Alarms . . . . .                       | 434 |

## Appendices

|   |                                                                               |     |
|---|-------------------------------------------------------------------------------|-----|
| A | Dimensions . . . . .                                                          | 441 |
| B | Sample Programs . . . . .                                                     | 445 |
| C | Data Memory Coding Sheets . . . . .                                           | 455 |
| D | Execution Times for Special Instructions for the CJ1W-AD042/-DA042V . . . . . | 481 |

### **Index . . . . . 483**

### **Revision History . . . . . 489**



## About this Manual:

This manual describes the installation and operation of the CS1W-AD041-V1, CS1W-AD081-V1, CS1W-AD161, CJ1W-AD041-V1, CJ1W-AD081-V1, and CJ1W-AD042 Analog Input Units; the CS1W-DA041, CS1W-DA08V, CS1W-DA08C, CJ1W-DA021, CJ1W-DA041, CJ1W-DA08V, CJ1W-DA08C, and CJ1W-DA042V Analog Output Units; and the CS1W-MAD44 and CJ1W-MAD42 Analog I/O Units. This manual includes the sections described below.

The input function of CS/CJ-series Analog I/O Units converts analog sensor output to the digital format and transmits it to CS/CJ-series PLCs. The output function converts digital data from the PLC to the analog format for output.

Please read this manual and the other manuals related to the CS/CJ-series Analog I/O Units carefully and be sure you understand the information provided before attempting to install and operate the Units. The manuals used with the CS/CJ-series Analog I/O Units are listed in the following table. The suffixes have been omitted from the catalog numbers. Be sure you are using the most recent version for your area.

| Name                                                                                                                                                                                                                            | Cat. No.              | Contents                                                                                                                                                                                                                                                               |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| SYSMAC CS/CJ-series Analog I/O Units Operation Manual<br>CS1W-AD041-V1/AD081-V1/AD161, CS1W-DA041/<br>DA08V/DA08C, CS1W-MAD44, CJ1W-AD041-V1/AD081-<br>V1, CJ1W-AD042, CJ1W-DA021/DA041/DA08V/DA08C,<br>CJ1W-DA042V, CJ1W-MAD42 | W345<br>(this manual) | Describes the application methods of the CS/CJ-series Analog Input, Analog Output, and Analog I/O Units.                                                                                                                                                               |
| CJ-series CJ2 CPU Unit Hardware User's Manual<br>CJ2H-CPU6□-EIP, CJ2H-CPU6□                                                                                                                                                     | W472                  | Provides the following information on PLCs built with CJ2 CPU Units: <ul style="list-style-type: none"> <li>• Overview</li> <li>• System design</li> <li>• System configuration</li> <li>• Maintenance</li> </ul>                                                      |
| CJ-series CJ2 CPU Unit Software User's Manual<br>CJ2H-CPU6□-EIP, CJ2H-CPU6□                                                                                                                                                     | W473                  | Provides the following information on PLCs built with CJ2 CPU Units: <ul style="list-style-type: none"> <li>• Overview of CPU Unit operation</li> <li>• Programming</li> <li>• System startup</li> <li>• Details on devices</li> <li>• Troubleshooting</li> </ul>      |
| SYSMAC CS-series<br>Programmable Controllers Operation Manual<br>CS1G/H-CPU□□-EV1, CS1G/H-CPU□□H                                                                                                                                | W339                  | Describes the installation and operation of the CS-series PLCs.                                                                                                                                                                                                        |
| SYSMAC CS Series<br>CS1D Duplex System Operation Manual<br>CS1D-CPU□□H CPU Units, CS1D-CPU□□S CPU Units,<br>CS1D-DPL01 Duplex Unit, CS1D-PA/PD□□ Power Supply Unit                                                              | W405                  | Provides an outline of and describes the design, installation, maintenance, and other basic operations for a Duplex System based on CS1D CPU Units.                                                                                                                    |
| CJ-series PLCs Operation Manual<br>CJ1H-CPU□□H-R, CJ1G/H-CPU□□H, CJ1G-CPU□□P,<br>CJ1G-CPU□□, CJ1H-CPU□□                                                                                                                         | W393                  | Provides the following information on CJ-series PLCs: <ul style="list-style-type: none"> <li>• Overview and features</li> <li>• System configuration design</li> <li>• Installation and wiring</li> <li>• I/O memory allocations</li> <li>• Troubleshooting</li> </ul> |
| CS/CJ/NSJ-series PLCs Programming Manual<br>CS1G/H-CPU□□H, CS1G/H-CPU□□-V1,<br>CS1D-CPU□□H, CS1D-CPU□□S, CJ1H-CPU□□H-R,<br>CJ1G/H-CPU□□H, CJ1G-CPU□□P, CJ1M-CPU□□,<br>CJ1G-CPU□□, NSJ□-□□□□(B)-G5D,<br>NSJ□-□□□□(B)-M3D         | W394                  | Provides the following information on CS/CJ/NSJ-series PLCs: <ul style="list-style-type: none"> <li>• Programming</li> <li>• Task functions</li> <li>• File memory</li> <li>• Various operations</li> </ul>                                                            |

| Name                                                                                                                                                                                                                                                           | Cat. No. | Contents                                                     |
|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|--------------------------------------------------------------|
| CS/CJ/NSJ-series PLCs Instructions Reference Manual<br>CJ2H-CPU6□-EIP, CJ2H-CPU6□, CS1G/H-CPU□□H,<br>CS1G/H-CPU□□-V1, CS1D-CPU□□H, CS1D-CPU□□S,<br>CJ1H-CPU□□H-R, CJ1G/H-CPU□□H, CJ1G-CPU□□P,<br>CJ1M-CPU□□, CJ1G-CPU□□, NSJ□-□□□□(B)-G5D,<br>NSJ□-□□□□(B)-M3D | W474     | Describes all the ladder programming instructions in detail. |
| CX-Programmer Operation Manual (Version 8.□)<br>WS02-CXPC□-V8                                                                                                                                                                                                  | W446     | Describes how to use the CX-Programmer.                      |
| SYSMAC CS/CJ-series Programming Consoles Operation Manual<br>CQM1H-PRO01, CQM1-PRO01, C200H-PRO27 + CS1W-KS001                                                                                                                                                 | W341     | Describes how to use the Programming Console.                |

**Section 1** describes the features and system configurations of the CS/CJ-series Analog I/O Unit.

**Section 2** explains how to use the CS1W-AD041-V1/081-V1/161 Analog Input Units.

**Section 3** explains how to use the CJ1W-AD041-V1/081-V1 Analog Input Units.

**Section 4** explains how to use the CJ1W-AD042 Analog Input Units.

**Section 5** explains how to use the CS1W-DA041/08V/08C Analog Output Units.

**Section 6** explains how to use the CJ1W-DA021/041/08V/08C Analog Output Units.

**Section 7** explains how to use the CJ1W-DA042V Analog Output Units.

**Section 8** explains how to use the CS1W-MAD44 Analog I/O Unit.

**Section 9** explains how to use the CJ1W-MAD42 Analog I/O Unit.

**Appendix A** provides details on dimensions.

**Appendix B** gives programming examples.

**Appendix C** provides data memory coding sheets.



**WARNING** Failure to read and understand the information provided in this manual may result in personal injury or death, damage to the product, or product failure. Please read each section in its entirety and be sure you understand the information provided in the section and related sections before attempting any of the procedures or operations given.

## ***Read and Understand this Manual***

Please read and understand this manual before using the product. Please consult your OMRON representative if you have any questions or comments.

## ***Warranty and Limitations of Liability***

### ***WARRANTY***

OMRON's exclusive warranty is that the products are free from defects in materials and workmanship for a period of one year (or other period if specified) from date of sale by OMRON.

OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, REGARDING NON-INFRINGEMENT, MERCHANTABILITY, OR FITNESS FOR PARTICULAR PURPOSE OF THE PRODUCTS. ANY BUYER OR USER ACKNOWLEDGES THAT THE BUYER OR USER ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE. OMRON DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED.

### ***LIMITATIONS OF LIABILITY***

OMRON SHALL NOT BE RESPONSIBLE FOR SPECIAL, INDIRECT, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED ON CONTRACT, WARRANTY, NEGLIGENCE, OR STRICT LIABILITY.

In no event shall the responsibility of OMRON for any act exceed the individual price of the product on which liability is asserted.

IN NO EVENT SHALL OMRON BE RESPONSIBLE FOR WARRANTY, REPAIR, OR OTHER CLAIMS REGARDING THE PRODUCTS UNLESS OMRON'S ANALYSIS CONFIRMS THAT THE PRODUCTS WERE PROPERLY HANDLED, STORED, INSTALLED, AND MAINTAINED AND NOT SUBJECT TO CONTAMINATION, ABUSE, MISUSE, OR INAPPROPRIATE MODIFICATION OR REPAIR.

## ***Application Considerations***

### ***SUITABILITY FOR USE***

OMRON shall not be responsible for conformity with any standards, codes, or regulations that apply to the combination of products in the customer's application or use of the products.

At the customer's request, OMRON will provide applicable third party certification documents identifying ratings and limitations of use that apply to the products. This information by itself is not sufficient for a complete determination of the suitability of the products in combination with the end product, machine, system, or other application or use.

The following are some examples of applications for which particular attention must be given. This is not intended to be an exhaustive list of all possible uses of the products, nor is it intended to imply that the uses listed may be suitable for the products:

- Outdoor use, uses involving potential chemical contamination or electrical interference, or conditions or uses not described in this manual.
- Nuclear energy control systems, combustion systems, railroad systems, aviation systems, medical equipment, amusement machines, vehicles, safety equipment, and installations subject to separate industry or government regulations.
- Systems, machines, and equipment that could present a risk to life or property.

Please know and observe all prohibitions of use applicable to the products.

**NEVER USE THE PRODUCTS FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCTS ARE PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.**

### ***PROGRAMMABLE PRODUCTS***

OMRON shall not be responsible for the user's programming of a programmable product, or any consequence thereof.

## ***Disclaimers***

### ***CHANGE IN SPECIFICATIONS***

Product specifications and accessories may be changed at any time based on improvements and other reasons.

It is our practice to change model numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the products may be changed without any notice. When in doubt, special model numbers may be assigned to fix or establish key specifications for your application on your request. Please consult with your OMRON representative at any time to confirm actual specifications of purchased products.

### ***DIMENSIONS AND WEIGHTS***

Dimensions and weights are nominal and are not to be used for manufacturing purposes, even when tolerances are shown.

### ***PERFORMANCE DATA***

Performance data given in this manual is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of OMRON's test conditions, and the users must correlate it to actual application requirements. Actual performance is subject to the OMRON Warranty and Limitations of Liability.

### ***ERRORS AND OMISSIONS***

The information in this manual has been carefully checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical, or proofreading errors, or omissions.





# PRECAUTIONS

This section provides general precautions for using the Programmable Controller (PLC) and Analog I/O Units.

**The information contained in this section is important for the safe and reliable application of the Analog I/O Unit. You must read this section and understand the information contained before attempting to set up or operate a PLC system and Analog I/O Unit.**

|   |                                         |       |
|---|-----------------------------------------|-------|
| 1 | Intended Audience .....                 | xviii |
| 2 | General Precautions .....               | xviii |
| 3 | Safety Precautions .....                | xviii |
| 4 | Operating Environment Precautions ..... | xix   |
| 5 | Application Precautions .....           | xx    |
| 6 | Conformance to EC Directives .....      | xxi   |

## 1 Intended Audience

This manual is intended for the following personnel, who must also have knowledge of electrical systems (an electrical engineer or the equivalent).

- Personnel in charge of installing FA systems
- Personnel in charge of designing FA systems
- Personnel in charge of managing FA systems and facilities

## 2 General Precautions

The user must operate the product according to the performance specifications described in the operation manuals.

Before using the product under conditions which are not described in the manual or applying the product to nuclear control systems, railroad systems, aviation systems, vehicles, combustion systems, medical equipment, amusement machines, safety equipment, and other systems, machines, and equipment that may have a serious influence on lives and property if used improperly, consult your OMRON representative.

Make sure that the ratings and performance characteristics of the product are sufficient for the systems, machines, and equipment, and be sure to provide the systems, machines, and equipment with double safety mechanisms.

This manual provides information for programming and operating OMRON Analog I/O Units. Be sure to read this manual before attempting to use the software and keep this manual close at hand for reference during operation.

 **WARNING** It is extremely important that a PLC and all PLC Units be used for the specified purpose and under the specified conditions, especially in applications that can directly or indirectly affect human life. You must consult with your OMRON representative before applying a PLC System to the above-mentioned applications.

 **WARNING** Do not apply the voltage/current outside the specified range to any Unit. It may cause a malfunction or fire.

## 3 Safety Precautions

 **WARNING** Do not attempt to take any Unit apart or touch any internal parts while power is being supplied. Doing so may result in electric shock.

 **WARNING** Do not touch any of the terminals or terminal blocks while power is being supplied. Doing so may result in electric shock.

 **WARNING** Provide safety measures in external circuits (i.e., not in the Programmable Controller), including the following items, in order to ensure safety in the system if an abnormality occurs due to malfunction of the PLC or another external factor affecting the PLC operation. Not doing so may result in serious accidents.

- Emergency stop circuits, interlock circuits, limit circuits, and similar safety measures must be provided in external control circuits.

- The PLC will turn OFF all outputs when its self-diagnosis function detects any error or when a severe failure alarm (FALS) instruction is executed. Unexpected operation, however, may still occur for errors in the I/O control section, errors in I/O memory, and other errors that cannot be detected by the self-diagnosis function. As a countermeasure for such errors, external safety measures must be provided to ensure safety in the system.
- The PLC outputs may remain ON or OFF due to deposition or burning of the output relays or destruction of the output transistors. As a countermeasure for such problems, external safety measures must be provided to ensure safety in the system.

 **WARNING** When the 24-VDC output (service power supply to the PLC) is overloaded or short-circuited, the voltage may drop and result in the outputs being turned OFF. As a countermeasure for such problems, external safety measures must be provided to ensure safety in the system.

 **Caution** When wiring crossovers between terminals, the total current for both terminals will flow in the line. Check the current capacities of all wires before wiring crossovers.

 **Caution** Tighten the screws on the terminal block of the AC Power Supply Unit to the torque specified in the operation manual. The loose screws may result in burning or malfunction.

 **Caution** Execute online edit only after confirming that no adverse effects will be caused by extending the cycle time. Otherwise, the input signals may not be readable.

 **Caution** With the CJ1W-AD042/-DA042V, always connect surge suppressors to inductive loads in the system (e.g., magnetic contactors, relays, and solenoids). Always separate devices that generate surge from the Analog I/O Units. Faulty Unit operation may cause unexpected system operation.

## 4 Operating Environment Precautions

 **Caution** Do not operate the control system in the following places:

- Locations subject to direct sunlight.
- Locations subject to temperatures or humidity outside the range specified in the specifications.
- Locations subject to condensation as the result of severe changes in temperature.
- Locations subject to corrosive or flammable gases.
- Locations subject to dust (especially iron dust) or salts.
- Locations subject to exposure to water, oil, or chemicals.
- Locations subject to shock or vibration.

 **Caution** Take appropriate and sufficient countermeasures when installing systems in the following locations:

- Locations subject to static electricity or other forms of noise.
- Locations subject to strong electromagnetic fields.
- Locations subject to possible exposure to radioactivity.
- Locations close to power lines.

 **Caution** The operating environment of the PLC System can have a large effect on the longevity and reliability of the system. Improper operating environments can lead to malfunction, failure, and other unforeseeable problems with the PLC System. Be sure that the operating environment is within the specified conditions at installation and remains within the specified conditions during the life of the system.

## 5 Application Precautions

Observe the following precautions when using the PLC.

 **WARNING** Always heed these precautions. Failure to abide by the following precautions could lead to serious or possibly fatal injury.

- Always connect to a class-3 ground (to 100  $\Omega$  or less) when installing the Units. Not connecting to a class-3 ground may result in electric shock.
- Always turn OFF the power supply to the PLC before attempting any of the following. Not turning off the power supply may result in malfunction or electric shock.
  - Mounting or dismounting I/O Units, CPU Units, Memory Cassettes, or any other Units.
  - Assembling the Units.
  - Setting DIP switch or rotary switches.
  - Connecting or wiring the cables.
  - Connecting or disconnecting the connectors.

 **Caution** Failure to abide by the following precautions could lead to faulty operation of the PLC or the system, or could damage the PLC or PLC Units. Always heed these precautions.

- Always use the power supply voltage specified in this manual. An incorrect voltage may result in malfunction or burning.
- Take appropriate measures to ensure that the specified power with the rated voltage and frequency is supplied. Be particularly careful in places where the power supply is unstable. An incorrect power supply may result in malfunction.
- Install external breakers and take other safety measures against short-circuiting in external wiring. Insufficient safety measures against short-circuiting may result in burning.
- Do not apply voltages to input sections in excess of the rated input voltage. Excess voltages may result in burning.
- Do not apply voltages or connect loads in excess of the maximum switching capacity to output sections. Excess voltage or loads may result in burning.

- Tighten the PLC terminal screws and cable screws to the torque specified in this manual.
- Wiring correctly, as indicated in this manual.
- Do not attempt to disassemble, repair, or modify any Units.
- Be sure to confirm that the DIP switch and the data memory (DM) are properly set.
- Leave the label attached to the Unit when wiring. Removing the label may result in malfunction.
- Remove the labels after the completion of wiring to ensure proper heat dissipation. Leaving the label attached may result in malfunction.
- Do not pull on cables and cords and do not bend them past their natural bending radius.
- Do not place any heavy objects on cables or cords.
- Mount the Unit only after checking the terminal block completely.
- Be sure that the terminal blocks, connectors, Memory Units, expansion cables, and other items with locking devices are properly locked into place.
- Check the user program for proper execution before actually running it on the Unit. Not checking the program may result in an unexpected operation.
- Use crimp terminals for wiring. Do not connect bare stranded wires directly to terminals. Connection of bare stranded wires may result in burning.
- Sufficiently confirm wiring, switch settings, and data set in the DM Area before turn ON the power supply.
- Confirm that no adverse effect will occur in the system before attempting any of the following. Not doing so may result in an unexpected operation.
  - Changing the operating mode of the PLC (including the setting of the startup operating mode).
  - Force-setting/force-resetting any bit in memory.
  - Changing the present value of any word or any set value in memory.
- Touch a grounded metal object to discharge static electricity from your body before touching any Unit.
- After replacing a CPU Unit, Special I/O Unit, CPU Bus Unit, or externally connected device, resume operation only after transferring to the new CPU Unit the contents of the DM Area, HR Area, and other data required for resuming operation, such as the program and parameters.
- The Analog I/O Units comply with the EMC Directive when assembled into a complete PLC system. Refer to the relevant product manuals for the conditions under which the EMC Directive are met, including grounding and cables.
- This is a class A product. In residential areas, it may cause radio interference. If radio interference occurs, the user may be required to take adequate measures to reduce interference.

## 6 Conformance to EC Directives

### Applicable Directives

- EMC Directives
- Low Voltage Directive

## Concepts

### ■ EMC Directives

OMRON supplies electric devices that are used built into other devices or manufacturing equipment. These OMRON products are designed to conform to the related EMC standards (see note) so that the devices or equipment in which they are used can more easily conform to EMC standards.

EMC-related performance of the OMRON devices that conform to EC Directives will vary depending on the configuration, wiring, and other conditions of the equipment or control panel on which the OMRON devices are installed. The customer must, therefore, perform the final check to confirm that devices and the overall machine conform to EMC standards.

**Note** Applicable EMC (Electromagnetic Compatibility) standards are as follows:

EMC (Electromagnetic Susceptibility)

CS-series PLCs: EN 61131-2 (CS1W-AD161: EN 61000-6-2)

CJ-series PLCs: EN 61000-6-2

EMI (Electromagnetic Interference)

CS-series PLCs: EN 61131-2 (CS1W-AD161: EN 61000-6-4)

CJ-series PLCs: EN 61000-6-4

### ■ Low Voltage Directive

Always ensure that devices operating at voltages of 50 to 1,000 V AC and 75 to 1,500 V DC meet the required safety standards for the PLC (EN 61131-2.)

CS/CJ-series products conform to EC Directives. However, the following precautions must be observed to ensure that the machine or device in which the CS/CJ-series PLC is used conforms to EC Directives:

1. The CS/CJ-series PLC must be installed within a control panel.
2. You must use reinforced insulation or double insulation for the DC power supplies used for the I/O power supplies. The DC power supply connected to the power supply terminals on PLCs using DC power must have an output hold time of at least 10 ms.
3. CS/CJ-series products conforming to EC Directives also conform to EN 61000-6-4 for EMI. Radiated emission characteristics (10-m regulations) may vary depending on the configuration of the control panel used, other devices connected to the control panel, wiring, and other conditions. You must therefore confirm that the overall machine or equipment conforms to EC Directives even when using CS/CJ-series products that conform to EC Directives.

## Conformance to EC Directives

## Conditions for Conforming to EMC Directives

The following immunity test conditions apply to CS/CJ-series Analog I/O Units.

### Overall Accuracy

|                     |                        |             |
|---------------------|------------------------|-------------|
| Analog Input Unit   | CS1W-AD161             | +4%/–6%     |
|                     | CJ1W-AD041-V1/AD081-V1 | +3%/–6%     |
|                     | CJ1W-AD042             | +6%/–6%     |
| Analog Output Units | CJ1W-DA021/DA041       | +4%/–1%     |
|                     | CJ1W-DA08V/DA08C       | +4%/–4%     |
|                     | CJ1W-DA042V            | +4.5%/–4.5% |
| Analog I/O Unit     | CS1W-MAD44             | +2%/–1%     |
|                     | CJ1W-MAD42             | +4%/–4%     |

Use shielded twisted-pair cable to connect analog inputs and connect the shield on the input line to the AG terminal.

# SECTION 1

## System Design

This section describes the features and system configurations of CS/CJ-series Analog I/O Units.


|       |                              |    |
|-------|------------------------------|----|
| 1-1   | Features and Functions ..... | 2  |
| 1-2   | Basic Configuration .....    | 11 |
| 1-2-1 | Mounting Procedure .....     | 13 |
| 1-2-2 | Precautions .....            | 15 |
| 1-3   | Function Applications .....  | 16 |

## 1-1 Features and Functions

### CS-series Analog I/O Units


#### Analog Input Units

CS1W-AD041-V1 CS1W-AD081-V1 CS1W-AD161




#### Analog Output Units

CS1W-DA041 CS1W-DA08V CS1W-DA08C



#### Analog I/O Unit

CS1W-MAD44



The SYSMAC CS Series includes CS1W-AD041-V1, CS1W-AD081-V1, and CS1W-AD161 Analog Input Units that convert analog signals to digital signals and transfer them to CS-series CPU Units, and CS1W-DA041, CS1W-DA08V, and CS1W-DA08C Analog Output Units for converting digital data in CS-series CPU Units into analog signals for output, and CS1W-MAD44 Analog I/O Units that have both analog input and output functions.


| Unit                 |               | Analog input         |                                                                | Analog output         |                                                                |
|----------------------|---------------|----------------------|----------------------------------------------------------------|-----------------------|----------------------------------------------------------------|
|                      |               | Maximum input points | Input signal range                                             | Maximum output points | Output signal range                                            |
| Analog Input Units   | CS1W-AD041-V1 | 4                    | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA | ---                   | ---                                                            |
|                      | CS1W-AD081-V1 | 8                    |                                                                |                       |                                                                |
|                      | CS1W-AD161    | 16                   |                                                                |                       |                                                                |
| Analog Out-put Units | CS1W-DA041    | ---                  | ---                                                            | 4                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA |
|                      | CS1W-DA08V    |                      |                                                                | 8                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V               |
|                      | CS1W-DA08C    |                      |                                                                | 8                     | 4 to 20 mA                                                     |
| Analog I/O Units     | CS1W-MAD44    | 4                    | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA | 4                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V               |




## CJ-series Analog I/O Units

## Analog Input Unit

CJ1W-AD041-V1  
CJ1W-AD081-V1




CJ1W-AD042




## Analog Output Unit


CJ1W-DA021  
CJ1W-DA041



CJ1W-DA042V




CJ1W-DA08V  
CJ1W-DA08C



## Analog I/O Unit

CJ1W-MAD42



The SYSMAC CJ Series includes CJ1W-AD041-V1, CS1W-AD081-V1, and CJ1W-AD042 Analog Input Units that convert analog signals to digital signals and transfer them to CJ-series CPU Units, and CJ1W-DA041, CS1W-DA021, and CJ1W-DA042V Analog Output Units for converting digital data from CJ-series CPU Units into analog signals for output.

The main specifications are listed in the following table.

| Unit               |               | Analog input         |                                                                 | Analog output         |                     | Conversion period                                                                                       |
|--------------------|---------------|----------------------|-----------------------------------------------------------------|-----------------------|---------------------|---------------------------------------------------------------------------------------------------------|
|                    |               | Maximum input points | Input signal range                                              | Maximum output points | Output signal range |                                                                                                         |
| Analog Input Units | CJ1W-AD041-V1 | 4                    | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA  | ---                   | ---                 | 1 ms/point<br>(Can be set to 250 $\mu$ s/point.)                                                        |
|                    | CJ1W-AD081-V1 | 8                    |                                                                 |                       |                     |                                                                                                         |
|                    | CJ1W-AD042    | 4                    | -10 to 10 V<br>0 to 10 V<br>-5 to 5 V<br>1 to 5 V<br>4 to 20 mA |                       |                     | 20 $\mu$ s for 1 point<br>25 $\mu$ s for 2 points<br>30 $\mu$ s for 3 points<br>35 $\mu$ s for 4 points |

| Unit                |             | Analog input         |                                                                | Analog output         |                                                                | Conversion period                                                                                       |
|---------------------|-------------|----------------------|----------------------------------------------------------------|-----------------------|----------------------------------------------------------------|---------------------------------------------------------------------------------------------------------|
|                     |             | Maximum input points | Input signal range                                             | Maximum output points | Output signal range                                            |                                                                                                         |
| Analog Output Units | CJ1W-DA041  | ---                  | ---                                                            | 4                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA | 1 ms/point                                                                                              |
|                     | CJ1W-DA021  |                      |                                                                | 2                     |                                                                |                                                                                                         |
|                     | CJ1W-DA08V  |                      |                                                                | 8                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V               | 1 ms/point<br>(Can be set to 250 $\mu$ s/point.)                                                        |
|                     | CJ1W-DA08C  |                      |                                                                | 8                     | 4 to 20 mA                                                     |                                                                                                         |
|                     | CJ1W-DA042V |                      |                                                                | 4                     | -10 to 10 V<br>0 to 10 V<br>1 to 5 V                           | 20 $\mu$ s for 1 point<br>25 $\mu$ s for 2 points<br>30 $\mu$ s for 3 points<br>35 $\mu$ s for 4 points |
| Analog I/O Units    | CJ1W-MAD42  | 4                    | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA | 2                     | -10 to 10 V<br>0 to 10 V<br>0 to 5 V<br>1 to 5 V<br>4 to 20 mA | 1 ms/point<br>(Can be set to 500 $\mu$ s/point.)                                                        |


**Note** The input signal range or output signal range can be set separately for each input or output.

Unit support for functions is shown in the following table.

| Unit                |               | Input disconnection detection | Peak value hold | Output hold    | Mean value processing | Proportional conversion | Offset and gain adjustment | Scaling        | Direct conversion |
|---------------------|---------------|-------------------------------|-----------------|----------------|-----------------------|-------------------------|----------------------------|----------------|-------------------|
| Analog Input Units  | CJ1W-AD041-V1 | Supported.                    | Supported.      | Not supported. | Supported.            | Not supported.          | Supported.                 | Not supported. | Not supported.    |
|                     | CJ1W-AD081-V1 | Supported.                    | Supported.      | Not supported. | Supported.            | Not supported.          | Supported.                 | Not supported. | Not supported.    |
|                     | CJ1W-AD042    | Supported.                    | Supported.      | Not supported. | Supported.            | Not supported.          | Not supported.             | Supported.     | Supported.        |
| Analog Output Units | CJ1W-DA041    | Not supported.                | Not supported.  | Supported.     | Not supported.        | Not supported.          | Supported.                 | Not supported. | Not supported.    |
|                     | CJ1W-DA021    | Not supported.                | Not supported.  | Supported.     | Not supported.        | Not supported.          | Supported.                 | Not supported. | Not supported.    |
|                     | CJ1W-DA08V    | Not supported.                | Not supported.  | Supported.     | Not supported.        | Not supported.          | Supported.                 | Supported.     | Not supported.    |
|                     | CJ1W-DA08C    | Not supported.                | Not supported.  | Supported.     | Not supported.        | Not supported.          | Supported.                 | Supported.     | Not supported.    |
|                     | CJ1W-DA042V   | Not supported.                | Not supported.  | Supported.     | Not supported.        | Not supported.          | Not supported.             | Supported.     | Supported.        |
| Analog I/O Units    | CJ1W-MAD42    | Supported.                    | Supported.      | Supported.     | Supported.            | Supported.              | Supported.                 | Supported.     | Not supported.    |


### Input Disconnection Detection Function

The input disconnection detection function can be used for analog inputs within an input signal range of 1 to 5 V (4 to 20 mA). Any input under 0.3 V (1.2 mA) will be regarded as a disconnection. For details, refer to 2-6-5, 3-6-5, 4-6-6, 8-6-4 or 9-6-6.




### Peak Value Hold Function

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). This function can be used with analog input. The following diagram shows how digital conversion values are affected when the peak value hold function is used. For details, refer to 2-6-4, 3-6-4, 4-6-5, 8-6-3 or 9-6-4.




### Output Hold Function

The output hold function can be used to hold the analog output value at any preset value when there is a fatal error at the CPU Unit or when specified by the CPU Unit. When output is stopped, CLR, HOLD, or MAX can be selected for output. For details, refer to 5-6-3, 6-6-4, 7-6-3, 8-7-2 or 9-7-3.




**Mean Value Function**


The mean value function can be used to remove erroneous values that occur due to factors such as noise that is included in analog inputs. The operating mean is taken without affecting the data refresh cycle. For details, refer to 2-6-3, 3-6-3, 4-6-3, 8-6-2 or 9-6-3.

**Ratio Conversion Function**

The CS1W-MAD44 and CJ1W-MAD42 Analog I/O Unit can output in analog format the results of analog inputs calculated for ratio and bias. For details, refer to 8-8 or 9-8.

**Offset and Gain Adjustment Function**

The A/D and D/A converter offset deviation and gain deviation can be adjusted for each input and output. The offset and gain adjustments are made with the Unit set for the adjustment mode, and the adjustment values are stored in the Unit's built-in EEPROM. For details, refer to 2-7, 3-7, 5-7, 6-7, 8-9 or 9-9.

**Scaling Function**

Refer to 4-6-4, 6-6-5, 7-6-4, 9-6-5 and 9-7-4.


With CS1W-AD042 Analog Input Units (See note 1.), CJ1W-DA08V/08C/042V Analog Output Units (See note 2.), and CJ1W-MAD42 Analog I/O Units, input analog values and output analog set values can be automatically converted into user-specified units. This scaling function eliminates the previous need to provide programs (e.g., scaling using the SCL instruction) for numeric conversion to different units.

When upper and lower limits have been preset in 16-bit binary data in the CPU Unit's DM Area, within a decimal range of -32,000 to +32,000, input

analog values and output analog set values can be automatically converted into user-specified units. (See note 3.) (Two's complements are used for negative analog input conversion values and analog output set values.)

- Note**
1. Only input scaling is supported by CJ1W-AD042 Analog Input Units.
  2. Only output scaling is supported by CJ1W-DA08V/08C/042V Analog Output Units.
  3. With the CJ1W-DA08V/08C Analog Output Unit and CJ1W-MAD42 Analog I/O Unit, scaling is possible only for a conversion period of 1 ms and a resolution of 4,000. The scaling function is not enabled for a conversion time of 250  $\mu$ s (500  $\mu$ s for the CJ1W-MAD42) and a resolution of 8,000.


#### Conceptual Diagram of Scaling (CJ1M-MAD42 Only)



#### Direct Conversion

Refer to pages 158 and 291.

Direct conversion can be used with the CJ1W-AD042 Analog Input Unit and CJ1W-DA042V Analog Output Unit. Direct conversion can be used to immediately perform conversion for an Analog Input Unit or Analog Output Unit and at the same time read or output the conversion data. With the CJ1W-AD042 Analog Input Unit, A/D conversion is performed and the converted value is refreshed immediately when the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is executed. With the CJ1W-DA042V Analog Output Unit, the conversion set value is refreshed and D/A conversion is performed immediately when the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed. A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion.



Direct conversion enables creating a consistent input-processing-output time for superior periodic control. This is not possible with the following methods.

- Refreshing I/O during the CPU Unit's cycle
- Using the I/O REFRESH (IORF) instruction
- Using the SPECIAL I/O UNIT I/O REFRESH (FIORF) instruction

## Setting Up Direct Conversion

This section provides the basic procedures for setting scheduled interrupt tasks, setting the High-speed Analog Units, and writing the ladder programming to set up direct conversion (analog-to-digital or digital-to-analog).

### 1. Setting a Scheduled Interrupt Task

For details, refer to the *CX-Programmer Operation Manual* (Cat. No. W446).


1,2,3...

1. Right-click **Programs** in the project workspace and, from the pop-up menu, select **Insert Program** and then either **Ladder**, **Structured Text**, or **SFC**.




2. Use the following procedure to assign the program to a scheduled interrupt task.  
Right-click **Programs** in the project workspace and select **Properties** from the pop-up menu.

- Assign the program to interrupt task 02 (scheduled interrupt 0).



- Set the time unit that will be used to set the scheduled interrupt interval. Set the interval to 10 ms, 1.0 ms, or 0.1 ms in the PLC Setup.



Note With a CJ2 CPU Unit, the overhead time required to start the interrupt task can be shortened.


Refer to the *SYSMAC CJ-series CJ2 CPU Unit Software User's Manual* (Cat. No. W473) for details.

## 2. Setting CJ1W-AD042 or CJ1W-DA042V Parameters

For details, refer to the *CX-Programmer Operation Manual* (Cat. No. W446).

**1,2,3...**


- Open the I/O Table Window.
- Double-click the CJ1W-AD042 or CJ1W-DA042V. The Edit Parameters Dialog Box for the selected Unit will be displayed.

3. Select *Direct Conversion Mode*.

## 3. Programming Example

1,2,3...

1. CJ1W-AD042: Unit number 3, CJ1W-DA042V: Unit number 7
2. The AIDC instruction is used to send a request to the CJ1W-AD042 Unit with unit number 3 to perform analog-to-digital conversion for analog input 1. The converted input value is written to CIO 2031. The value in CIO 2031 is used in data processing and the result is written to CIO 2071. The AODC instruction is then used to send a request to the CJ1W-DA042V Unit with unit number 7 to perform digital-to-analog conversion. (AIDC operands: The unit number and analog input number, AODC operands: The unit number and analog output number)




3. Enable the task. The SET INTERRUPT MASK instruction (MSKS) is used in the main task to set the scheduled interrupt interval and start execution of the scheduled interrupts. (MSKS operands: "4" (specifies interrupt task 2 (scheduled interrupt 0)) and the interrupt interval)






## 1-2 Basic Configuration

### CS-series PLCs



**Note** The above diagram is an installation example for the CS1W-AD081-V1 Analog Input Unit and CS1W-DA08V Analog Output Unit.

**CJ-series PLCs**

**Note** The above diagram is an installation example for the CJ1W-AD041-V1/081-V1 Analog Input Unit and CJ1W-DA021/041 Analog Output Unit.

**Mounting Restrictions****CS-series PLCs**

The CS1W-MAD44 Analog I/O Unit is a Special I/O Unit of the CS Series.

CS1W-MAD44 Analog I/O Units can be mounted to either CS-series CPU Racks or CS-series Expansion Racks. These Analog I/O Units cannot be mounted to C200H Expansion I/O Racks or SYSMAC BUS Slave Racks.

The number of Analog I/O Units that can be mounted to one Rack (i.e., a CPU Rack or Expansion Rack) depends on the maximum supply current of the Power Supply Unit and the current consumption of other Units. If a Rack is to be mounted with Analog Input, Output, or I/O Units only, the following restrictions will apply.

| Power Supply Unit                                                                                   | Rack           | CS1W-AD041-V1<br>CS1W-AD081-V1<br>(5 VDC<br>120 mA) | CS1W-DA041<br>CS1W-DA08V<br>(5 VDC<br>130 mA) | CS1W-MAD44<br>(5 VDC<br>200 mA) | CS1W-DA08C<br>(5 VDC<br>130 mA) | CS1W-AD161<br>(5 VDC<br>150 mA) |
|-----------------------------------------------------------------------------------------------------|----------------|-----------------------------------------------------|-----------------------------------------------|---------------------------------|---------------------------------|---------------------------------|
| C200HW-PA204<br>C200HW-PA204S<br>C200HW-PA204R<br>C200HW-PA204C<br>C200HW-PD024<br>(4.6 A at 5 VDC) | CPU Rack       | 6                                                   | 3                                             | 3                               | 2                               | 8                               |
|                                                                                                     | Expansion Rack | 6                                                   | 3                                             | 3                               | 2                               | 9                               |
| C200HW-PA209R<br>(9 A at 5 VDC)                                                                     | CPU Rack       | 10                                                  | 7                                             | 6                               | 5                               | 10                              |
|                                                                                                     | Expansion Rack | 10                                                  | 7                                             | 6                               | 5                               | 10                              |
| CS1D-PA207R<br>(7 A at 5 VDC)                                                                       | CPU Rack       | 8                                                   | 5                                             | 4                               | 4                               | 8                               |
|                                                                                                     | Expansion Rack | 9                                                   | 6                                             | 5                               | 4                               | 9                               |
| CS1D-PD024<br>(4.3 A at 5 VDC)                                                                      | CPU Rack       | 6                                                   | 3                                             | 2                               | 2                               | 7                               |
|                                                                                                     | Expansion Rack | 6                                                   | 3                                             | 2                               | 2                               | 8                               |

**Note** The I/O bits of the Special I/O Unit are allocated according to the setting of the unit number switches on the front panel of the Unit, and not the slot number where the Unit is mounted.

### CJ-series PLCs

CJ-series Analog I/O Units are Special I/O Unit of the CJ-series PLCs.

These Units can be connected in the CJ-series CPU Rack or Expansion Racks. The number of Analog I/O Units that can be connected in each Rack will depend on the current consumption of the other Units in the Rack. The number of Analog I/O Units that can be mounted to one Rack (i.e., a CPU Rack or Expansion Rack) depends on the current consumption of other Units.

The maximum number of Analog Input Units, Analog Output Units, or Analog I/O Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP) is given in the following table for when only these Units are mounted.

| Power Supply Unit                                            | Rack           | CJ1W-DA021<br>CJ1W-DA041<br>(5 VDC 120 mA)<br>CJ1W-DA08V<br>CJ1W-DA08C<br>(5 VDC 140 mA) | CS1W-AD041-V1<br>CJ1W-AD081-V1<br>(5 VDC 420 mA)<br>CJ1W-DA042V<br>(5 VDC 400 mA) | CJ1W-AD042<br>(5 VDC 520 mA) | CJ1W-MAD42<br>(5 VDC 580 mA) |
|--------------------------------------------------------------|----------------|------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|------------------------------|------------------------------|
| CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025<br>(5.0 A at 5 VDC) | CPU Rack       | 10                                                                                       | 10                                                                                | 8                            | 7                            |
|                                                              | Expansion Rack | 10                                                                                       | 10                                                                                | 9                            | 8                            |
| CJ1W-PA202<br>(2.8 A at 5 VDC)                               | CPU Rack       | 10                                                                                       | 5                                                                                 | 4                            | 4                            |
|                                                              | Expansion Rack | 10                                                                                       | 6                                                                                 | 5                            | 4                            |
| CJ1W-PD022<br>(2.0 A at 5 VDC)                               | CPU Rack       | 10                                                                                       | 3                                                                                 | 3                            | 2                            |
|                                                              | Expansion Rack | 10                                                                                       | 4                                                                                 | 3                            | 3                            |


**Note** The I/O bits of the Special I/O Unit are allocated according to the setting of the unit number switches on the front panel of the Unit, and not the order in which it is connected.

## 1-2-1 Mounting Procedure

### CS-series PLCs


Use the following procedure to mount Analog I/O Units to the Backplane.

- 1,2,3...**
1. Lock the top of the Analog I/O Unit into the slot on the Backplane and rotate the Unit downwards as shown in the following diagram.




2. While making sure to align the Unit properly with the connectors, tighten the mounting screws securely to the tightening torque of 0.4 N·m.

- To remove the Unit, first loosen the mounting screws using a Phillips screwdriver.




Leave enough space below each Rack, as shown in the following diagram for mounting and removing the Units.



## CJ-series PLCs

Analog I/O Units are connected as I/O Units in the system configuration, as shown below.


CPU Rack



Use the following procedure to connect Analog I/O Units to a CJ-series Rack.

- 
- Diagram illustrating the assembly of two cabinets using the hook and connector system. The diagram shows two cabinets being joined. Labels indicate the components: Hooks, Connector, and Hook holes. Arrows point from the labels to the corresponding parts on the cabinets.

- Move the sliders to the back until they click into place.




- ### 1-2-2 Precautions

When wiring a Unit, place a label over the top of the Unit to prevent wire clippings or other materials from getting inside the Unit. When the wiring has been completed, the label must be removed to prevent heat radiation.

Remove the label after the wiring has been completed.

## CJ-series PLCs



## 1-3 Function Applications

| Function                | Application                                                                                                                                     | Page                        |
|-------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| Mean value processing   | Performs a smooth conversion when the input fluctuation is too extreme.<br>Example: Removes noise interference from data such as flow/pressure. | 59, 111, 160, 334, 402      |
| Peak value hold         | Holds the maximum value that has been read.<br>Holds the data that is less than the maximum value.                                              | 62, 114, 164, 337, 405      |
| Disconnection detection | Detects disconnection of input signals.                                                                                                         | 63, 115, 165, 338, 408      |
| Output hold             | Holds the output signal at the previous value for certain conditions, such as errors.                                                           | 200, 248, 292, 341, 412     |
|                         | Holds the output signal in the lower-limit value or 0 V for certain conditions, such as errors.                                                 |                             |
|                         | Holds the output signal in the upper-limit value for certain conditions, such as errors.                                                        |                             |
| Ratio conversion        | Uses the Analog I/O Unit as a gradient setting device for setting ratio and bias.                                                               | 342, 415                    |
| Offset gain adjustment  | Adjusts the offset and gain, and uses the I/O functions.                                                                                        | 64, 116, 203, 252, 347, 418 |
| Direct conversion       | Creating a consistent input-processing-output time                                                                                              | 158, 291                    |

# SECTION 2

## CS-series Analog Input Units (CS1W-AD041-V1/081-V1/161)

This section explains how to use the CS1W-AD041-V1/081-V1/161 Analog Input Units.

|       |                                                       |    |
|-------|-------------------------------------------------------|----|
| 2-1   | Specifications .....                                  | 18 |
| 2-1-1 | Specifications .....                                  | 18 |
| 2-1-2 | Input Function Block Diagram.....                     | 21 |
| 2-1-3 | Input Specifications .....                            | 21 |
| 2-2   | Operating Procedure .....                             | 24 |
| 2-2-1 | Procedure Examples .....                              | 25 |
| 2-3   | Components and Switch Settings .....                  | 31 |
| 2-3-1 | Indicators .....                                      | 32 |
| 2-3-2 | Unit Number Switches .....                            | 33 |
| 2-3-3 | Operation Mode Switch .....                           | 34 |
| 2-3-4 | Voltage/Current Switch (CS1W-AD041-V1/AD081-V1) ..... | 35 |
| 2-4   | Wiring .....                                          | 36 |
| 2-4-1 | Terminal Arrangement .....                            | 36 |
| 2-4-2 | Internal Circuitry .....                              | 37 |
| 2-4-3 | Voltage Input Disconnection.....                      | 38 |
| 2-4-4 | Input Wiring Example .....                            | 39 |
| 2-4-5 | Input Wiring Considerations.....                      | 42 |
| 2-5   | Exchanging Data with the CPU Unit .....               | 42 |
| 2-5-1 | Outline of Data Exchange.....                         | 42 |
| 2-5-2 | Unit Number Settings .....                            | 43 |
| 2-5-3 | Special I/O Unit Restart Bits .....                   | 44 |
| 2-5-4 | Fixed Data Allocations .....                          | 45 |
| 2-5-5 | I/O Refresh Data Allocations .....                    | 50 |
| 2-6   | Analog Input Functions and Operating Procedures ..... | 56 |
| 2-6-1 | Input Settings and Conversion Values .....            | 56 |
| 2-6-2 | Conversion Time/Resolution Setting .....              | 58 |
| 2-6-3 | Mean Value Processing.....                            | 59 |
| 2-6-4 | Peak Value Hold Function .....                        | 62 |
| 2-6-5 | Input Disconnection Detection Function .....          | 63 |
| 2-6-6 | Scaling Function (CS1W-AD161 Only).....               | 64 |
| 2-7   | Adjusting Offset and Gain .....                       | 64 |
| 2-7-1 | Adjustment Mode Operational Flow .....                | 64 |
| 2-7-2 | Input Offset and Gain Adjustment Procedures.....      | 66 |
| 2-8   | Handling Errors and Alarms .....                      | 73 |
| 2-8-1 | Indicators and Error Flowchart.....                   | 73 |
| 2-8-2 | Alarms Occurring at the Analog Input Unit.....        | 74 |
| 2-8-3 | Errors in the CPU Unit .....                          | 77 |
| 2-8-4 | Restarting Special I/O Units.....                     | 78 |
| 2-8-5 | Troubleshooting .....                                 | 78 |

## 2-1 Specifications

### 2-1-1 Specifications

| Item                                          |                                                 | CS1W-AD041-V1                                                                                                                                          | CS1W-AD081-V1                                                            | CS1W-AD161                                                                                                                                             |
|-----------------------------------------------|-------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------|
| Unit type                                     |                                                 | CS-series Special I/O Unit                                                                                                                             |                                                                          |                                                                                                                                                        |
| Isolation (See note 1.)                       |                                                 | Between inputs and PLC signals: Photocoupler<br>(No isolation between input signals.)                                                                  |                                                                          |                                                                                                                                                        |
| External terminals                            |                                                 | 21-point detachable terminal block (M3 screws)                                                                                                         |                                                                          | Two 34-pin MIL connectors                                                                                                                              |
| Affect on CPU Unit cycle time                 |                                                 | 0.2 ms                                                                                                                                                 |                                                                          |                                                                                                                                                        |
| Current consumption                           |                                                 | 120 mA max. at 5 VDC, 90 mA max. at 26 VDC                                                                                                             |                                                                          | 150 mA max. at 5 VDC,<br>55 mA max. at 26 VDC                                                                                                          |
| Dimensions (mm) (See note 2.)                 |                                                 | 35 × 130 × 126 (W × H × D)                                                                                                                             |                                                                          | 35 × 130 × 119 (W × H × D)                                                                                                                             |
| Weight                                        |                                                 | 450 g max.                                                                                                                                             |                                                                          |                                                                                                                                                        |
| General specifications                        |                                                 | Conforms to general specifications for SYSMAC CS Series.                                                                                               |                                                                          |                                                                                                                                                        |
| Mounting position                             |                                                 | CS-series CPU Rack or CS-series Expansion Rack<br>(Cannot be mounted to a C200H Expansion I/O Rack or a SYSMAC BUS Slave Rack.)                        |                                                                          |                                                                                                                                                        |
| Maximum number of Units<br>(See note 3.)      |                                                 | Refer to the table on page 19.                                                                                                                         |                                                                          |                                                                                                                                                        |
| Data exchange with CPU Units<br>(See note 4.) |                                                 | Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959): 10 words per Unit<br>Special I/O Unit Area in DM Area (D20000 to D29599): 100 words per Unit |                                                                          | Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959): 20 words per Unit<br>Special I/O Unit Area in DM Area (D20000 to D29599): 200 words per Unit |
| Input specifications                          | Number of analog inputs                         | 4                                                                                                                                                      | 8                                                                        | 16                                                                                                                                                     |
|                                               | Input signal range<br>(See note 5.)             | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>−10 to 10 V<br>4 to 20 mA<br>(See note 6.)                                                                        |                                                                          |                                                                                                                                                        |
|                                               | Maximum rated input (for 1 point) (See note 7.) | Voltage Input: ±15 V<br>Current Input: ±30 mA                                                                                                          |                                                                          |                                                                                                                                                        |
|                                               | Input impedance                                 | Voltage Input: 1 MΩ min.<br>Current Input: 250 Ω (rated value)                                                                                         |                                                                          |                                                                                                                                                        |
|                                               | Resolution                                      | 4,000/8,000 (See note 8.)                                                                                                                              |                                                                          |                                                                                                                                                        |
|                                               | Converted output data                           | 16-bit binary data                                                                                                                                     |                                                                          |                                                                                                                                                        |
|                                               | Accuracy<br>(See note 9.)                       | 23±2°C                                                                                                                                                 | Voltage Input: ±0.2% of full scale<br>Current Input: ±0.4% of full scale | Voltage Input: ±0.2% of full scale<br>Current Input: ±0.2% of full scale                                                                               |
|                                               |                                                 | 0°C to 55°C                                                                                                                                            | Voltage Input: ±0.4% of full scale<br>Current Input: ±0.6% of full scale | Voltage Input: ±0.4% of full scale<br>Current Input: ±0.4% of full scale                                                                               |
|                                               | A/D conversion period<br>(See note 10.)         | 1.0 ms or 250 μs per point max. (See note 8.)                                                                                                          |                                                                          |                                                                                                                                                        |



| Item            |                               | CS1W-AD041-V1                                                                                                                                                    | CS1W-AD081-V1 | CS1W-AD161                                                                                                                                                                                                                       |
|-----------------|-------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input functions | Mean value processing         | Stores the last “n” data conversions in the buffer, and stores the mean value of the conversion values.<br>Number of mean value buffers: n = 2, 4, 8, 16, 32, 64 |               |                                                                                                                                                                                                                                  |
|                 | Peak value hold               | Stores the maximum conversion value while the Peak Value Hold Bit is ON.                                                                                         |               |                                                                                                                                                                                                                                  |
|                 | Input disconnection detection | Detects the disconnection and turns ON the Disconnection Detection Flag. (See note 11.)                                                                          |               |                                                                                                                                                                                                                                  |
|                 | Scaling function              | None                                                                                                                                                             | None          | Enabled only for conversion time of 1 ms and resolution of 4,000. Setting any values within a range of $\pm 32,000$ as the upper and lower limits allows the A/D conversion result to be output with these values as full scale. |

- Note**
1. Do not apply a voltage higher than 600 V to the terminal block when performing withstand voltage test on this Unit. Otherwise, internal elements may deteriorate.
  2. Refer to *Dimensions* on page 441 for details on the Unit's dimensions.
  3. The maximum number of Analog Input Units that can be mounted to one Rack depends on the Power Supply Unit mounted to the Rack.

| Power Supply Unit                                                                                   | Rack           | CS1W-AD041-V1<br>CS1W-AD081-V1<br>(5 VDC 120 mA) | CS1W-DA041<br>CS1W-DA08V<br>(5 VDC 130 mA) | CS1W-MAD44<br>(5 VDC 200 mA) | CS1W-DA08C<br>(5 VDC 130 mA) | CS1W-AD161<br>(5 VDC 150 mA) |
|-----------------------------------------------------------------------------------------------------|----------------|--------------------------------------------------|--------------------------------------------|------------------------------|------------------------------|------------------------------|
| C200HW-PA204<br>C200HW-PA204S<br>C200HW-PA204R<br>C200HW-PA204C<br>C200HW-PD024<br>(4.6 A at 5 VDC) | CPU Rack       | 6                                                | 3                                          | 3                            | 2                            | 8                            |
|                                                                                                     | Expansion Rack | 6                                                | 3                                          | 3                            | 2                            | 9                            |
| C200HW-PA209R<br>(9 A at 5 VDC)                                                                     | CPU Rack       | 10                                               | 7                                          | 6                            | 5                            | 10                           |
|                                                                                                     | Expansion Rack | 10                                               | 7                                          | 6                            | 5                            | 10                           |
| CS1D-PA207R<br>(7 A at 5 VDC)                                                                       | CPU Rack       | 8                                                | 5                                          | 4                            | 4                            | 8                            |
|                                                                                                     | Expansion Rack | 9                                                | 6                                          | 5                            | 4                            | 9                            |
| CS1D-PD024<br>(4.3 A at 5 VDC)                                                                      | CPU Rack       | 6                                                | 3                                          | 2                            | 2                            | 7                            |
|                                                                                                     | Expansion Rack | 6                                                | 3                                          | 2                            | 2                            | 8                            |

The above limits may be reduced depending on the power consumed by other Units on the same Rack.


## 4. Data Exchange with the CPU Unit

| Area                                                                                 | Number of words                                                                                                                    | Data transfer timing                         | Transfer direction            | Data contents                                                                                                                                                                                  |
|--------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------|-------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959, CIO 2000.00 to CIO 2959.15) | <ul style="list-style-type: none"> <li>CS1W-AD041-V1/081-V1: 10 words per Unit</li> <li>CS1W-AD161: 20 words per Unit</li> </ul>   | Constantly                                   | CPU Unit to Analog Input Unit | Peak value hold                                                                                                                                                                                |
|                                                                                      |                                                                                                                                    |                                              | Analog Input Unit to CPU Unit | Analog input values<br>Line disconnection detection<br>Alarm flags<br>Etc.                                                                                                                     |
| Special I/O Unit Area in DM Area (D20000 to D26959)                                  | <ul style="list-style-type: none"> <li>CS1W-AD041-V1/081-V1: 100 words per Unit</li> <li>CS1W-AD161: 200 words per Unit</li> </ul> | When power is turned ON or Unit is restarted | CPU Unit to Analog Input Unit | Input signal conversion ON/OFF<br>Signal range specifications<br>Averaging specifications<br>Resolution/conversion time setting<br>Operation mode setting<br>Scaling setting (CS1W-AD161 only) |

**Note** The resolution/conversion time setting and operation mode setting are supported only by version-1 Analog Input Units.

- Input signal ranges can be set for each input.
- Voltage input or current input is selected for the CS1W-AD041-V1 and CS1W-AD081-V1 by using the voltage/current switch at the back of the terminal block. Voltage input or current input is selected for the CS1W-AD161 by wiring the connector terminals. Voltage/current selection for input ranges 1 to 5 V or 4 to 20 mA can be set in DM word m+52.
- Use the analog input voltage/current value within the specified input signal range. Exceeding the specified range may result in malfunction.
- With Analog Input Units, the resolution can be changed from 4,000 to 8,000 and the conversion time changed from 1 ms to 250  $\mu$ s in DM word m+18 for CS1W-AD041-V1 and CS1W-AD081-V1 or in DM word m+19 for CS1W-AD161.
- The following are adjusted at the factory.  
CS1W-AD041-V1/081-V1: Voltage inputs  
CS1W-AD161: Voltage inputs and current inputs  
Calibration conditions: Recommended Terminal Block-Connector Conversion Unit used. (The factory calibration for a current input can be made effective by setting DM word m+52.)  
  
To use current inputs with the CS1W-AD041-V1/081-V1 or to use the CS1W-AD161 with products other than the recommended ones, adjust the offset and gain as required.
- A/D conversion time is the time it takes for an analog signal to be stored in memory as converted data after it has been input. It takes at least one cycle before the converted data is read by the CPU Unit.
- Input disconnection detection is valid only when the 1 to 5-V or 4 to 20-mA range is set. If there is no input signal for when the 1 to 5-V or 4 to 20-mA range is set, the Disconnection Detection Flag will turn ON.

## 2-1-2 Input Function Block Diagram






**Note** There are only four analog inputs for the CS1W-AD041-V1, and 16 analog inputs for the CS1W-AD161.

## 2-1-3 Input Specifications


If signals that are outside the specified range provided below are input, the conversion values (16-bit binary data) used will be either the maximum or minimum value.

**Range: 1 to 5 V (4 to 20 mA)**



**Range: 0 to 10 V****Range: 0 to 5 V**

Range: -10 to 10 V



**Note** The conversion values for a range of -10 to 10 V will be as follows (for a resolution of 4,000):

| 16-bit binary data | BCD   |
|--------------------|-------|
| F768               | -2200 |
| :                  | :     |
| FFFF               | -1    |
| 0000               | 0     |
| 0001               | 1     |
| :                  | :     |
| 0898               | 2200  |

## 2-2 Operating Procedure

Follow the procedure outlined below when using Analog Input Units.

### Installation and Settings

- 1,2,3...**
1. Set the operation mode to normal mode. (See note 1.)
  2. Select voltage/current input using the switch at the back of the terminal block. (See note 2.)
  3. Wire the Unit.
  4. Use the unit number switches on the front panel of the Unit to set the unit number. (See note 3.)
  5. Turn ON the power to the PLC.
  6. Create the Input tables.
  7. Make the Special Input Unit DM Area settings.
    - Set the input numbers to be used.
    - Set the input signal ranges.
    - Set the number of mean processing samplings.
    - Conversion time and resolution
  8. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to ON.

When the input for the connected devices needs to be calibrated, follow the procedures in *Offset Gain Adjustment* below. Otherwise, skip to *Operation* below.

### Offset and Gain Adjustment

- 1,2,3...**
1. Set the operation mode to adjustment mode. (See note 1.)
  2. Select voltage or current input. (See note 2.)
  3. Turn ON the power to the PLC.
  4. Adjust the offset and gain.
  5. Turn OFF the power to the PLC.
  6. Set the operation mode to normal mode. (See note 1.)

### Operation

- 1,2,3...**
1. Turn ON the power to the PLC.
  2. Ladder program
    - Read conversion values or write set values by means of MOV(021) and XFER(070).
    - Specify the peak hold function.
    - Obtain disconnection notifications and error codes.

#### Note

1. Setting the Operation Mode  
The operation mode can be changed either by setting the DIP switch on the rear panel of the Unit or changing the DM Area settings. When normal mode is set both in the DIP switch and in the DM Area settings, the Unit operates in normal mode. If adjustment mode is set in either or both of the settings, the Unit operates in adjustment mode. The operation mode selection setting is allocated in DM word m+18 for CS1W-AD041-V1 and CS1W-AD081-V1 and in DM word m+19 for CS1W-AD161.
2. Selecting Voltage/Current Input  
With the CS1W-AD041-V1 and CS1W-AD081-V1, remove the terminal block and set the DIP switch located at the back. With the CS1W-AD161,

select either voltage input or current input by wiring the connector terminals. Use DM word  $m+52$  to select 1 to 5 V or 4 to 20 mA as the voltage or current input range, respectively.


### 3. Setting the Unit Number

Set the unit number for the Special I/O Unit using the rotary switches on the front panel of the Unit.

Set the CS1W-AD041-V1 and CS1W-AD081-V1 between 0 and 95. A single CS1W-AD161 is allocated words in the CIO Area and DM Area for two Units. Set the unit number between 0 and 94. To set a CS1W-AD161 to unit number “n,” the unit number setting “n+1” is not possible.

## 2-2-1 Procedure Examples


The procedure for using Analog Input Units is provided here using the CS1W-AD081-V1 as an example. The method used to set CS1W-AD161 Analog Input Units is different. Be sure to use the correct procedure.



### Setting the Analog Input Unit


1,2,3...

1. Set the operation mode. Refer to 2-3-3 *Operation Mode Switch* for further details.




The operation mode can be changed by setting DM word  $m+18$  (DM word  $m+19$  for CS1W-AD161).

2. Set the voltage/current switch. Refer to *2-3-4 Voltage/Current Switch (CS1W-AD041-V1/AD081-V1)* for further details.




**Note** With CS1W-AD161, select voltage/current input by wiring the connector terminals.

3. Mount and wire the Analog Input Unit. Refer to *1-2-1 Mounting Procedure*, *2-4 Wiring* or *2-4-4 Input Wiring Example* for further details.



4. Set the unit number switches. Refer to *2-3-2 Unit Number Switches* for further details.






If the unit number is set to 1, words will be allocated to the Special I/O Unit Area CIO 2010 to CIO 2019 and to the Special I/O Unit Area D20100 to D20199.


**Note** A single CS1W-AD161 is allocated CIO Area words and DM Area words for two Units. For example, if the unit number is set to 1, the CS1W-AD161 will be allocated CIO Area words CIO 2010 to CIO 2029 and DM Area words D20100 to D20299.

5. Turn ON the power to the PLC.




### Creating I/O Tables

After turning ON the power to the PLC, be sure to create the I/O tables.



## Initial Data Settings

- 1,2,3...** 1. Specify the Special I/O Unit DM Area settings. Refer to 2-5-4 *Fixed Data Allocations* for further details.




Setting conditions


Unit No. 1

Analog input 1: 1 to 5 V  
 Analog input 2: 1 to 5 V  
 Analog input 3: 4 to 20 mA  
 Analog input 4: 4 to 20 mA  
 Analog input 5: 0 to 10 V  
 Analog input 6: 0 to 10 V  
 Analog input 7: -10 to 10 V  
 Analog input 8: Not used.

- The following diagram shows the input settings used. Refer to *Allocations in DM Area* on page 45 and 2-6-1 *Input Settings and Conversion Values* for more details.




- The following diagram shows the input range settings. Refer to *DM Allocation Contents* on page 45 and 2-6-1 *Input Settings and Conversion Values* for more details.




Also set DM word m+52 when using current input with the CS1W-AD161.

- The following diagram shows the conversion time/resolution setting.  
(Refer to 2-6-2 Conversion Time/Resolution Setting.)




**Note** For CS1W-AD161, set D(m+19):D20119.

- Restart the CPU Unit.



## Creating Ladder Programs




The data that is converted from analog to digital and output to CIO words (n + 1) to (n + 7) of the Special I/O Unit Area (CIO 2011 to CIO2017), is stored in the specified addresses D00100 to D00106 as signed binary values 0000 to 0FA0 hex.

- The following table shows the addresses used for analog input.

| Input number | Input signal range | Input conversion value address<br>(n = CIO 2010)<br>(See note 1.) | Conversion data holding address<br>(See note 2.) |
|--------------|--------------------|-------------------------------------------------------------------|--------------------------------------------------|
| 1            | 1 to 5 V           | (n+1) = CIO 2011                                                  | D00100                                           |
| 2            | 1 to 5 V           | (n+2) = CIO 2012                                                  | D00101                                           |
| 3            | 4 to 20 mA         | (n+3) = CIO 2013                                                  | D00102                                           |
| 4            | 4 to 20 mA         | (n+4) = CIO 2014                                                  | D00103                                           |
| 5            | 0 to 10 V          | (n+5) = CIO2015                                                   | D00104                                           |
| 6            | 0 to 10 V          | (n+6) = CIO2016                                                   | D00105                                           |
| 7            | -10 to 10 V        | (n+7) = CIO2017                                                   | D00106                                           |
| 8            | Not used           | ---                                                               | ---                                              |

- Note**
- The addresses are fixed according to the unit number of the Special I/O Unit. Refer to *2-3-2 Unit Number Switches* for further details.
  - Set as required.




- Bits 00 to 07 of word (n + 9) are allocated to the input Disconnection Detection Flags. Refer to *Allocations for Normal Mode* on page 51 for further details.

## 2-3 Components and Switch Settings

CS1W-AD041-V1

Front

With Terminal Block




Unit number switches

External terminal block mounting screws (black M3)

External terminal block (M3)

With Terminal Block Removed




Voltage/Current switch

CS1W-AD081-V1

Front

With Terminal Block




Unit number switches

External terminal block mounting screws (black M3)


External terminal block (M3)

With Terminal Block Removed



Voltage/Current switch


Back



Operation mode switch

Backplane connector


Side




Terminal block

The terminal block is attached by a connector. It can be removed by loosening the two black mounting screws located at the top and bottom of the terminal block.

Check to be sure that the black terminal block mounting screw is securely tightened to a torque of 0.5 N·m.



### CS1W-AD161



## 2-3-1 Indicators

The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.


| Indicator   | Meaning                | Indicator status | Operating status                                                                        |
|-------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green) | Operating              | Lit              | Operating in normal mode.                                                               |
|             |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)   | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|             |                        | Not lit          | Operating normally.                                                                     |

| Indicator    | Meaning               | Indicator status | Operating status                                           |
|--------------|-----------------------|------------------|------------------------------------------------------------|
| ADJ (yellow) | Adjusting             | Flashing         | Operating in offset/gain adjustment mode.                  |
|              |                       | Not lit          | Other than the above.                                      |
| ERH (red)    | Error in the CPU Unit | Lit              | Error has occurred during data exchange with the CPU Unit. |
|              |                       | Not lit          | Operating normally.                                        |

## 2-3-2 Unit Number Switches

The CPU Unit and Analog Input Unit exchange data via the Special I/O Unit Area in the CIO Area and DM Area. The words that are allocated to each Analog Input Unit in the Special I/O Unit Area in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings.




| Switch setting | CS1W-AD041-V1/AD081-V1 |                                                    |                                                   | CS1W-AD161 (See note 2.) |                                                    |                                                   |
|----------------|------------------------|----------------------------------------------------|---------------------------------------------------|--------------------------|----------------------------------------------------|---------------------------------------------------|
|                | Unit number            | Words allocated in Special/O Unit Area in CIO Area | Words allocated in Special/O Unit Area in DM Area | Unit number              | Words allocated in Special/O Unit Area in CIO Area | Words allocated in Special/O Unit Area in DM Area |
| 0              | Unit #0                | CIO 2000 to CIO 2009                               | D20000 to D20099                                  | Unit #0                  | CIO 2000 to CIO 2019                               | D20000 to D20199                                  |
| 1              | Unit #1                | CIO 2010 to CIO 2019                               | D20100 to D20199                                  | Unit #1                  | CIO 2010 to CIO 2029                               | D20100 to D20299                                  |
| 2              | Unit #2                | CIO 2020 to CIO 2029                               | D20200 to D20299                                  | Unit #2                  | CIO 2020 to CIO 2039                               | D20200 to D20399                                  |
| 3              | Unit #3                | CIO 2030 to CIO 2039                               | D20300 to D20399                                  | Unit #3                  | CIO 2030 to CIO 2049                               | D20300 to D20499                                  |
| 4              | Unit #4                | CIO 2040 to CIO 2049                               | D20400 to D20499                                  | Unit #4                  | CIO 2040 to CIO 2059                               | D20400 to D20599                                  |
| 5              | Unit #5                | CIO 2050 to CIO 2059                               | D20500 to D20599                                  | Unit #5                  | CIO 2050 to CIO 2069                               | D20500 to D20699                                  |
| 6              | Unit #6                | CIO 2060 to CIO 2069                               | D20600 to D20699                                  | Unit #6                  | CIO 2060 to CIO 2079                               | D20600 to D20799                                  |
| 7              | Unit #7                | CIO 2070 to CIO 2079                               | D20700 to D20799                                  | Unit #7                  | CIO 2070 to CIO 2089                               | D20700 to D20899                                  |
| 8              | Unit #8                | CIO 2080 to CIO 2089                               | D20800 to D20899                                  | Unit #8                  | CIO 2080 to CIO 2099                               | D20800 to D20999                                  |
| 9              | Unit #9                | CIO 2090 to CIO 2099                               | D20900 to D20999                                  | Unit #9                  | CIO 2090 to CIO 2109                               | D20900 to D21099                                  |
| 10             | Unit #10               | CIO 2100 to CIO 2109                               | D21000 to D21099                                  | Unit #10                 | CIO 2100 to CIO 2119                               | D21000 to D21199                                  |
| to             | to                     | to                                                 | to                                                | to                       | to                                                 | to                                                |
| n              | Unit #n                | CIO 2000 + (n x 10) to CIO 2000 + (n x 10) + 9     | D20000 + (n x 100) to D20000 + (n x 100) + 99     | Unit #n                  | CIO 2000 + (n x 10) to CIO 2000 + (n x 10) + 19    | D20000 + (n x 100) to D20000 + (n x 100) + 199    |
| to             | to                     | to                                                 | to                                                | to                       | to                                                 | to                                                |

| Switch setting | CS1W-AD041-V1/AD081-V1 |                                                    |                                                   | CS1W-AD161 (See note 2.) |                                                    |                                                   |
|----------------|------------------------|----------------------------------------------------|---------------------------------------------------|--------------------------|----------------------------------------------------|---------------------------------------------------|
|                | Unit number            | Words allocated in Special/O Unit Area in CIO Area | Words allocated in Special/O Unit Area in DM Area | Unit number              | Words allocated in Special/O Unit Area in CIO Area | Words allocated in Special/O Unit Area in DM Area |
| 94             | Unit #94               | CIO 2940 to CIO 2949                               | D29400 to D29499                                  | Unit #94                 | CIO 2940 to CIO 2959                               | D29400 to D29499                                  |
| 95             | Unit #95               | CIO 2950 to CIO 2959                               | D29500 to D29599                                  | Not used.                | ---                                                | ---                                               |

- Note**
1. If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.
  2. A single CS1W-AD161 is allocated CIO Area words and DM Area words for two Units. Be sure to set a unit number so that the CS1W-AD161 is not allocated words in the CIO Area and DM Area that are already allocated to other Special I/O Units. For example, if the CS1W-AD161 is set to unit number n, another Special I/O Unit cannot be set with unit number n+1. The highest unit number that can be set for a CS1W-AD161 is unit number 94.

### 2-3-3 Operation Mode Switch

The operation mode switch on the back panel of the Unit is used to set the operation mode to either normal mode or adjustment mode (for adjusting off-set and gain).



| Pin number |     | Mode            |
|------------|-----|-----------------|
| 1          | 2   |                 |
| OFF        | OFF | Normal mode     |
| ON         | OFF | Adjustment mode |

- Note**
1. The operation mode can be set in the DM Area as an alternative to using the operation mode switch.
  2. Set the operation mode in DM word m+18 for CS1W-AD041-V1 and CS1W-AD081-V1, and in DM word m+19 for CS1W-AD161.

CS1W-AD041-V1/AD081-V1

| Bit      | 15                                 | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                                               | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|----------|------------------------------------|----|----|----|----|----|----|----|------------------------------------------------------------------|----|----|----|----|----|----|----|
| D (m+18) | Conversion time/resolution setting |    |    |    |    |    |    |    | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |    |    |    |    |    |    |    |

$$m = D20000 + (\text{unit number} \times 100)$$

CS1W-AD161

| Bit      | 15                                 | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                                               | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|----------|------------------------------------|----|----|----|----|----|----|----|------------------------------------------------------------------|----|----|----|----|----|----|----|
| D (m+19) | Conversion time/resolution setting |    |    |    |    |    |    |    | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |    |    |    |    |    |    |    |

$$m = D20000 + (\text{unit number} \times 100)$$




### Relationship between Operation Mode Switch Setting and DM Area Setting

| Operation mode switch | DM Area setting | Analog Input Unit operation mode |
|-----------------------|-----------------|----------------------------------|
| Normal mode (default) | Normal mode     | Normal mode                      |
|                       | Adjustment mode | Adjustment mode                  |
| Adjustment mode       | Normal mode     |                                  |
|                       | Adjustment mode |                                  |

The Unit will operate in normal mode when both the operation mode switch and DM Area setting are set to normal mode. If either or both of the settings are set to adjustment mode, the Unit will operate in adjustment mode. The operation mode will change whenever the power is restarted or any of the Special I/O Unit Restart Bits (A502 to A507) turn ON.

### 2-3-4 Voltage/Current Switch (CS1W-AD041-V1/AD081-V1)

The analog conversion input can be switched from voltage input to current input by changing the pin settings on the voltage/current switch located on the back of the terminal block.



- Note**
1. There are only four inputs for the CS1W-AD041-V1.
  2. With CS1W-AD161, select voltage/current input by wiring the connector terminals.

**Caution** Be sure to turn OFF the power to the PLC before mounting or removing the terminal block or connector.

## 2-4 Wiring

### 2-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

#### CS1W-AD041-V1

|             |     |     |             |
|-------------|-----|-----|-------------|
| Input 2 (+) | B1  | A1  | Input 1 (+) |
| Input 2 (-) | B2  | A2  | Input 1 (-) |
| AG          | B3  | A3  | AG          |
| Input 4 (+) | B4  | A4  | Input 3 (+) |
| Input 4 (-) | B5  | A5  | Input 3 (-) |
| N.C.        | B6  | A6  | N.C.        |
| N.C.        | B7  | A7  | N.C.        |
| N.C.        | B8  | A8  | N.C.        |
| N.C.        | B9  | A9  | N.C.        |
| N.C.        | B10 | A10 | N.C.        |
|             |     | A11 | N.C.        |

#### CS1W-AD081-V1

|             |     |     |             |
|-------------|-----|-----|-------------|
| Input 2 (+) | B1  | A1  | Input 1 (+) |
| Input 2 (-) | B2  | A2  | Input 1 (-) |
| AG          | B3  | A3  | AG          |
| Input 4 (+) | B4  | A4  | Input 3 (+) |
| Input 4 (-) | B5  | A5  | Input 3 (-) |
| Input 6 (+) | B6  | A6  | Input 5 (+) |
| Input 6 (-) | B7  | A7  | Input 5 (-) |
| AG          | B8  | A8  | AG          |
| Input 8 (+) | B9  | A9  | Input 7 (+) |
| Input 8 (-) | B10 | A10 | Input 7 (-) |
|             |     | A11 | N.C.        |

## CS1W-AD161

| CN2 Inputs 9 to 16 |    |    |                 | CN1 Inputs 1 to 8 |    |    |                |
|--------------------|----|----|-----------------|-------------------|----|----|----------------|
| Input 9+           | 1  | 2  | Input 10+       | Input 1+          | 1  | 2  | Input 2+       |
| Current mode 9     | 3  | 4  | Current mode 10 | Current mode 1    | 3  | 4  | Current mode 2 |
| Input 9-           | 5  | 6  | Input 10-       | Input 1-          | 5  | 6  | Input 2-       |
| AG                 | 7  | 8  | AG              | AG                | 7  | 8  | AG             |
| Input 11+          | 9  | 10 | Input 12+       | Input 3+          | 9  | 10 | Input 4+       |
| Current mode 11    | 11 | 12 | Current mode 12 | Current mode 3    | 11 | 12 | Current mode 4 |
| Input 11-          | 13 | 14 | Input 12-       | Input 3-          | 13 | 14 | Input 4-       |
| AG                 | 15 | 16 | AG              | AG                | 15 | 16 | AG             |
| Input 13+          | 17 | 18 | Input 14+       | Input 5+          | 17 | 18 | Input 6+       |
| Current mode 13    | 19 | 20 | Current mode 14 | Current mode 5    | 19 | 20 | Current mode 6 |
| Input 13-          | 21 | 22 | Input 14-       | Input 5-          | 21 | 22 | Input 6-       |
| AG                 | 23 | 24 | AG              | AG                | 23 | 24 | AG             |
| Input 15+          | 25 | 26 | Input 16+       | Input 7+          | 25 | 26 | Input 8+       |
| Current mode 15    | 27 | 28 | Current mode 16 | Current mode 7    | 27 | 28 | Current mode 8 |
| Input 15-          | 29 | 30 | Input 16-       | Input 7-          | 29 | 30 | Input 8-       |
| AG                 | 31 | 32 | AG              | AG                | 31 | 32 | AG             |
| NC                 | 33 | 34 | NC              | NC                | 33 | 34 | NC             |

- Note**
1. The number of analog inputs that can be used is set in the DM Area.
  2. The input signal ranges for individual inputs are set in the DM Area. The input signal range can be set separately for each input.
  3. The AG terminals (A8, B8) are connected to the 0-V analog circuit in the Unit. Connecting shielded input lines can improve noise resistance.


**Caution** Do not make any connections to the N.C. terminals.

## 2-4-2 Internal Circuitry


The following diagrams show the internal circuitry of the analog input section.

### Input Circuitry


#### CS1W-AD041-V1/AD081-V1




#### CS1W-AD161



## Internal Configuration



## 2-4-3 Voltage Input Disconnection



**Note** If the connected device #2 in the above example outputs 5 V and the power supply is shared by 2 channels as shown in the above diagram, approximately one third of the voltage, or 1.6 V, will be input at input 1.


When voltage inputs are used and a disconnection occurs, separate the power supply at the side of the connected devices or use an insulating device (isolator) for each input to avoid the following problems.

When the power supply at the connected devices is shared and section A or B is disconnected, power will flow in the direction of the broken line and the output voltage of the other connected devices will be reduced to between a third to a half of the voltage. If 1 to 5 V is used and the reduced voltage output, disconnection may not be detectable. If section C is disconnected, the power at the (–) input terminal will be shared and disconnection will not be detectable.

For current inputs, sharing the power supply between the connected devices will not cause any problems.


## 2-4-4 Input Wiring Example

CS1W-AD041-V1/AD081-V1



- Note**
1. When using current inputs, pins IN1 to IN8 (pins IN1 to IN4 for the CS1W-AD041-V1) of the voltage/current switch must be set to ON. Refer to 2-3-4 *Voltage/Current Switch (CS1W-AD041-V1/AD081-V1)* for further details.
  2. For inputs that are not used, either set to "0: Not used" in the input number settings (refer to 2-6-1 *Input Settings and Conversion Values*) or short-circuit the voltage input terminals (V+) and (V–). If this is not performed and the inputs are set for the 1 to 5-V or 4 to 20-mA range, the Line Disconnection Flag will turn ON.
  3. Crimp-type terminals must be used for terminal connections, and the screws must be tightened securely. Use M3 screws and tighten them to a torque of 0.5 N·m.
  4. When connecting the shield of the analog input cables to the Unit's AG terminals, as shown in the above diagram, use a wire that is 30 cm max. in length if possible.


**Caution** Do not connect anything to N.C. terminals shown in the wiring diagram on page 36.




Connect the analog input line shield to the AG terminal on the Analog Input Unit to improve noise resistance.

### CS1W-AD161

Use OMRON's XW2D-34G6 Connector-Terminal Conversion Unit and Special Connection Cable for input wiring.



### Terminal Block Pin Arrangement



XW2D-34G6  
Terminal Block  
Conversion Unit


|             |    |    |    |    |     |     |
|-------------|----|----|----|----|-----|-----|
| Upper level | A1 | A2 | A3 | to | A16 | A17 |
| Lower level | B1 | B2 | B3 | to | B16 | B17 |

**CN1 to Terminal Block Conversion**


|          |                |          |    |          |                |          |    |          |                |          |     |          |                |          |     |     |
|----------|----------------|----------|----|----------|----------------|----------|----|----------|----------------|----------|-----|----------|----------------|----------|-----|-----|
| Input 1+ | Current mode 1 | Input 1– | AG | Input 3+ | Current mode 3 | Input 3– | AG | Input 5+ | Current mode 5 | Input 5– | AG  | Input 7+ | Current mode 7 | Input 7– | AG  | NC  |
| A1       | A2             | A3       | A4 | A5       | A6             | A7       | A8 | A9       | A10            | A11      | A12 | A13      | A14            | A15      | A16 | A17 |
| Input 2+ | Current mode 2 | Input 2– | AG | Input 4+ | Current mode 4 | Input 4– | AG | Input 6+ | Current mode 6 | Input 6– | AG  | Input 8+ | Current mode 8 | Input 8– | AG  | NC  |
| B1       | B2             | B3       | B4 | B5       | B6             | B7       | B8 | B9       | B10            | B11      | B12 | B13      | B14            | B15      | B16 | B17 |

**CN2 to Terminal Block Conversion**

|           |                 |           |    |           |                 |           |    |           |                 |           |     |           |                 |           |     |     |
|-----------|-----------------|-----------|----|-----------|-----------------|-----------|----|-----------|-----------------|-----------|-----|-----------|-----------------|-----------|-----|-----|
| Input 9+  | Current mode 9  | Input 9–  | AG | Input 11+ | Current mode 11 | Input 11– | AG | Input 13+ | Current mode 13 | Input 13– | AG  | Input 15+ | Current mode 15 | Input 15– | AG  | NC  |
| A1        | A2              | A3        | A4 | A5        | A6              | A7        | A8 | A9        | A10             | A11       | A12 | A13       | A14             | A15       | A16 | A17 |
| Input 10+ | Current mode 10 | Input 10– | AG | Input 12+ | Current mode 12 | Input 12– | AG | Input 14+ | Current mode 14 | Input 14– | AG  | Input 16+ | Current mode 16 | Input 16– | AG  | NC  |
| B1        | B2              | B3        | B4 | B5        | B6              | B7        | B8 | B9        | B10             | B11       | B12 | B13       | B14             | B15       | B16 | B17 |


**Voltage Input Wiring****Current Input Wiring**

Short-circuit the input(+) and current mode terminals when using current input.



With the CS1W-AD161, select voltage input or current input by wiring the connector terminals. Voltage and current selection for input ranges 1 to 5 V and 4 to 20 mA, respectively, can also be set in DM word m+52.

Use crimp terminals to wire the terminal block.



XW2D-34G6  
Terminal Block  
Conversion Unit

**Note** The following Connectors are included with the CS1W-AD161. Use them if you are going to make your own cable (e.g., if you are not going to use an OMRON Connector-Terminal Block Conversion Unit).

| Name                          | Connection method | Manufacturer | Model number | Qty. included |
|-------------------------------|-------------------|--------------|--------------|---------------|
| Applicable Connector (34-pin) | Pressure welded   | OMRON        | XG4M-3430-T  | 2             |

## 2-4-5 Input Wiring Considerations

When wiring inputs, apply the following points to avoid noise interference and optimize Analog Input Unit performance.

- Use two-core shielded twisted-pair cables for input connections.
- Route input cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable, high voltage cable, or a non-PLC load cable.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.

## 2-5 Exchanging Data with the CPU Unit

### 2-5-1 Outline of Data Exchange

Data is exchanged between the CPU Unit and the CS1W-AD041-V1/081-V1/AD161 Analog Input Unit via the Special I/O Unit Area in the CIO Area (for data used to operate the Unit) and the Special I/O Unit in the DM Area (for data used for initial settings).

#### I/O Refresh Data


Analog input conversion values, which are used as data for Unit operation, are allocated in the Special I/O Unit Area in the CIO Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.

#### Fixed Data

The Unit's fixed data, such as the analog input signal ranges and the number of operational mean value buffers is allocated in the Special I/O Unit DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.




The conversion time and resolution can be set, along with the operation mode.



- Note**
1. A single CS1W-AD161 is allocated CIO Area words and DM Area words for two Units, i.e., 20 words in the CIO Area (CIO 2000 + n x 10 to CIO 2000 + n x 10 + 19) and 200 words in the DM Area (D20000 + n x 100 to D20000 + n x 100 + 199).
  2. Transferring scaling data is supported by CS1W-AD161 only.

## 2-5-2 Unit Number Settings

The Special I/O Unit Area and Special I/O Unit DM Area word addresses that each Analog Input Unit occupies are set by the unit number switches on the front panel of the Unit.



| Switch setting | CS1W-AD041-V1/AD081-V1 |                                                      |                                                     | CS1W-AD161 (See note 2.) |                                                      |                                                     |
|----------------|------------------------|------------------------------------------------------|-----------------------------------------------------|--------------------------|------------------------------------------------------|-----------------------------------------------------|
|                | Unit number            | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area | Unit number              | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
| 0              | Unit #0                | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    | Unit #0                  | CIO 2000 to CIO 2019                                 | D20000 to D20199                                    |
| 1              | Unit #1                | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    | Unit #1                  | CIO 2010 to CIO 2029                                 | D20100 to D20299                                    |
| 2              | Unit #2                | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    | Unit #2                  | CIO 2020 to CIO 2039                                 | D20200 to D20399                                    |
| 3              | Unit #3                | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    | Unit #3                  | CIO 2030 to CIO 2049                                 | D20300 to D20499                                    |
| 4              | Unit #4                | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    | Unit #4                  | CIO 2040 to CIO 2059                                 | D20400 to D20599                                    |

| Switch setting | CS1W-AD041-V1/AD081-V1 |                                                      |                                                     | CS1W-AD161 (See note 2.) |                                                      |                                                     |
|----------------|------------------------|------------------------------------------------------|-----------------------------------------------------|--------------------------|------------------------------------------------------|-----------------------------------------------------|
|                | Unit number            | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area | Unit number              | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
| 5              | Unit #5                | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    | Unit #5                  | CIO 2050 to CIO 2069                                 | D20500 to D20699                                    |
| 6              | Unit #6                | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    | Unit #6                  | CIO 2060 to CIO 2079                                 | D20600 to D20799                                    |
| 7              | Unit #7                | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    | Unit #7                  | CIO 2070 to CIO 2089                                 | D20700 to D20899                                    |
| 8              | Unit #8                | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    | Unit #8                  | CIO 2080 to CIO 2099                                 | D20800 to D20999                                    |
| 9              | Unit #9                | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    | Unit #9                  | CIO 2090 to CIO 2109                                 | D20900 to D21099                                    |
| 10             | Unit #10               | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    | Unit #10                 | CIO 2100 to CIO 2119                                 | D21000 to D21199                                    |
| to             | to                     | to                                                   | to                                                  | to                       | to                                                   | to                                                  |
| n              | Unit #n                | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       | Unit #n                  | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 19      | D20000 + (n × 100) to D20000 + (n × 100) + 199      |
| to             | to                     | to                                                   | to                                                  | to                       | to                                                   | to                                                  |
| 94             | Unit #94               | CIO 2940 to CIO 2949                                 | D29400 to D29499                                    | Unit #94                 | CIO 2940 to CIO 2959                                 | D29400 to D29499                                    |
| 95             | Unit #95               | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    | Not used.                | ---                                                  | ---                                                 |

- Note**
1. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.
  2. Be sure to set a unit number such that the CS1W-AD161 is not allocated words in the CIO Area and DM Area that are already allocated to other Special I/O Units. The unit number can be set between 0 and 94.

### 2-5-3 Special I/O Unit Restart Bits

To restart the Unit after changing the contents of the DM Area or correcting an error, cycle the power supply to the PLC or turn ON the Special I/O Unit Restart Bit.

| Special I/O Unit Area word address | Function                |                                                      |
|------------------------------------|-------------------------|------------------------------------------------------|
| A50200                             | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON and then OFF again. |
| A50201                             | Unit No. 1 Restart Bit  |                                                      |
| to                                 | to                      |                                                      |
| A50215                             | Unit No. 15 Restart Bit |                                                      |
| A50300                             | Unit No. 16 Restart Bit |                                                      |
| to                                 | to                      |                                                      |
| A50715                             | Unit No. 95 Restart Bit |                                                      |

A single CS1W-AD161 is allocated words for two unit numbers, but uses only the Special I/O Unit Restart Bit setting corresponding to the unit number that is set.


- Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.


## 2-5-4 Fixed Data Allocations

### Allocations in DM Area

The initial settings of the Analog Input Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the inputs used and the analog input signal range must be set in this area.

#### **CS1W-AD041-V1/AD081-V1**



**CS1W-AD161**

- Note**
1. The words in the Special I/O Unit DM Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. Refer to *2-5-2 Unit Number Settings* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

**Allocations in DM Area**

The following table shows the allocation of DM Area words and bits for both normal and adjustment mode.

**CS1W-AD041-V1**

| DM Area word (See note.) | Bits                                                                                                                                               |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
|--------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|----|----|----|----|---|---|------------------------------------------------------------------|---|---------|---|-------------------|---------|---------|---------|
|                          | 15                                                                                                                                                 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                                                | 6 | 5       | 4 | 3                 | 2       | 1       | 0       |
| D (m)                    | Not used. (Settings are ignored.)                                                                                                                  |    |    |    |    |    |   |   | Not used.                                                        |   |         |   | Input use setting |         |         |         |
|                          |                                                                                                                                                    |    |    |    |    |    |   |   |                                                                  |   |         |   | Input 4           | Input 3 | Input 2 | Input 1 |
| D (m+1)                  | Not used. (Settings are ignored.)                                                                                                                  |    |    |    |    |    |   |   | Input range setting                                              |   |         |   |                   |         |         |         |
|                          |                                                                                                                                                    |    |    |    |    |    |   |   | Input 4                                                          |   | Input 3 |   | Input 2           |         | Input 1 |         |
| D (m+2)                  | Input 1: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+3)                  | Input 2: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+4)                  | Input 3: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+5)                  | Input 4: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+18)                 | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 μs and resolution of 8,000 |    |    |    |    |    |   |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |   |         |   |                   |         |         |         |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**CS1W-AD081-V1**

| DM Area<br>word (See<br>note.) | Bits                                                                                                         |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
|--------------------------------|--------------------------------------------------------------------------------------------------------------|----|---------|----|---------|----|---------|---|----------------------------------------|------------|------------|------------|------------|------------|------------|------------|
|                                | 15                                                                                                           | 14 | 13      | 12 | 11      | 10 | 9       | 8 | 7                                      | 6          | 5          | 4          | 3          | 2          | 1          | 0          |
| D (m)                          | Not used. (Settings are ignored.)                                                                            |    |         |    |         |    |         |   | Input use setting                      |            |            |            |            |            |            |            |
|                                |                                                                                                              |    |         |    |         |    |         |   | Input<br>8                             | Input<br>7 | Input<br>6 | Input<br>5 | Input<br>4 | Input<br>3 | Input<br>2 | Input<br>1 |
| D (m+1)                        | Input range setting                                                                                          |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
|                                | Input 8                                                                                                      |    | Input 7 |    | Input 6 |    | Input 5 |   | Input 4                                |            | Input 3    |            | Input 2    |            | Input 1    |            |
| D (m+2)                        | Input 1: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+3)                        | Input 2: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+4)                        | Input 3: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+5)                        | Input 4: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+6)                        | Input 5: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+7)                        | Input 6: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+8)                        | Input 7: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+9)                        | Input 8: Mean value processing setting                                                                       |    |         |    |         |    |         |   |                                        |            |            |            |            |            |            |            |
| D (m+18)                       | Conversion time/resolution setting                                                                           |    |         |    |         |    |         |   | Operation mode setting                 |            |            |            |            |            |            |            |
|                                | 00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 μs and resolution of 8,000 |    |         |    |         |    |         |   | 00: Normal mode<br>C1: Adjustment mode |            |            |            |            |            |            |            |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**CS1W-AD161**

| DM Area word (See note 1.) | Bits                                   |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
|----------------------------|----------------------------------------|----------|----------|----------|----------|----------|----------|---------|------------------------|---------|----------|---------|----------|---------|---------|---------|
|                            | 15                                     | 14       | 13       | 12       | 11       | 10       | 9        | 8       | 7                      | 6       | 5        | 4       | 3        | 2       | 1       | 0       |
| D (m)                      | Input use setting                      |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
|                            | Input 16                               | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8                | Input 7 | Input 6  | Input 5 | Input 4  | Input 3 | Input 2 | Input 1 |
| D (m+1)                    | Input range setting (inputs 1 to 8)    |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
|                            | Input 8                                |          | Input 7  |          | Input 6  |          | Input 5  |         | Input 4                |         | Input 3  |         | Input 2  |         | Input 1 |         |
| D (m+2)                    | Input range setting (Inputs 9 to 16)   |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
|                            | Input 16                               |          | Input 15 |          | Input 14 |          | Input 13 |         | Input 12               |         | Input 11 |         | Input 10 |         | Input 9 |         |
| D (m+3)                    | Input 1 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+4)                    | Input 2 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+5)                    | Input 3 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+6)                    | Input 4 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+7)                    | Input 5 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+8)                    | Input 6 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+9)                    | Input 7 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+10)                   | Input 8 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+11)                   | Input 9 mean value processing setting  |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+12)                   | Input 10 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+13)                   | Input 11 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+14)                   | Input 12 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+15)                   | Input 13 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+16)                   | Input 14 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+17)                   | Input 15 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+18)                   | Input 16 mean value processing setting |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+19)                   | Conversion time/resolution setting     |          |          |          |          |          |          |         | Operation mode setting |         |          |         |          |         |         |         |
| D (m+20)                   | Input 1 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+21)                   | Input 1 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+22)                   | Input 2 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+23)                   | Input 2 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+24)                   | Input 3 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+25)                   | Input 3 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+26)                   | Input 4 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+27)                   | Input 4 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+28)                   | Input 5 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+29)                   | Input 5 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+30)                   | Input 6 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+31)                   | Input 6 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+32)                   | Input 7 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+33)                   | Input 7 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+34)                   | Input 8 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+35)                   | Input 8 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+36)                   | Input 9 scaling lower limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+37)                   | Input 9 scaling upper limit            |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+38)                   | Input 10 scaling lower limit           |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+39)                   | Input 10 scaling upper limit           |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+40)                   | Input 11 scaling lower limit           |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |
| D (m+41)                   | Input 11 scaling upper limit           |          |          |          |          |          |          |         |                        |         |          |         |          |         |         |         |

| DM Area word (See note 1.) | Bits                                                              |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
|----------------------------|-------------------------------------------------------------------|----------|----------|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
|                            | 15                                                                | 14       | 13       | 12       | 11       | 10       | 9        | 8       | 7       | 6       | 5       | 4       | 3       | 2       | 1       | 0       |
| D (m+42)                   | Input 12 scaling lower limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+43)                   | Input 12 scaling upper limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+44)                   | Input 13 scaling lower limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+45)                   | Input 13 scaling upper limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+46)                   | Input 14 scaling lower limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+47)                   | Input 14 scaling upper limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+48)                   | Input 15 scaling lower limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+49)                   | Input 15 scaling upper limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+50)                   | Input 16 scaling lower limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+51)                   | Input 16 scaling upper limit                                      |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
| D (m+52)                   | Voltage/current range setting (Only for 1 to 5 V and 4 to 20 mA.) |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
|                            | Input 16                                                          | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

### Set Values and Stored Values


| Item  |                               | Contents                                                                                                                                                                                                                                                                                                                                  | Page |
|-------|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Input | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                                  | 56   |
|       | Input signal range            | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V/4 to 20 mA (See note 1.)<br>11: 0 to 5 V                                                                                                                                                                                                                                                 | 56   |
|       | Mean value processing setting | 0000: Mean value processing with 2 buffers (See note 3.)<br>0001: Mean value processing not used<br>0002: Mean value processing with 4 buffers<br>0003: Mean value processing with 8 buffers<br>0004: Mean value processing with 16 buffers<br>0005: Mean value processing with 32 buffers<br>0006: Mean value processing with 64 buffers | 59   |
|       | Scaling setting               | Only set for CS1W-AD161                                                                                                                                                                                                                                                                                                                   | 64   |

- Note**
- For CS1W-AD041-V1 and CS1W-AD081-V1, the input signal range of “1 to 5 V” and “4 to 20 mA” is switched using the pins of the voltage/current switch. Refer to 2-3-4 *Voltage/Current Switch (CS1W-AD041-V1/AD081-V1)* for details. With CS1W-AD161, select voltage/current input by wiring the connector terminals.
  - The default of mean value processing setting is set to “Mean value processing with 2 buffers.” Refer to 2-6-3 *Mean Value Processing*.
  - Voltage/current input selection can be set for input signal ranges of 1 to 5 V and 4 to 20 mA using the switch at the back of the terminal block for CS1W-AD041-V1 and CS1W-AD081-V1, or selected when wiring the connector or in DM word m+52 for CS1W-AD161.

## 2-5-5 I/O Refresh Data Allocations


I/O refresh data for the Analog Input Unit is exchanged according to the allocations in the Special I/O Unit Area.

### CS1W-AD041-V1/AD081-V1





CS1W-AD161




- Note
1.

The words in the Special I/O Unit Area in the CIO Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. Refer to 2-5-2 Unit Number Settings for details on the method used to set the unit number switches.
2.

If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

Allocations for Normal Mode

For normal mode, set to OFF the operation mode switch on the rear panel of the Unit as shown in the following diagram, or set bits 00 to 07 in DM word m+18.



The allocation of words and bits in the CIO Area is shown in the following table.

## CS1W-AD041-V1

| I/O                     | Word  | Bits                     |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|-------------------------|-------|--------------------------|----|----|----|-----------------|----|---|---|-----------------|---|---|---|-------------------------|---------|---------|---------|
|                         |       | 15                       | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7               | 6 | 5 | 4 | 3                       | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n     | Not used.                |    |    |    |                 |    |   |   |                 |   |   |   | Peak value hold         |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |   |                 |   |   |   | Input 4                 | Input 3 | Input 2 | Input 1 |
| Input<br>(Unit to CPU)  | n + 1 | Input 1 conversion value |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         |       | 16 <sup>3</sup>          |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup> |   |   |   | 16 <sup>0</sup>         |         |         |         |
|                         | n + 2 | Input 2 conversion value |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 3 | Input 3 conversion value |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 4 | Input 4 conversion value |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 5 | Not used                 |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 6 | Not used                 |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 7 | Not used                 |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 8 | Not used                 |    |    |    |                 |    |   |   |                 |   |   |   |                         |         |         |         |
|                         | n + 9 | Alarm Flags              |    |    |    |                 |    |   |   | Not used        |   |   |   | Disconnection detection |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |   |                 |   |   |   | Input 4                 | Input 3 | Input 2 | Input 1 |

**Note** For the CIO word addresses, n = CIO 2000 + unit number x 10.

## CS1W-AD081-V1

| I/O                     | Word  | Bits                     |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|-------------------------|-------|--------------------------|----|----|----|-----------------|----|---|---|-------------------------|---------|---------|---------|-----------------|---------|---------|---------|
|                         |       | 15                       | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                       | 6       | 5       | 4       | 3               | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n     | Not used.                |    |    |    |                 |    |   |   | Peak value hold         |         |         |         |                 |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |   | Input 8                 | Input 7 | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |
| Input<br>(Unit to CPU)  | n + 1 | Input 1 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         |       | 16 <sup>3</sup>          |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup> |         |         |         |
|                         | n + 2 | Input 2 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 3 | Input 3 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 4 | Input 4 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 5 | Input 5 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 6 | Input 6 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 7 | Input 7 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 8 | Input 8 conversion value |    |    |    |                 |    |   |   |                         |         |         |         |                 |         |         |         |
|                         | n + 9 | Alarm Flags              |    |    |    |                 |    |   |   | Disconnection detection |         |         |         |                 |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |   | Input 8                 | Input 7 | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |

**Note** For the CIO word addresses, n = CIO 2000 + unit number x 10.

## CS1W-AD161

| I/O                     | Word   | Bits                          |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|-------------------------|--------|-------------------------------|----------|----------|----------|-----------------|----------|----------|---------|-----------------|-----------|---------|---------|-----------------|---------|---------|---------|
|                         |        | 15                            | 14       | 13       | 12       | 11              | 10       | 9        | 8       | 7               | 6         | 5       | 4       | 3               | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n      | Peak value hold               |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         |        | Input 16                      | Input 15 | Input 14 | Input 13 | Input 12        | Input 11 | Input 10 | Input 9 | Input 8         | Input 7   | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |
| Input<br>(Unit to CPU)  | n + 1  | Input 1 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         |        | 16 <sup>3</sup>               |          |          |          | 16 <sup>2</sup> |          |          |         | 16 <sup>1</sup> |           |         |         | 16 <sup>0</sup> |         |         |         |
|                         | n + 2  | Input 2 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 3  | Input 3 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 4  | Input 4 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 5  | Input 5 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 6  | Input 6 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 7  | Input 7 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 8  | Input 8 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 9  | Input 9 A/D conversion value  |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 10 | Input 10 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 11 | Input 11 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 12 | Input 12 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 13 | Input 13 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 14 | Input 14 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 15 | Input 15 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 16 | Input 16 A/D conversion value |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 17 | Not used.                     |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         | n + 18 | Disconnection detection       |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |
|                         |        | Input 16                      | Input 15 | Input 14 | Input 13 | Input 12        | Input 11 | Input 10 | Input 9 | Input 8         | Input 7   | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |
|                         | n + 19 | Alarm flags                   |          |          |          |                 |          |          |         |                 | Not used. |         |         |                 |         |         |         |
|                         |        |                               |          |          |          |                 |          |          |         |                 |           |         |         |                 |         |         |         |

**Note** For the CIO word addresses, n = CIO 2000 + unit number x 10.

## Set Values and Stored Values


| Item                                     | Contents                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | Page |
|------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Peak value hold function                 | 0: Not used.<br>1: Peak value hold used.                                                                                                                                                                                                                                                                                                                                                                                                                                         | 62   |
| Conversion value<br>(calculation result) | 4-digit hexadecimal                                                                                                                                                                                                                                                                                                                                                                                                                                                              | 57   |
| Disconnection detection                  | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                                                                                                                                                                                                                                          | 63   |
| Alarm Flags                              | <ul style="list-style-type: none"> <li>CS1W-AD041-VI and CS1W-AD081-V1: CIO n+9<br/>Bit 11: Mean value processing setting error<br/>Bit 15: Operating in adjustment mode (always OFF in normal mode)</li> <li>CS1W-AD161: CIO n+19<br/>Bit 08: Scaling data setting error<br/>Bit 11: Mean value processing setting error<br/>Bit 12: Conversion time/resolution or operation mode setting error<br/>Bit 15: Operating in adjustment mode (always OFF in normal mode)</li> </ul> | 75   |

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

**Allocation for Adjustment Mode**

For adjustment mode, turn ON the operation mode switch on the rear panel of the Unit as shown in the following diagram, or set bits 00 to 07 in DM word m+18 (m+19 for CS1W-AD161) to C1. When the Unit is set for adjustment mode, the ADJ indicator on the front panel of the Unit will flash.



The allocation of CIO words and bits is shown in the following table.

**CS1W-AD041-V1/AD081-V1**

| I/O                     | Word      | Bits                                   |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|-------------------------|-----------|----------------------------------------|----|----|----|----|----|-----------------|---|---------------------------------------|---------|-----------------|---------|-------------------------------|---------|-----------------|---------|
|                         |           | 15                                     | 14 | 13 | 12 | 11 | 10 | 9               | 8 | 7                                     | 6       | 5               | 4       | 3                             | 2       | 1               | 0       |
| Output<br>(CPU to Unit) | n         | Not used.                              |    |    |    |    |    |                 |   | Inputs to be adjusted                 |         |                 |         |                               |         |                 |         |
|                         |           |                                        |    |    |    |    |    |                 |   | 2 (fixed)                             |         |                 |         | 1 to 8 (1 to 4) (See note 1.) |         |                 |         |
|                         | n + 1     | Not used.                              |    |    |    |    |    |                 |   | Not used.                             |         | Clr             | Set     | Up                            | Down    | Gain            | Off-set |
|                         | n + 2     | Not used.                              |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|                         | n + 3     | Not used.                              |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|                         | n + 4     | Not used.                              |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|                         | n + 5     | Not used.                              |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|                         | n + 6     | Not used.                              |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
| n + 7                   | Not used. |                                        |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
| Input<br>(Unit to CPU)  | n + 8     | Conversion value at time of adjustment |    |    |    |    |    |                 |   |                                       |         |                 |         |                               |         |                 |         |
|                         |           | 16 <sup>3</sup>                        |    |    |    |    |    | 16 <sup>2</sup> |   |                                       |         | 16 <sup>1</sup> |         |                               |         | 16 <sup>0</sup> |         |
|                         | n + 9     | Alarm Flags                            |    |    |    |    |    |                 |   | Disconnection detection (See note 2.) |         |                 |         | Not used.                     |         |                 |         |
|                         |           |                                        |    |    |    |    |    |                 |   | Input 8                               | Input 7 | Input 6         | Input 5 | Input 4                       | Input 3 | Input 2         | Input 1 |


- Note**
1. Use settings 1 to 4 for the CS1W-AD041-V1.
  2. With the CS1W-AD041-V1, bits 04 to 07 in word n+9 (disconnection detection) are not used.

**CS1W-AD161**

| I/O                     | Word          | Bits                                   |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |
|-------------------------|---------------|----------------------------------------|----------|----------|----------|-------------------------------------|----------|----------|---------|-----------------|---------|---------|---------|-----------------|---------|---------|---------|
|                         |               | 15                                     | 14       | 13       | 12       | 11                                  | 10       | 9        | 8       | 7               | 6       | 5       | 4       | 3               | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n             | Not used.                              |          |          |          | Inputs to be adjusted (See note 2.) |          |          |         |                 |         |         |         |                 |         |         |         |
|                         |               |                                        |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |
|                         | n + 1         | Not used.                              |          |          |          |                                     |          |          |         |                 |         | Clr     | Set     | ---             | ---     | Gain    | Off-set |
|                         | n + 2 to n+16 | Not used.                              |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |
| Input<br>(Unit to CPU)  | n + 17        | Conversion value at time of adjustment |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |
|                         |               | 16 <sup>3</sup>                        |          |          |          | 16 <sup>2</sup>                     |          |          |         | 16 <sup>1</sup> |         |         |         | 16 <sup>0</sup> |         |         |         |
|                         | n + 18        | Disconnection detection                |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |
|                         |               | Input 16                               | Input 15 | Input 14 | Input 13 | Input 12                            | Input 11 | Input 10 | Input 9 | Input 8         | Input 7 | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |
|                         | n + 19        | Alarm Flags                            |          |          |          |                                     |          |          |         | Not used.       |         |         |         |                 |         |         |         |
|                         |               |                                        |          |          |          |                                     |          |          |         |                 |         |         |         |                 |         |         |         |

- Note**
1. For the CIO word addresses, n = CIO 2000 + unit number × 10.

2. The input format used for adjustment is as follows:



### Set Values and Stored Values

Refer to 2-7-1 Adjustment Mode Operational Flow for further details.

| Item                            | Contents                                                                                                                                                                                                                                                  |
|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input to be adjusted            | Sets input to be adjusted.<br>Leftmost digit: 2 (fixed)<br>Rightmost digit: 1 to 8 (1 to 4 for CS1W-AD041-V1)                                                                                                                                             |
| Offset (Offset Bit)             | When ON, adjusts offset error.                                                                                                                                                                                                                            |
| Gain (Gain Bit)                 | When ON, adjusts gain error.                                                                                                                                                                                                                              |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                                                                                                                                                                 |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                                                                                                                                                                 |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                                                                                                                                                                 |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                                                                                                                                                                        |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                                                                                                                                                                  |
| Disconnection detection         | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                   |
| Alarm Flags                     | Bit 12: Input value is outside adjustment limits (in adjustment mode)<br>Bit 13: Input number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode (always 1 in adjustment mode) |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

## 2-6 Analog Input Functions and Operating Procedures

### 2-6-1 Input Settings and Conversion Values

#### Input Numbers

The Analog Input Unit converts analog inputs specified by input numbers. To specify the analog inputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.

|      |          |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
|------|----------|----------|----------|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Bit  | 15       | 14       | 13       | 12       | 11       | 10       | 09       | 08      | 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
| D(m) | Input 16 | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$m = D20000 + \text{unit number} \times 100$

Setting 0: Not used.

1: Used

- CS1W-AD041-V1: Inputs 1 to 4
- CS1W-AD081-V1: Inputs 1 to 8

The analog input sampling interval can be shortened by setting any unused input numbers to 0.

Sampling interval = (1 ms) x (Number of inputs used) (See note.)

**Note** Use 250  $\mu$ s instead of 1 ms is set to a conversion time of 250  $\mu$ s and resolution of 8,000.

The conversion values in words for inputs that have been set to “Not used” will always be “0000.”


For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

#### Input Signal Range

Any of four types of input signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, and 4 to 20 mA) can be selected for each of the inputs.

#### CS1W-AD041-V1/AD081-V1

To specify the input signal range for each input, set from a Programming Device the D(m + 1) bits in the DM Area as shown in the following diagram.



**Note** There are only four inputs for the CS1W-AD041-V1.

#### CS1W-AD161

|         |          |    |          |    |          |    |          |    |          |    |          |    |          |    |         |    |
|---------|----------|----|----------|----|----------|----|----------|----|----------|----|----------|----|----------|----|---------|----|
| Bit     | 15       | 14 | 13       | 12 | 11       | 10 | 09       | 08 | 07       | 06 | 05       | 04 | 03       | 02 | 01      | 00 |
| D (m+1) | Input 8  |    | Input 6  |    | Input 6  |    | Input 5  |    | Input 4  |    | Input 3  |    | Input 2  |    | Input 1 |    |
| D (m+2) | Input 16 |    | Input 15 |    | Input 14 |    | Input 13 |    | Input 12 |    | Input 11 |    | Input 10 |    | Input 9 |    |

$m = D20000 + \text{unit number} \times 100$

00: -10 to +10 V  
 01: 0 to 10 V  
 10: 1 to 5 V/4 to 20 mA (See note 2.)  
 11: 0 to 10 V

Select the input signal range 1 to 5 V/4 to 20 mA by wiring the connector or terminal block conversion connector. The voltage/current input setting can also be set using DM word m+52.

| Bit      | 15       | 14       | 13       | 12       | 11       | 10       | 09       | 08      | 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
|----------|----------|----------|----------|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| D (m+52) | Input 16 | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$$m = D20000 + \text{unit number} \times 100$$

0: 1 to 5 V  
 1: 4 to 20 mA

- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$
  2. The input signal range of “1 to 5 V” or “4 to 20 mA” is switched using the voltage/current switch.
  3. When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

### Reading Conversion Values

Analog input conversion values are read in 4-digit hexadecimal for each input.


| Address | CS1W-AD161                | CS1W-AD081-V1            | CS1W-AD041-V1            |
|---------|---------------------------|--------------------------|--------------------------|
| n+1     | Input 1 conversion value  | Input 1 conversion value | Input 1 conversion value |
| n+2     | Input 2 conversion value  | Input 2 conversion value | Input 2 conversion value |
| n+3     | Input 3 conversion value  | Input 3 conversion value | Input 3 conversion value |
| n+4     | Input 4 conversion value  | Input 4 conversion value | Input 4 conversion value |
| n+5     | Input 5 conversion value  | Input 5 conversion value | Cannot be used.          |
| n+6     | Input 6 conversion value  | Input 6 conversion value |                          |
| n+7     | Input 7 conversion value  | Input 7 conversion value |                          |
| n+8     | Input 8 conversion value  | Input 8 conversion value |                          |
| n+9     | Input 9 conversion value  | Cannot be used.          |                          |
| n+10    | Input 0 conversion value  |                          |                          |
| n+11    | Input 1 conversion value  |                          |                          |
| n+12    | Input 12 conversion value |                          |                          |
| n+13    | Input 13 conversion value |                          |                          |
| n+14    | Input 14 conversion value |                          |                          |
| n+15    | Input 15 conversion value |                          |                          |
| n+16    | Input 16 conversion value |                          |                          |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


Use MOV(021) or XFER(070) to read conversion values in the user program.

**Example 1**

In this example, the conversion data from only one input is read. (The unit number is 0.)

**Example 2**

In this example, the conversion data from multiple inputs is read. (The unit number is 0.)



For details regarding conversion value scaling, refer to *Scaling* on page 448.

## 2-6-2 Conversion Time/Resolution Setting

The default setting is a conversion cycle of 1 ms and resolution of 4,000. For even higher speed and precision, change the settings in bits 08 to 15.

### CS1W-AD041-V1/AD081-V1

| Bit      | 15                                                                                                                                                      | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                                                | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|----------|---------------------------------------------------------------------------------------------------------------------------------------------------------|----|----|----|----|----|---|---|------------------------------------------------------------------|---|---|---|---|---|---|---|
| D (m+18) | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 $\mu$ s and resolution of 8,000 |    |    |    |    |    |   |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |   |   |   |   |   |   |   |

$$m = D20000 + \text{unit number} \times 100$$

### CS1W-AD161

| Bit      | 15                                                                                                                                                      | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                                                | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
|----------|---------------------------------------------------------------------------------------------------------------------------------------------------------|----|----|----|----|----|---|---|------------------------------------------------------------------|---|---|---|---|---|---|---|
| D (m+19) | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 $\mu$ s and resolution of 8,000 |    |    |    |    |    |   |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |   |   |   |   |   |   |   |


$$m = D20000 + \text{unit number} \times 100$$

**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.



### 2-6-3 Mean Value Processing

The Analog Input Unit can compute the mean value of the conversion values of analog inputs that have been previously sampled. Mean value processing involves an operational mean value in the history buffers, so it has no effect on the data refresh cycle. (The number of history buffers that can be set to use mean value processing is 2, 4, 8, 16, 32, or 64.)



When “n” number of history buffers are being used, the first conversion data will be stored for all “n” number of history buffers immediately data conversion has begun or after a disconnection is restored.

When mean value processing is used together with the peak value hold function, the mean value will be held.

Specify whether or not to use mean value processing and the number of history buffers to be used for mean value processing.

| Address  | CS1W-AD161 | CS1W-AD081-V1   | CS1W-AD041-V1   | Set value                                                                                                                                                                                                                                                                                                             |
|----------|------------|-----------------|-----------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+2)  | ---        | Input 1         | Input 1         | 0000: Mean value processing with 2 buffers<br>0001: No mean value processing<br>0002: Mean value processing with 4 buffers<br>0003: Mean value processing with 8 buffers<br>0004: Mean value processing with 16 buffers<br>0005: Mean value processing with 32 buffers<br>0006: Mean value processing with 64 buffers |
| D (m+3)  | Input 1    | Input 2         | Input 2         |                                                                                                                                                                                                                                                                                                                       |
| D (m+4)  | Input 2    | Input 3         | Input 3         |                                                                                                                                                                                                                                                                                                                       |
| D( m+5)  | Input 3    | Input 4         | Input 4         |                                                                                                                                                                                                                                                                                                                       |
| D (m+6)  | Input 4    | Input 5         | Cannot be used. |                                                                                                                                                                                                                                                                                                                       |
| D (m+7)  | Input 5    | Input 6         |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+8)  | Input 6    | Input 7         |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+9)  | Input 7    | Input 8         |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+10) | Input 8    | Cannot be used. |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+11) | Input 9    |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+12) | Input 10   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+13) | Input 11   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+14) | Input 12   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+15) | Input 13   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+16) | Input 14   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+17) | Input 15   |                 |                 |                                                                                                                                                                                                                                                                                                                       |
| D (m+18) | Input 16   |                 |                 |                                                                                                                                                                                                                                                                                                                       |


For the DM word addresses,  $m = D2000 + (\text{unit number} \times 100)$

**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special

I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.


The history buffer moving average is calculated as shown below. (In this example, there are four buffers.)

- 1,2,3...** 1. With the first cycle, data 1 is stored in all the history buffers.




$$\text{Mean value} = (\text{Data 1} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

2. With the second cycle, data 2 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 2} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

3. With the third cycle, data 3 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 3} + \text{Data 2} + \text{Data 1} + \text{Data 1}) \div 4$$

4. With the fourth cycle, data 4 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 4} + \text{Data 3} + \text{Data 2} + \text{Data 1}) \div 4$$


5. With the fifth cycle, data 5 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 5} + \text{Data 4} + \text{Data 3} + \text{Data 2}) \div 4$$

When a disconnection is restored, the mean value processing function begins again from step 1.

- Note**
1. The default setting for mean value processing in the Analog Input Unit is mean value processing with 2 buffers. The response time for the default setting is different from when there is no mean processing, as shown in the following diagram.
  2. Specify “no mean value processing” to follow conversion of a rapid change in input signals.
  3. If the averaging function is used, the delay in the conversion data in comparison to changes in the input signals will be as shown below.



For V = 20 V (–10 to 10 V)

**1-ms Conversion Time/4,000 Resolution**

**Using One Word**

$$t = n + (2 \text{ to } 3)$$

**Using m Words (1 ≤ m ≤ 16)**

No averaging (n = 1) or two averaging buffers (n = 2):

$$t = n \times (m + 2)$$

n averaging buffers (4 ≤ n ≤ 64):

$$t = (n - 2) \times m + 10.5$$

**250-μs Conversion Time/8,000 Resolution (For version-1 Unit)**

**Using One Word**

$$t = n + (2 \text{ to } 3) \times 1/4$$

**Using m Words (1 ≤ m ≤ 16)**

No averaging (n = 1) or two averaging buffers (n = 2):

$$t = n \times (m + 2) \times 1/4$$

n averaging buffers (4 ≤ n ≤ 64):

$$t = \{(n - 2) \times m + 10.5\} \times 1/4$$

**Response Time at 1-ms  
Conversion Time/4,000  
Resolution**

Unit: ms

| M  | N      |       |       |       |      |    |    |
|----|--------|-------|-------|-------|------|----|----|
|    | 64     | 32    | 16    | 8     | 4    | 2  | 1  |
| 16 | 1002.5 | 490.5 | 234.5 | 106.5 | 42.5 | 36 | 18 |
| 15 | 940.5  | 460.5 | 220.5 | 100.5 | 40.5 | 34 | 17 |
| 14 | 878.5  | 430.5 | 206.5 | 94.5  | 38.5 | 32 | 16 |
| 13 | 816.5  | 400.5 | 192.5 | 88.5  | 36.5 | 30 | 15 |
| 12 | 754.5  | 370.5 | 178.5 | 82.5  | 34.5 | 28 | 14 |
| 11 | 692.5  | 340.5 | 164.5 | 76.5  | 32.5 | 26 | 13 |
| 10 | 630.5  | 310.5 | 150.5 | 70.5  | 30.5 | 24 | 12 |
| 9  | 568.5  | 280.5 | 136.5 | 64.5  | 28.5 | 22 | 11 |
| 8  | 506.5  | 250.5 | 122.5 | 58.5  | 26.5 | 20 | 10 |
| 7  | 444.5  | 220.5 | 108.5 | 52.5  | 24.5 | 18 | 9  |
| 6  | 382.5  | 190.5 | 94.5  | 46.5  | 22.5 | 16 | 8  |
| 5  | 320.5  | 160.5 | 80.5  | 40.5  | 20.5 | 14 | 7  |
| 4  | 258.5  | 130.5 | 66.5  | 34.5  | 18.5 | 12 | 6  |
| 3  | 196.5  | 100.5 | 52.5  | 28.5  | 16.5 | 10 | 5  |
| 2  | 134.5  | 70.5  | 38.5  | 22.5  | 14.5 | 8  | 4  |
| 1  | 67     | 35    | 19    | 11    | 7    | 5  | 3  |

**Response Time at 250- $\mu$ s  
Conversion Time/8,000  
Resolution**

Unit: ms

| M  | N       |         |        |        |        |      |      |
|----|---------|---------|--------|--------|--------|------|------|
|    | 64      | 32      | 16     | 8      | 4      | 2    | 1    |
| 16 | 250.625 | 122.625 | 58.625 | 26.625 | 10.625 | 9    | 4.5  |
| 15 | 235.125 | 115.125 | 55.125 | 25.125 | 10.125 | 8.5  | 4.25 |
| 14 | 219.625 | 107.625 | 51.625 | 23.625 | 9.625  | 8    | 4    |
| 13 | 204.125 | 100.125 | 48.125 | 22.125 | 9.125  | 7.5  | 3.75 |
| 12 | 188.625 | 92.625  | 44.625 | 20.625 | 8.625  | 7    | 3.5  |
| 11 | 173.125 | 85.125  | 41.125 | 19.125 | 8.125  | 6.5  | 3.25 |
| 10 | 157.625 | 77.625  | 37.625 | 17.625 | 7.625  | 6    | 3    |
| 9  | 142.125 | 70.125  | 34.125 | 16.125 | 7.125  | 5.5  | 2.75 |
| 8  | 126.625 | 62.625  | 30.625 | 14.625 | 6.625  | 5    | 2.5  |
| 7  | 111.125 | 55.125  | 27.125 | 13.125 | 6.125  | 4.5  | 2.25 |
| 6  | 95.625  | 47.625  | 23.625 | 11.625 | 5.625  | 4    | 2    |
| 5  | 80.125  | 40.125  | 20.125 | 10.125 | 5.125  | 3.5  | 1.75 |
| 4  | 64.625  | 32.625  | 16.625 | 8.625  | 4.625  | 3    | 1.5  |
| 3  | 49.125  | 25.125  | 13.125 | 7.125  | 4.125  | 2.5  | 1.25 |
| 2  | 33.625  | 17.625  | 9.625  | 5.625  | 3.625  | 2    | 1    |
| 1  | 16.75   | 8.75    | 4.75   | 2.75   | 1.75   | 1.25 | 0.75 |

### Symbols

M: Number of input words used in DM Area

N: Average number of buffers set for the input number for which to find the response time


### Calculation Example

The following example calculations are for a resolution of 8,000 with an application using inputs 1 and 8, 64 averaging buffers set for input 1, and no averaging set for input 8.

- Response time for input 1:  $t = \{(64 - 2) \times 2 + 10.5\} \times 1/4 = 34$  (ms)
- Response time for input 1:  $t = 1 \times (2 + 2) \times 1/4 = 1$  (ms)

## 2-6-4 Peak Value Hold Function

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). This function can be used with analog input. The following diagram shows how digital conversion values are affected when the peak value hold function is used.



The peak value hold function can be set separately for each input number by turning ON the respective bits (00 to 07 for CS1W-AD081-V1, 00 to 03 for CS1W-AD041-V1) in CIO word n.

| Bit    | 15       | 14       | 13       | 12       | 11       | 10       | 09       | 08      | 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
|--------|----------|----------|----------|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Word n | Input 16 | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$$n = D20000 + \text{unit number} \times 10$$

Setting 0: Not used (the conversion value is reset when the bit turns OFF)


1: Peak value hold function is used (held while ON)

- CS1W-AD041-V1: Inputs 1 to 4

- CS1W-AD081-V1: Inputs 1 to 8

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

In the following example, the peak value hold function is in effect for input number 1, and the unit number is 0.



When mean value processing is used together with the peak value hold function, the mean value will be held.

As long as the peak value hold function is in effect, the peak value hold will be held even in the event of a disconnection.

When the load to the CPU Unit is disconnected, the Peak Value Hold Bits.

## 2-6-5 Input Disconnection Detection Function

When an input signal range of 1 to 5 V (4 to 20 mA) is used, input circuit disconnections can be detected. The detection conditions for each of the input signal ranges are shown in the following table. (see note)

| Range      | Current/voltage  |
|------------|------------------|
| 1 to 5 V   | Less than 0.3 V  |
| 4 to 20 mA | Less than 1.2 mA |

**Note** The current/voltage level will fluctuate according to the offset/gain adjustment.

The following bits turn ON when a disconnection is detected in each input. When the connection is recovered, these bits turn OFF. Be sure to specify these bits in the execution condition of the ladder program when using the disconnection detection function in the user program.

### CS1W-AD041-V1/AD081-V1

|          |           |    |    |    |    |    |    |    |         |         |         |         |         |         |         |         |
|----------|-----------|----|----|----|----|----|----|----|---------|---------|---------|---------|---------|---------|---------|---------|
| Bit      | 15        | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
| Word n+9 | Not used. |    |    |    |    |    |    |    | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$$n = 2000 + \text{unit number} \times 10$$

CS1W-AD041-V1: Inputs 1 to 4

### CS1W-AD161

|           |          |          |          |          |          |          |          |         |         |         |         |         |         |         |         |         |
|-----------|----------|----------|----------|----------|----------|----------|----------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Bit       | 15       | 14       | 13       | 12       | 11       | 10       | 09       | 08      | 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
| Word n+18 | Input 16 | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$$n = 2000 + \text{unit number} \times 10$$

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The conversion value during a disconnection will be 0000.

In the following example, the conversion value is read only if there is no disconnection at analog input number 1. (The unit number is 0.)



## 2-6-6 Scaling Function (CS1W-AD161 Only)

With the CS1W-AD161, the scaling function can be used to convert data into engineering units after A/D conversion. The scaling function can only be used when the resolution is set to 4,000. Scaling is not supported for resolutions of 8,000.

### Overview

When using a resolution of 4,000, A/D conversion data in the ranges 1 to 5 V, 0 to 5 V, 0 to 10 V, or 4 to 20 mA will be scaled to values between 0 and 4,000 (decimal), approximately. A/D conversion data in the range -10 to +10 V will be scaled to values between -2,000 and +2,000 (decimal), approximately. (Actual D/A conversion is executed up to -5% to +105% of full scale.)

The lower limit and upper limit can be set to between -32,000 and +32,000 (decimal). Actual settings in DM word m+20 to DM word m+51 are set in 4-digit hexadecimal. (In the above example, the lower limit is 0000 and the upper limit is 03E8 hexadecimal.)

- Besides upper limit and lower limit. (Reverse scaling is supported.)
- Negative values are set as two's complement
- Scaling is not performed when the upper limit and lower limit are both set to 0000 (default setting).

## 2-7 Adjusting Offset and Gain

### 2-7-1 Adjustment Mode Operational Flow

The adjustment mode enables the input of the connected devices to be calibrated.


The offset voltage (or current) and gain voltage (or current) at the output device are entered as analog input conversion data 0000 and 0FA0 (07D0 if the range is  $\pm 10$  V) respectively for a resolution of 4,000.

For example, when using in the range 1 to 5 V, the actual output may be in the range 0.8 to 4.8 V, even though the specifications range for the external device is 1 to 5 V. In this case, when an offset voltage of 0.8 V is output at the external device, the conversion data at the Analog Input Unit for a resolution of 4,000 will be FF38, and if a gain voltage of 4.8 V is output, the conversion data will be 0EDA. The offset/gain adjustment function will, for this example, convert 0.8 V and 4.8 V to 0000 and 0FA0 respectively and not to FF38 and 0EDA, as illustrated in the following table.

| Offset/gain voltage at the output device | Conversion data before adjustment | Conversion data after adjustment |
|------------------------------------------|-----------------------------------|----------------------------------|
| 0.8 V                                    | FF38 (FE70)                       | 0000 (0000)                      |
| 4.8 V                                    | 0EDA (0DB4)                       | 0FA0 (1F40)                      |

(Values in parentheses are for a resolution of 8,000.)

The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.



**⚠ Caution** Be sure to turn OFF the power to the PLC before changing the setting of the operation mode switch.

**⚠ Caution** The power must be cycled or the Unit restarted if the operation mode is set in DM.

**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog Input Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog Input Unit will stop operating, and the input values that existed immediately before this stoppage will be retained.

**⚠ Caution** Always perform adjustments in conjunction with offset and gain adjustments.

**Note** Input adjustments can be performed more accurately in conjunction with mean value processing.

## 2-7-2 Input Offset and Gain Adjustment Procedures

### Specifying Input Number to be Adjusted

The following bits turn ON when a disconnection is detected in each input. When the connection is recovered, these bits turn OFF. Be sure to specify these bits in the execution condition of the ladder program when using the disconnection detection function in the user program.

#### CS1W-AD041-V1-AD081-V1

| Bit    | 15        | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03                                              | 02 | 01 | 00 |
|--------|-----------|----|----|----|----|----|----|----|----|----|----|----|-------------------------------------------------|----|----|----|
| Word n | Not used. |    |    |    |    |    |    |    | 0  | 0  | 1  | 0  | Input numbers to be adjusted 1 to 8 (See note.) |    |    |    |

$n = \text{CIO } 2000 + \text{unit number} \times 10$

2: Input (fixed)

**Note** Use inputs 1 to 4 for the CS1W-AD041-V1.

#### CS1W-AD161

| Bit    | 15        | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                               | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|--------|-----------|----|----|----|----|----|----|----|--------------------------------------------------|----|----|----|----|----|----|----|
| Word n | Not used. |    |    |    | 0  | 0  | 1  | 0  | Input numbers to be adjusted 1 to 16 (See note.) |    |    |    |    |    |    |    |

$n = \text{CIO } 2000 + \text{unit number} \times 10$

2: Input (fixed)

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The following example shows an adjustment for input number 1 using a CS1W-AD041-V1/081-V1 for illustration. (The unit number is 0.)

CLR

SHIFT

CH  
\*DM

C  
2

A  
0

A  
0

A  
0

MON

CHG

C  
2

B  
1

WRITE

000000 CT00

2000 0000


2000 0000  
PRES VAL ?????

2000 0021




**Bits Used for Adjusting Offset and Gain**

The CIO word (n+1) bits shown in the following diagram are used for adjusting offset and gain.

**Offset Adjustment**

The procedure for adjusting the analog input offset is explained below. As shown in the following diagram, the offset is adjusted by sampling inputs so that the conversion value becomes 0.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

A  
0

MON

200100 ^ OFF

SET


200100 ^ ON

For CS1W-AD041-V1 and CS1W-AD081-V1, the analog input's digital conversion values while the Offset Bit is ON will be monitored in CIO word n+8. For CS1W-AD161, the values will be monitored in CIO word n+17.


2. Check whether the input devices are connected.

**Wiring for Voltage Input**

CS1W-AD041-V1/081-V1




CS1W-AD161

**Wiring for Current Input**


When using current input, short-circuit the input (+) terminal and the current mode terminal.

CS1W-AD041-V1/081-V1



For current input, check that the voltage/  
current switch is ON.

CS1W-AD161



3. Input the voltage or current so that the conversion value becomes 0000. The following table shows the offset adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value     |
|--------------------|-----------------|---------------------------------|
| 0 to 10 V          | -0.5 to 0.5 V   | FF38 to 00C8 (4,000 resolution) |
| -10 to 10 V        | -1.0 to 1.0 V   |                                 |
| 1 to 5 V           | 0.8 to 1.2 V    | FE70 to 0190 (8,000 resolution) |
| 0 to 5 V           | -0.25 to 0.25 V |                                 |
| 4 to 20 mA         | 3.2 to 4.8 mA   |                                 |

4. After inputting the voltage or current so that the conversion value for the analog input terminal is 0000, turn ON bit 04 (the Set Bit) of CIO word n+1, and then turn it OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200100 ^ ON

RESET

200100 ^ OFF


**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
1. The EEPROM can be overwritten 50,000 times.
  2. While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

## Gain Adjustment


The procedure for adjusting the analog input gain is explained below. As shown in the following diagram, the gain is adjusted by sampling inputs so that the conversion value is maximized.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)




For CS1W-AD041-V1 and CS1W-AD081-V1, the analog input's digital conversion values while the Gain Bit is ON will be monitored in CIO word n+8. For CS1W-AD161, the values will be monitored in CIO word n+17.


2. Check whether the input devices are connected.

## Wiring for Voltage Input

## CS1W-AD041-V1/081-V1




## CS1W-AD161




**Wiring for Current Input**

When using current input, short-circuit the input (+) terminal and the current mode terminal.

**CS1W-AD041-V1/081-V1**

For current input, check that the voltage/current switch is ON.


**CS1W-AD161**

- Input the voltage or current so that the conversion value is maximized (0FA0 or 07D0 at a resolution of 4,000). The following table shows the gain adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value |
|--------------------|-----------------|-----------------------------|
| 0 to 10 V          | 9.5 to 10.5 V   | 0ED8 to 1068 (0FB0 to 20D0) |
| -10 to 10 V        | 9.0 to 11.0 V   | 0708 to 0898 (0E10 to 1130) |
| 1 to 5 V           | 4.8 to 5.2 V    | 0ED8 to 1068 (0FB0 to 20D0) |
| 0 to 5 V           | 4.75 to 5.25 V  | 0ED8 to 1068 (0FB0 to 20D0) |
| 4 to 20 mA         | 19.2 to 20.8 mA | 0ED8 to 1068 (0FB0 to 20D0) |

(Values in parentheses are for a resolution of 8,000.)

- With the voltage or current having been input so that the conversion value for the Analog Input Unit is maximized (0FA0 or 07D0), turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.



200104 ^ OFF



200104 ^ ON



200104 ^ OFF

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200101 ^ ON

RESET

200101 ^ OFF

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
1. The EEPROM can be overwritten 50,000 times.
  2. While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

### Clearing Offset and Gain Adjusted Values

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses adjustment for illustration. (The unit number is 0.)

- 1,2,3...**
1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the input value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

SET

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET


200104 ^ ON

RESET

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

- To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.



**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.


**Note** The EEPROM can be overwritten 50,000 times.

## 2-8 Handling Errors and Alarms

### 2-8-1 Indicators and Error Flowchart

#### Indicators


If an alarm or error occurs in the Analog Input Unit, the ERC or ERH indicators on the front panel of the Unit will light.



| LED          | Meaning                | Indicator | Operating status                                                                        |
|--------------|------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                                               |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit   | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit   | Operating normally.                                                                     |

**Troubleshooting Procedure**

Use the following procedure for troubleshooting Analog Input Unit errors.

**2-8-2 Alarms Occurring at the Analog Input Unit**

If an error is detected in the Analog Input Unit, the ERC indicator will light and the corresponding bit will turn ON.

Disconnection Detection Flags operate when the input range is set to 1 to 5 V or 4 to 20 mA.



**CS1W-AD041-V1/AD081-V1**

|          |             |    |    |    |    |    |    |    |                                           |         |         |         |         |         |         |         |
|----------|-------------|----|----|----|----|----|----|----|-------------------------------------------|---------|---------|---------|---------|---------|---------|---------|
| Bit      | 15          | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                        | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
| Word n+9 | Alarm Flags |    |    |    |    |    |    |    | Disconnection Detection Flags (See note.) |         |         |         |         |         |         |         |
|          |             |    |    |    |    |    |    |    | Input 8                                   | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

$m = D20000 + \text{unit number} \times 10$

**Note** Use inputs 1 to 4 for the CS1W-AD041-V1.

**CS1W-AD161**


|           |                               |          |          |          |          |          |          |         |           |         |         |         |         |         |         |         |
|-----------|-------------------------------|----------|----------|----------|----------|----------|----------|---------|-----------|---------|---------|---------|---------|---------|---------|---------|
| Bit       | 15                            | 14       | 13       | 12       | 11       | 10       | 09       | 08      | 07        | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
| Word n+18 | Disconnection Detection Flags |          |          |          |          |          |          |         |           |         |         |         |         |         |         |         |
|           | Input 16                      | Input 15 | Input 14 | Input 13 | Input 12 | Input 11 | Input 10 | Input 9 | Input 8   | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |
| Word n+19 | Alarm Flags                   |          |          |          |          |          |          |         | Not used. |         |         |         |         |         |         |         |

$n = CIO\ 2000 + \text{unit number} \times 10$

**Alarm Flags**

| Model | CS1W-AD041-V1<br>CS1W-AD081-V1 | CS1W-AD161 | Contents                                                     |
|-------|--------------------------------|------------|--------------------------------------------------------------|
| Word  | n+9                            | n+19       |                                                              |
| Bit   | 15                             | 15         | Operating in adjustment mode.                                |
|       | 14                             | 14         | EEPROM error occurred during adjustment mode.                |
|       | 13                             | 13         | Input number setting error occurred during adjustment mode.  |
|       | 12                             | 12         | Input adjustment value outside range during adjustment mode. |
|       | 11                             | 11         | Mean average processing error occurred.                      |
|       | ---                            | 08         | Scaling data setting error occurred.                         |

$n = CIO\ 2000 + \text{unit number} \times 10$

**ERC and RUN Indicators: Lit**

The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.


| Word n+9,<br>n+18, or n+19<br>(See note 1.) | Alarm flag                 | Error contents                                 | Input status                     | Countermeasure                                                                                                                                  |
|---------------------------------------------|----------------------------|------------------------------------------------|----------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 07<br>(See note 2.)              | Disconnection<br>Detection | A disconnection was detected.<br>(See note 3.) | Conversion data<br>becomes 0000. | Check the rightmost byte of CIO<br>word n+9. The inputs for bits<br>that are ON may be discon-<br>nected. Restore any discon-<br>nected inputs. |

| Word n+9, n+18, or n+19<br>(See note 1.) | Alarm flag                                | Error contents                                                 | Input status                                                         | Countermeasure                                                                                                         |
|------------------------------------------|-------------------------------------------|----------------------------------------------------------------|----------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------|
| Bit 14                                   | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the values immediately prior to the error. No data is changed. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog Input Unit. |

$$n = \text{CIO 2000} + \text{unit number} \times 10$$

- Note**
1. These alarms are output in word n+9 for CS1W-AD041-V1 and CS1W-AD081-V1, and in words n+18/n+19 for CS1W-AD161.
  2. The CS1W-AD041-V1 uses bits 00 to 08 of word n+9, and the CS1W-AD081-V1 uses bits 00 to 04. The CS1W-AD161 uses bits 00 to 15 of word n+18.
  3. The disconnection detection function is enabled for input numbers set within the input ranges 1 to 5 V or 4 to 20 mA.

#### ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing



This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.


| Word n+9/n+19<br>(See note 2.)  | Alarm flag                                                 | Error contents                                                                                                                                           | Input status                                                                                  | Countermeasure                                                                                                                                                                                                                                                                                                                                           |
|---------------------------------|------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 12                          | (Adjustment mode)<br>Input Value Adjustment Range Exceeded | In adjustment mode, offset or gain cannot be adjusted because input value is out of the permissible range for adjustment.                                | Conversion data corresponding to the input signal is monitored in word n+8/n+18 (see note 3). | If making the adjustment by means of a connected input device, first adjust the input device before adjusting the Analog Input Unit.                                                                                                                                                                                                                     |
| Bit 13                          | (Adjustment mode)<br>Input Number Setting Error            | In adjustment mode, adjustment cannot be performed because the specified input number is not set for use or because the wrong input number is specified. | Holds the values immediately prior to the error. No data is changed.                          | <ul style="list-style-type: none"> <li>• Check whether the word n input number to be adjusted is set within the following ranges:<br/>CS1W-AD041-V1: 21 to 24<br/>CS1W-AD801-V1: 21 to 28<br/>CS1W-AD161: 201 to 216</li> <li>• Check whether the input number to be adjusted is set for use by means of the DM setting (DM word m set to 1).</li> </ul> |
| Bit 15 only ON<br>(See note 5.) | (Adjustment Mode)<br>PLC Error                             | The PLC is in either MONITOR or RUN mode while the Analog Input Unit is operating in adjustment mode.                                                    | Holds the values immediately prior to the error. No data is changed.                          | Set the Unit to normal mode either by removing the Unit and setting the DIP switch on the rear panel or by setting the mode in DM word m+18 (see note 4), and then restart the Unit.                                                                                                                                                                     |

$$n = \text{CIO 2000} + \text{unit number} \times 10$$

- Note**
1. When a PLC error occurs in the adjustment mode, the Unit will stop operating. (The input values immediately prior to the error are held.)

- These alarms are output in CIO word n+9 for CS1W-AD041-V1 and CS1W-AD081-V1, and in CIO word n+19 for CS1W-AD161.
- These alarms are output in CIO word n+8 for CS1W-AD041-V1 and CS1W-AD081-V1, and in CIO word n+18 for CS1W-AD161.
- The operation mode is set in DM word m+18 for CS1W-AD041-V1 and CS1W-AD081-V1, and in DM word m+19 for CS1W-AD161.
- Bit 15 is always ON in adjustment mode. When the PLC is in RUN mode or MONITOR mode, the ERC indicator will be lit.

**ERC Indicator: Lit, RUN Indicator: Not Lit**



The ERC indicator will be lit when the initial settings for the Analog Input Unit are not set correctly. The following alarm flags will turn ON in CIO word. These alarm flags will turn OFF when the error is cleared and the Unit is restarted, or the Special I/O Unit Restart Bit is turned ON and then OFF again.


| Word n+9/n+19<br>(See note.) | Alarm flag                                   | Error contents                                                        | Input status                                     | Countermeasure                      |
|------------------------------|----------------------------------------------|-----------------------------------------------------------------------|--------------------------------------------------|-------------------------------------|
| Bit 11                       | Mean Value Processing Setting Error          | The wrong number of samplings has been specified for mean processing. | Conversion does not start and data becomes 0000. | Specify a number from 0000 to 0006. |
| Bit 12                       | Conversion Time/Operation Mode Setting Error | The setting for conversion time/resolution is incorrect.              | Conversion does not start and data becomes 0000. | Specify 00 or C1.                   |

**Note** These alarms are output in CIO word n+9 for CS1W-AD041-V1 and CS1W-AD081-V1, and in CIO word n+19 for CS1W-AD161.

### 2-8-3 Errors in the CPU Unit

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Input Unit from operating.

**ERH and RUN Indicators: Lit**



The ERH and RUN indicators will be lit if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog Input Unit.

Turn ON the power supply again or restart the system.


For further details, refer to *CS-series CS1G/H-CPU□□-EV1, CS1G/H-CPU□□H Programmable Controllers Operation Manual (W339)*.

| Error         | Error contents                                             | Input status                  |
|---------------|------------------------------------------------------------|-------------------------------|
| I/O bus error | Error has occurred during data exchange with the CPU Unit. | Conversion data becomes 0000. |

| Error                                | Error contents                                 | Input status                                       |
|--------------------------------------|------------------------------------------------|----------------------------------------------------|
| CPU Unit monitoring error (see note) | No response from CPU Unit during fixed period. | Maintains the condition existing before the error. |
| CPU Unit WDT error                   | Error has been generated in CPU Unit.          | Changes to undefined state.                        |

**Note** No error will be detected by the CPU Unit or displayed on the Programming Console, because the CPU Unit is continuing operation.

**ERH Indicator: Lit, RUN Indicator: Not Lit**



The unit number for the Analog Input Unit has not been set correctly.

| Error                             | Error contents                                                                                                          | Input status                                     |
|-----------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
| Duplicate Unit Number (See note.) | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | Conversion does not start and data becomes 0000. |
| Special I/O Unit Setting Error    | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                                                  |

**Note** A single CS1W-AD161 is allocated CIO Area and DM Area words for two Special I/O Units. Be sure to set a unit number so that the CS1W-AD161 is not allocated words in the CIO Area and DM Area that are already allocated to other Special I/O Units. Unit numbers for CS1W-AD161 can be set from 0 to 94.

## 2-8-4 Restarting Special I/O Units

To restart the Analog Input Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

### Special I/O Unit Restart Bits

| Bits   | Functions                        |                                                                                |
|--------|----------------------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit              | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit              |                                                                                |
| to     | to                               |                                                                                |
| A50215 | Unit #15 Restart Bit             |                                                                                |
| A50300 | Unit #16 Restart Bit             |                                                                                |
| to     | to                               |                                                                                |
| A50715 | Unit #95 Restart Bit (See note.) |                                                                                |

The conversion data becomes 0000 during restart.

If the error is not cleared even after turning the Special I/O Unit Restart Bit ON and then OFF again, then replace the Unit.

**Note** The highest unit number that can be set for a CS1W-AD161 is unit number 94.

## 2-8-5 Troubleshooting

The following tables explain the probable causes of troubles that may occur, and the countermeasures for dealing with them.

**Conversion Data Does Not Change**

| Probable cause                                                                           | Countermeasure                                                            | Page |
|------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|------|
| The input is not set for being used.                                                     | Set the input to be used.                                                 | 56   |
| The peak value hold function is in operation.                                            | Turn OFF the peak value hold function if it is not required.              | 62   |
| The input device is not working, the input wiring is wrong, or there is a disconnection. | Using a tester, check to see if the input voltage or current is changing. | ---  |
|                                                                                          | Use Unit's alarm flags to check for a disconnection.                      | 74   |

**Value Does Not Change as Intended**

| Probable cause                                                                                                                | Countermeasure                                                                                    | Page |
|-------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|------|
| The input device's signal range does not match the input signal range for the relevant input number at the Analog Input Unit. | Check the specifications of the input device, and match the settings for the input signal ranges. | 18   |
| The offset and gain are not adjusted.                                                                                         | Adjust the offset and gain.                                                                       | 64   |
| When using the 4 mA to 20 mA range, the voltage/current switch is not turned ON.                                              | Turn ON the voltage/current switch.                                                               | 35   |

**Conversion Values are Inconsistent**

| Probable cause                                          | Countermeasure                                                                                                        | Page |
|---------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|------|
| The input signals are being affected by external noise. | Change the shielded cable connection to the Unit's COM terminal.                                                      | 39   |
|                                                         | Insert a 0.01- $\mu$ F to 0.1- $\mu$ F ceramic capacitor or film capacitor between the input's (+) and (–) terminals. | ---  |
|                                                         | Try increasing the number of mean value processing buffers.                                                           | 59   |



# SECTION 3

## CJ-series Analog Input Units (CJ1W-AD041-V1/081-V1)

This section explains how to use the CJ1W-AD041-V1/081-V1 Analog Input Unit.

|       |                                                       |     |
|-------|-------------------------------------------------------|-----|
| 3-1   | Specifications .....                                  | 82  |
| 3-1-1 | Specifications .....                                  | 82  |
| 3-1-2 | Input Function Block Diagram .....                    | 84  |
| 3-1-3 | Input Specifications .....                            | 84  |
| 3-2   | Operating Procedure .....                             | 87  |
| 3-2-1 | Procedure Examples .....                              | 88  |
| 3-3   | Components and Switch Settings .....                  | 93  |
| 3-3-1 | Indicators .....                                      | 94  |
| 3-3-2 | Unit Number Switches .....                            | 94  |
| 3-3-3 | Operation Mode Switch .....                           | 95  |
| 3-3-4 | Voltage/Current Switch .....                          | 96  |
| 3-4   | Wiring .....                                          | 97  |
| 3-4-1 | Terminal Arrangement .....                            | 97  |
| 3-4-2 | Internal Circuitry .....                              | 98  |
| 3-4-3 | Voltage Input Disconnection .....                     | 99  |
| 3-4-4 | Input Wiring Example .....                            | 100 |
| 3-4-5 | Input Wiring Considerations .....                     | 100 |
| 3-5   | Exchanging Data with the CPU Unit .....               | 101 |
| 3-5-1 | Outline of Data Exchange .....                        | 101 |
| 3-5-2 | Unit Number Setting .....                             | 102 |
| 3-5-3 | Special I/O Unit Restart Bits .....                   | 102 |
| 3-5-4 | Fixed Data Allocations .....                          | 103 |
| 3-5-5 | I/O Refresh Data Allocations .....                    | 105 |
| 3-6   | Analog Input Functions and Operating Procedures ..... | 108 |
| 3-6-1 | Input Settings and Conversion Values .....            | 108 |
| 3-6-2 | Conversion Time/Resolution Setting .....              | 110 |
| 3-6-3 | Mean Value Processing .....                           | 111 |
| 3-6-4 | Peak Value Hold Function .....                        | 114 |
| 3-6-5 | Input Disconnection Detection Function .....          | 115 |
| 3-7   | Adjusting Offset and Gain .....                       | 116 |
| 3-7-1 | Adjustment Mode Operational Flow .....                | 116 |
| 3-7-2 | Input Offset and Gain Adjustment Procedures .....     | 118 |
| 3-8   | Handling Errors and Alarms .....                      | 124 |
| 3-8-1 | Indicators and Error Flowchart .....                  | 124 |
| 3-8-2 | Alarms Occurring at the Analog Input Unit .....       | 126 |
| 3-8-3 | Errors in the CPU Unit .....                          | 128 |
| 3-8-4 | Restarting Special I/O Units .....                    | 129 |
| 3-8-5 | Troubleshooting .....                                 | 129 |

## 3-1 Specifications

### 3-1-1 Specifications

| Item                                       |                                                 | CJ1W-AD041-V1                                                                                                                                                    | CJ1W-AD081-V1                                                            |
|--------------------------------------------|-------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------|
| Unit type                                  |                                                 | CJ-series Special I/O Unit                                                                                                                                       |                                                                          |
| Isolation (See note 1.)                    |                                                 | Between inputs and PLC signals: Photocoupler<br>(No isolation between input signals.)                                                                            |                                                                          |
| External terminals                         |                                                 | 18-point detachable terminal block (M3 screws)                                                                                                                   |                                                                          |
| Affect on CPU Unit cycle time              |                                                 | 0.2 ms                                                                                                                                                           |                                                                          |
| Current consumption                        |                                                 | 420 mA max. at 5 VDC                                                                                                                                             |                                                                          |
| Dimensions (mm) (See note 2.)              |                                                 | 31 × 90 × 65 (W × H × D)                                                                                                                                         |                                                                          |
| Weight                                     |                                                 | 140 g max.                                                                                                                                                       |                                                                          |
| General specifications                     |                                                 | Conforms to general specifications for SYSMAC CJ Series.                                                                                                         |                                                                          |
| Mounting position                          |                                                 | CJ-series CPU Rack or CJ-series Expansion Rack                                                                                                                   |                                                                          |
| Maximum number of Units                    |                                                 | Per CPU Rack or Expansion Rack (See note 3.)                                                                                                                     | Power Supply Unit                                                        |
|                                            |                                                 |                                                                                                                                                                  | No. of mountable Units                                                   |
|                                            |                                                 |                                                                                                                                                                  | CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025                                 |
|                                            |                                                 |                                                                                                                                                                  | CPU Rack: 10 Units/Rack<br>Expansion Rack: 10 Units/Rack                 |
|                                            |                                                 |                                                                                                                                                                  | CJ1W-PA202                                                               |
|                                            |                                                 |                                                                                                                                                                  | CPU Rack: 5 Units/Rack<br>Expansion Rack: 6 Units/Rack                   |
|                                            |                                                 |                                                                                                                                                                  | CJ1W-PD022                                                               |
|                                            |                                                 |                                                                                                                                                                  | CPU Rack: 3 Units/Rack<br>Expansion Rack: 4 Units/Rack                   |
| Data exchange with CPU Units (See note 4.) |                                                 | Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959): 10 words per Unit<br>Special I/O Unit Area in DM Area (D20000 to D29599): 100 words per Unit           |                                                                          |
| Inputs specifications                      | Number of analog inputs                         | 4                                                                                                                                                                | 8                                                                        |
|                                            | Input signal range (See note 5.)                | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>−10 to 10 V<br>4 to 20 mA<br>(See note 6.)                                                                                  |                                                                          |
|                                            | Maximum rated input (for 1 point) (See note 7.) | Voltage Input: ±15 V<br>Current Input: ±30 mA                                                                                                                    |                                                                          |
|                                            | Input impedance                                 | Voltage Input: 1 MΩ min.<br>Current Input: 250 Ω (rated value)                                                                                                   |                                                                          |
|                                            | Resolution (See note 8.)                        | 4,000/8,000                                                                                                                                                      | 4,000/8,000                                                              |
|                                            | Converted output data                           | 16-bit binary data                                                                                                                                               |                                                                          |
|                                            | Accuracy (See note 9.)                          | 23±2°C                                                                                                                                                           | Voltage Input: ±0.2% of full scale<br>Current Input: ±0.4% of full scale |
|                                            |                                                 | 0°C to 55°C                                                                                                                                                      | Voltage Input: ±0.4% of full scale<br>Current Input: ±0.6% of full scale |
|                                            | A/D conversion period (See note 10.)            | 1 ms/point or 250 μs/point<br>(See note 8.)                                                                                                                      | 1 ms/point or 250 μs/point<br>(See note 8.)                              |
| Inputs functions                           | Mean value processing                           | Stores the last “n” data conversions in the buffer, and stores the mean value of the conversion values.<br>Number of mean value buffers: n = 2, 4, 8, 16, 32, 64 |                                                                          |
|                                            | Peak value hold                                 | Stores the maximum conversion value while the Peak Value Hold Bit is ON.                                                                                         |                                                                          |
|                                            | Input disconnection detection                   | Detects the disconnection and turns ON the Disconnection Detection Flag.<br>(See note 11.)                                                                       |                                                                          |

- Note** 1. Do not apply a voltage higher than 600 V to the terminal block when performing withstand voltage test on this Unit. Otherwise, internal elements may deteriorate.



2. Refer to *Dimensions* on page 441 for details on the Unit's dimensions.
3. This is the maximum number of Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP). The maximum number of Analog Output Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack.


| Power Supply Unit                        | Rack           | CJ1W-DA021<br>CJ1W-DA041<br>(5 VDC 120 mA)<br>CJ1W-DA08V<br>CJ1W-DA08C<br>(5 VDC 140 mA) | CS1W-AD041-V1<br>CJ1W-AD081-V1<br>(5 VDC 420 mA) | CJ1W-MAD42<br>(5 VDC 580 mA) |
|------------------------------------------|----------------|------------------------------------------------------------------------------------------|--------------------------------------------------|------------------------------|
| CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025 | CPU Rack       | 10                                                                                       | 9                                                | 7                            |
|                                          | Expansion Rack | 10                                                                                       | 10                                               | 8                            |
| CJ1W-PA202                               | CPU Rack       | 5                                                                                        | 4                                                | 3                            |
|                                          | Expansion Rack | 6                                                                                        | 6                                                | 4                            |
| CJ1W-PD022                               | CPU Rack       | 3                                                                                        | 2                                                | 1                            |
|                                          | Expansion Rack | 4                                                                                        | 4                                                | 3                            |

4. Data Transfer with the CPU Unit

|                                                                                                      |                                                  |                                     |                                                                                                                                                           |
|------------------------------------------------------------------------------------------------------|--------------------------------------------------|-------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|
| Special I/O<br>Unit Area in<br>CIO Area<br>(CIO 2000 to<br>CIO 2959,<br>CIO 200000 to<br>CIO 295915) | 10 words<br>per Unit<br>refreshed<br>cyclically  | CPU Unit to<br>Analog Input<br>Unit | Peak value hold function                                                                                                                                  |
|                                                                                                      |                                                  | Analog Input<br>Unit to CPU<br>Unit | Analog input values<br>Line disconnection detection<br>Alarm flags<br>Etc.                                                                                |
| Special I/O<br>Unit Area in<br>DM Area<br>(D20000 to<br>D29599)                                      | 100 words<br>per Unit<br>refreshed<br>cyclically | CPU Unit to<br>Analog Input<br>Unit | Input signal conversion ON/OFF<br>Signal range specifications<br>Averaging specifications<br>Resolution/conversion time setting<br>Operation mode setting |

5. Input signal ranges can be set for each input.
6. Voltage input or current input are chosen by using the voltage/current switch at the back of the terminal block.
7. The Analog Input Unit must be operated according to the input specifications provided here. Operating the Unit outside these specifications will cause the Unit to malfunction.
8. The resolution can be set to 8,000 and the conversion time to 250  $\mu$ s in the DM Area (m+18). There is only one setting for both of these, i.e., they are both enabled or disabled together.
9. The accuracy is given for full scale. For example, an accuracy of  $\pm 0.2\%$  means a maximum error of  $\pm 8$  (BCD).  
The default setting is adjusted for voltage input. To use current input, perform the offset and gain adjustments as required.
10. A/D conversion time is the time it takes for an analog signal to be stored in memory as converted data after it has been input. It takes at least one cycle before the converted data is read by the CPU Unit.
11. Line disconnection detection is supported only when the range is set to 1 to 5 V or 4 to 20 mA. If there is no input signal when the 1 to 5-V or 4 to 20-mA range is set, the Line Disconnection Flag will turn ON.

### 3-1-2 Input Function Block Diagram






**Note** There are only four analog inputs for the CJ1W-AD041-V1.

### 3-1-3 Input Specifications


If signals that are outside the specified range provided below are input, the conversion values (16-bit binary data) used will be either the maximum or minimum value.

**Range: 1 to 5 V (4 to 20 mA)**



**Range: 0 to 10 V****Range: 0 to 5 V**

Range: -10 to 10 V



**Note** The conversion values for a range of -10 to 10 V will be as follows (for a resolution of 4,000):

| 16-bit binary data | BCD   |
|--------------------|-------|
| F768               | -2200 |
| :                  | :     |
| FFFF               | -1    |
| 0000               | 0     |
| 0001               | 1     |
| :                  | :     |
| 0898               | 2200  |

## 3-2 Operating Procedure

Follow the procedure outlined below when using Analog Input Units.

### Installation and Settings

- 1,2,3...**
1. Set the operation mode to normal mode.  
Set the DIP switch on the front panel of the Unit, or set the operation mode in DM word m+18, to normal mode.
  2. Set the voltage/current switch at the back of the terminal block.
  3. Use the unit number switches on the front panel of the Unit to set the unit number.
  4. Wire the Unit.
  5. Turn ON the power to the PLC.
  6. Create the Input tables.
  7. Make the Special Input Unit DM Area settings.
    - Set the input numbers to be used.
    - Set the input signal ranges.
    - Set the number of mean processing samplings.
    - Conversion period and resolution
  8. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the input for the connected devices needs to be calibrated, follow the procedures in *Offset Gain Adjustment* below. Otherwise, skip to *Operation* below.


### Offset and Gain Adjustment

- 1,2,3...**
1. Set the operation mode to adjustment mode.  
Set the DIP switch on the front panel of the Unit, or set the operation mode in DM word m+18, to adjustment mode.
  2. Set the voltage/current switch at the back of the terminal block.
  3. Turn ON the power to the PLC.  
Be sure to set the PLC to PROGRAM mode.
  4. Adjust the offset and gain.
  5. Turn OFF the power to the PLC.
  6. Set the operation mode to normal mode.  
Set the DIP switch on the front panel of the Unit, or set the operation mode in DM word m+18, to normal mode.

### Operation


- 1,2,3...**
1. Turn ON the power to the PLC.
  2. Ladder program
    - Read conversion values or write set values by means of MOV(021) and XFER(070).
    - Specify the peak hold function.
    - Obtain disconnection notifications and error codes.

### 3-2-1 Procedure Examples




#### Setting the Analog Input Unit


- 1,2,3...**
1. Set the operation mode switch on the front panel of the Unit. Refer to 3-3-3 *Operation Mode Switch* for further details. (This setting can also be made in DM word m+18.)



2. Set the voltage/current switch. Refer to 3-3-4 *Voltage/Current Switch* for further details.




- Set the unit number switches. Refer to *3-3-2 Unit Number Switches* for further details.



If the unit number is set to 1, words will be allocated to the Analog Input Unit in Special I/O Unit Area CIO 2010 to CIO 2019 and in the Special I/O Unit Area D20100 to D20199.


- Connect and wire the Analog Input Unit. Refer to *1-2-1 Mounting Procedure*, *3-4 Wiring* or *3-4-4 Input Wiring Example* for further details.



- Turn ON the power to the PLC.


## Creating I/O Tables

After turning ON the power to the PLC, be sure to create the I/O tables.




## Initial Data Settings


- 1,2,3...** 1. Specify the Special I/O Unit DM Area settings. Refer to *3-5-4 Fixed Data Allocations* for further details.



- The following diagram shows the input settings used. Refer to *Allocations in DM Area* on page 103 and *3-6-1 Input Settings and Conversion Values* for more details.




- The following diagram shows the input range settings. Refer to *DM Allocation Contents* on page 103 and *3-6-1 Input Settings and Conversion Values* for more details.







- The following diagram shows the conversion time/resolution setting.  
(Refer to 3-6-2 Conversion Time/Resolution Setting.)



- Cycle the power to the PLC.



## Creating Ladder Programs




The data that is converted from analog to digital and output to CIO words (n + 1) to (n + 7) of the Special I/O Unit Area (CIO 2011 to CIO2017), is stored in the specified addresses D00100 to D00106 as signed binary values 0000 to 0FA0 hex.

- The following table shows the addresses used for analog input.

| Input number | Input signal range | Input conversion value address<br>(n = CIO 2010)<br>(See note 1.) | Conversion data holding address<br>(See note 2.) |
|--------------|--------------------|-------------------------------------------------------------------|--------------------------------------------------|
| 1            | 1 to 5 V           | (n+1) = CIO 2011                                                  | D00100                                           |
| 2            | 1 to 5 V           | (n+2) = CIO 2012                                                  | D00101                                           |
| 3            | 4 to 20 mA         | (n+3) = CIO 2013                                                  | D00102                                           |
| 4            | 4 to 20 mA         | (n+4) = CIO 2014                                                  | D00103                                           |
| 5            | 0 to 10 V          | (n+5) = CIO2015                                                   | D00104                                           |
| 6            | 0 to 10 V          | (n+6) = CIO2016                                                   | D00105                                           |
| 7            | -10 to 10 V        | (n+7) = CIO2017                                                   | D00106                                           |
| 8            | Not used           | ---                                                               | ---                                              |

- Note**
- The addresses are fixed according to the unit number of the Special I/O Unit. Refer to 3-3-2 Unit Number Switches for further details.

2. Set as required.




3. Bits 00 to 07 of word (n + 9) are allocated to the input Disconnection De-  
tection Flags. Refer to *Allocations for Normal Mode* on page 106 for further  
details.


### 3-3 Components and Switch Settings

CJ1W-AD041-V1  
CJ1W-AD081-V1

Front




Side



The terminal block is attached using a connector. It can be removed by lowering the lever at the bottom of the terminal block.

The lever must normally be in the raised position. Confirm this before operation.



### 3-3-1 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| Indicator    | Meaning                | Indicator status | Operating status                                                                        |
|--------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit              | Operating in normal mode.                                                               |
|              |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit          | Operating normally.                                                                     |
| ERH (red)    | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit          | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing         | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit          | Other than the above.                                                                   |

### 3-3-2 Unit Number Switches

The CPU Unit and Analog Input Unit exchange data via the Special I/O Unit Area in the CIO Area and DM Area. The words that are allocated to each Analog Input Unit in the Special I/O Unit Area in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings.



| Switch setting | Unit number | Words allocated in Special/O Unit Area in CIO Area | Words allocated in Special/O Unit Area in DM Area |
|----------------|-------------|----------------------------------------------------|---------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                               | D20000 to D20099                                  |
| 1              | Unit #1     | CIO 2010 to CIO 2019                               | D20100 to D20199                                  |
| 2              | Unit #2     | CIO 2020 to CIO 2029                               | D20200 to D20299                                  |
| 3              | Unit #3     | CIO 2030 to CIO 2039                               | D20300 to D20399                                  |
| 4              | Unit #4     | CIO 2040 to CIO 2049                               | D20400 to D20499                                  |
| 5              | Unit #5     | CIO 2050 to CIO 2059                               | D20500 to D20599                                  |
| 6              | Unit #6     | CIO 2060 to CIO 2069                               | D20600 to D20699                                  |
| 7              | Unit #7     | CIO 2070 to CIO 2079                               | D20700 to D20799                                  |
| 8              | Unit #8     | CIO 2080 to CIO 2089                               | D20800 to D20899                                  |
| 9              | Unit #9     | CIO 2090 to CIO 2099                               | D20900 to D20999                                  |
| 10             | Unit #10    | CIO 2100 to CIO 2109                               | D21000 to D21099                                  |
| to             | to          | to                                                 | to                                                |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9     | D20000 + (n × 100) to D20000 + (n × 100) + 99     |
| to             | to          | to                                                 | to                                                |
| 95             | Unit #95    | CIO 2950 to CIO 2959                               | D29500 to D29599                                  |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 3-3-3 Operation Mode Switch

The operation mode switch on the front panel of the Unit is used to set the operation mode to either normal mode or adjustment mode (for adjusting off-set and gain).



| Pin number |     | Mode            |
|------------|-----|-----------------|
| 1          | 2   |                 |
| OFF        | OFF | Normal mode     |
| ON         | OFF | Adjustment mode |

**Caution** Do not set the pins to any combination other than those shown in the above table. Be sure to set pin 2 to OFF.

**Caution** Be sure to turn OFF the power to the PLC before installing or removing the Unit.

**Note** The operation mode can also be set using bits 00 to 07 of DM word m+18, in addition to the hardware operation mode switch. The contents of DM word m+18 are shown below.

| Bit      | 15                                   | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                                               | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|----------|--------------------------------------|----|----|----|----|----|----|----|------------------------------------------------------------------|----|----|----|----|----|----|----|
| D (m+18) | Conversion period/resolution setting |    |    |    |    |    |    |    | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |    |    |    |    |    |    |    |


$$m = D20000 + (\text{unit number} \times 100)$$

#### Relationship between Operation Mode Setting and Hardware Operation Mode Switch

| Hardware operation mode switch | Setting of bits 00 to 07 of m+18 | Operation mode when power is turned ON or Unit is restarted |
|--------------------------------|----------------------------------|-------------------------------------------------------------|
| Normal mode                    | Normal mode                      | Normal mode                                                 |
| Normal mode                    | Adjustment mode                  | Adjustment mode                                             |
| Adjustment mode                | Normal mode                      | Adjustment mode                                             |
| Normal mode                    | Adjustment mode                  | Adjustment mode                                             |

### 3-3-4 Voltage/Current Switch

The analog conversion input can be switched from voltage input to current input by changing the pin settings on the voltage/current switch located on the back of the terminal block.



**Note** There are only four inputs for the CJ1W-AD041-V1.

**Caution** Be sure to turn OFF the power to the PLC before mounting or removing the terminal block.

## 3-4 Wiring

### 3-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

#### CJ1W-AD041-V1

|             |    |    |             |
|-------------|----|----|-------------|
| Input 2 (+) | B1 | A1 | Input 1 (+) |
| Input 2 (–) | B2 | A2 | Input 1 (–) |
| Input 4 (+) | B3 | A3 | Input 3 (+) |
| Input 4 (–) | B4 | A4 | Input 3 (–) |
| AG          | B5 | A5 | AG          |
| N.C.        | B6 | A6 | N.C.        |
| N.C.        | B7 | A7 | N.C.        |
| N.C.        | B8 | A8 | N.C.        |
| N.C.        | B9 | A9 | N.C.        |

#### CJ1W-AD081-V1

|             |    |    |             |
|-------------|----|----|-------------|
| Input 2 (+) | B1 | A1 | Input 1 (+) |
| Input 2 (–) | B2 | A2 | Input 1 (–) |
| Input 4 (+) | B3 | A3 | Input 3 (+) |
| Input 4 (–) | B4 | A4 | Input 3 (–) |
| AG          | B5 | A5 | AG          |
| Input 6 (+) | B6 | A6 | Input 5 (+) |
| Input 6 (–) | B7 | A7 | Input 5 (–) |
| Input 8 (+) | B8 | A8 | Input 7 (+) |
| Input 8 (–) | B9 | A9 | Input 7 (–) |


- Note**
1. The number of analog inputs that can be used is set in the DM Area.
  2. The input signal ranges for individual inputs are set in the DM Area. The input signal range can be set separately for each input.
  3. The AG terminals are connected to the 0-V analog circuit in the Unit. Connecting the input line shield can improve noise resistance.

 **Caution** Do not make any connections to the N.C. terminals.


### 3-4-2 Internal Circuitry

The following diagrams show the internal circuitry of the analog input section.

#### Input Circuitry




#### Internal Configuration





### 3-4-3 Voltage Input Disconnection




**Note** If the connected device #2 in the above example outputs 5 V and the power supply is shared by 2 channels as shown in the above diagram, approximately one third of the voltage, or 1.6 V, will be input at input 1.

When voltage inputs are used and a disconnection occurs, separate the power supply at the side of the connected devices or use an insulating device (isolator) for each input to avoid the following problems.

When the power supply at the connected devices is shared and section A or B is disconnected, power will flow in the direction of the broken line and the output voltage of the other connected devices will be reduced to between a third to a half of the voltage. If 1 to 5 V is used and the reduced voltage output, disconnection may not be detectable. If section C is disconnected, the power at the (–) input terminal will be shared and disconnection will not be detectable.


For current inputs, sharing the power supply between the connected devices will not cause any problems.

### 3-4-4 Input Wiring Example



**Note** There are only four inputs for the CJ1W-AD041-V1. Inputs 5 to 8 are not used.

**Note** Crimp-type terminals must be used for terminal connections, and the screws must be tightened securely. Use M3 screws and tighten them to a torque of 0.5 N·m.



- Note**
1. When using current inputs, turn ON the voltage/current switches. Refer to *3-3-4 Voltage/Current Switch* for further details.
  2. For inputs that are not used, either set to "0: Not used" in the input number settings (refer to *3-6-1 Input Settings and Conversion Values*) or short-circuit the voltage input terminals (V+) and (V-). If this is not performed and the inputs are set for the 1 to 5-V or 4 to 20-mA range, the Line Disconnection Flag will turn ON.
  3. When connecting the shield of the analog input cables\* to the Unit's AG terminals, as shown in the above diagram, use a wire that is 30 cm max. in length if possible.

**Caution** Do not connect anything to N.C. terminals shown in the wiring diagram on page 97.

Connect the analog input line shield to the AG terminal on the Analog Input Unit to improve noise resistance.

### 3-4-5 Input Wiring Considerations

When wiring inputs, apply the following points to avoid noise interference and optimize Analog Input Unit performance.

- Use two-core shielded twisted-pair cables for input connections.

- Route input cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable, high voltage cable, or a non-PLC load cable.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.

## 3-5 Exchanging Data with the CPU Unit

### 3-5-1 Outline of Data Exchange

Data is exchanged between the CPU Unit and the CJ1W-AD041-V1/081-V1 Analog Input Unit via the Special I/O Unit Area in the CIO Area (for data used to operate the Unit) and the Special I/O Unit Area in the DM Area (for data used for initial settings).


#### I/O Refresh Data

Analog input conversion values, which are used as data for Unit operation, are allocated in the Special I/O Unit Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.


#### Fixed Data

The Unit's fixed data, such as the analog input signal ranges and the number of operational mean value buffers is allocated in the Special I/O Unit Area in the DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.

The conversion time and resolution can be set, along with the operation mode.



### 3-5-2 Unit Number Setting



The words in the Special I/O Unit Areas in the CIO Area and DM Area that are allocated to each Analog Input Unit are determined by the unit number switches on the front panel of the Unit.

| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | Unit #1     | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | Unit #2     | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | Unit #3     | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | Unit #4     | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | Unit #5     | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | Unit #6     | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | Unit #7     | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | Unit #8     | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | Unit #9     | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | Unit #10    | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | Unit #95    | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 3-5-3 Special I/O Unit Restart Bits

To restart the Unit after changing the contents of the DM Area or correcting an error, cycle the power supply to the PLC or turn ON the Special I/O Unit Restart Bit.

| Special I/O Unit Area word address | Function                |                                                      |
|------------------------------------|-------------------------|------------------------------------------------------|
| A50200                             | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON and then OFF again. |
| A50201                             | Unit No. 1 Restart Bit  |                                                      |
| to                                 | to                      |                                                      |
| A50215                             | Unit No. 15 Restart Bit |                                                      |
| A50300                             | Unit No. 16 Restart Bit |                                                      |
| to                                 | to                      |                                                      |
| A50715                             | Unit No. 95 Restart Bit |                                                      |


**Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

### 3-5-4 Fixed Data Allocations

#### Allocations in DM Area

The initial settings of the Analog Input Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the inputs used and the analog input signal range must be set in this area.

The conversion time and resolution can be set, along with the operation mode, in DM word  $m+18$ .



- Note**
1. The words in the Special I/O Unit DM Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. Refer to *3-5-2 Unit Number Setting* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.
  3. Only D(m) to D(m+5) are supported by the CJ1W-AD041-V1.

**Allocations in DM Area**

The following table shows the allocation of DM Area words and bits for both normal and adjustment mode.

**CJ1W-AD041-V1**

| DM Area word      | Bits                                                                                                                                               |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
|-------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|----|----|----|----|---|---|------------------------------------------------------------------|---|---------|---|-------------------|---------|---------|---------|
|                   | 15                                                                                                                                                 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                                                | 6 | 5       | 4 | 3                 | 2       | 1       | 0       |
| D (m)             | Not used. (Settings are ignored.)                                                                                                                  |    |    |    |    |    |   |   | Not used.                                                        |   |         |   | Input use setting |         |         |         |
|                   |                                                                                                                                                    |    |    |    |    |    |   |   |                                                                  |   |         |   | Input 4           | Input 3 | Input 2 | Input 1 |
| D (m+1)           | Not used. (Settings are ignored.)                                                                                                                  |    |    |    |    |    |   |   | Input signal range setting                                       |   |         |   |                   |         |         |         |
|                   |                                                                                                                                                    |    |    |    |    |    |   |   | Input 4                                                          |   | Input 3 |   | Input 2           |         | Input 1 |         |
| D (m+2)           | Input 1: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+3)           | Input 2: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+4)           | Input 3: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+5)           | Input 4: Mean value processing setting                                                                                                             |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+6) to (m+17) | Not used. (Settings are ignored.)                                                                                                                  |    |    |    |    |    |   |   |                                                                  |   |         |   |                   |         |         |         |
| D (m+18)          | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 μs and resolution of 8,000 |    |    |    |    |    |   |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |   |         |   |                   |         |         |         |

**Note** For the DM word addresses, m = D20000 + (unit number  $\times$  100).

**CJ1W-AD081-V1**

| DM Area word       | Bits                                                                                                                                               |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
|--------------------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|---------|----|---------|----|---------|---|------------------------------------------------------------------|---------|---------|---------|---------|---------|---------|---------|
|                    | 15                                                                                                                                                 | 14 | 13      | 12 | 11      | 10 | 9       | 8 | 7                                                                | 6       | 5       | 4       | 3       | 2       | 1       | 0       |
| D (m)              | Not used. (Settings are ignored.)                                                                                                                  |    |         |    |         |    |         |   | Input use setting                                                |         |         |         |         |         |         |         |
|                    |                                                                                                                                                    |    |         |    |         |    |         |   | Input 8                                                          | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |
| D (m+1)            | Input signal range setting                                                                                                                         |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
|                    | Input 8                                                                                                                                            |    | Input 7 |    | Input 6 |    | Input 5 |   | Input 4                                                          |         | Input 3 |         | Input 2 |         | Input 1 |         |
| D (m+2)            | Input 1: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+3)            | Input 2: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+4)            | Input 3: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+5)            | Input 4: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+6)            | Input 5: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+7)            | Input 6: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+8)            | Input 7: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+9)            | Input 8: Mean value processing setting                                                                                                             |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+10) to (m+17) | Not used. (Settings are ignored.)                                                                                                                  |    |         |    |         |    |         |   |                                                                  |         |         |         |         |         |         |         |
| D (m+18)           | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 μs and resolution of 8,000 |    |         |    |         |    |         |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |         |         |         |         |         |         |         |

**Note** For the DM word addresses, m = D20000 + (unit number  $\times$  100).


## Set Values and Stored Values

| Item  |                               | Contents                                                                                                                                                                                                                                                                                                                                  | Page |
|-------|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Input | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                                  | 108  |
|       | Input signal range            | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V/4 to 20 mA (See note 1.)<br>11: 0 to 5 V                                                                                                                                                                                                                                                 | 109  |
|       | Mean value processing setting | 0000: Mean value processing with 2 buffers (See note 3.)<br>0001: Mean value processing not used<br>0002: Mean value processing with 4 buffers<br>0003: Mean value processing with 8 buffers<br>0004: Mean value processing with 16 buffers<br>0005: Mean value processing with 32 buffers<br>0006: Mean value processing with 64 buffers | 111  |

- Note**
1. The input signal range of “1 to 5 V” and “4 to 20 mA” is switched using the pins of the voltage/current switch. Refer to 3-3-4 *Voltage/Current Switch* for details.
  2. The default of mean value processing setting is set to “Mean value processing with 2 buffers.” Refer to 3-6-3 *Mean Value Processing*.

## 3-5-5 I/O Refresh Data Allocations

I/O refresh data for the Analog Input Unit is exchanged according to the allocations in the Special I/O Unit Area.



- Note**
1. The words in the Special I/O Unit Area in the CIO Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. Refer to 3-5-2 *Unit Number Setting* for details on the method used to set the unit number switches.

2. If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### Allocations for Normal Mode

For normal mode, set the operation mode switch on the front panel of the Unit as shown in the following diagram, or set bits 00 to 07 in DM word m+18.



Switch color: Brown



Switch color: Black

**Note** The pins are ON when set to the right and OFF when set to the left.

The allocation of words and bits in the CIO Area is shown in the following table.

#### CJ1W-AD041-V1

| I/O                     | Word  | Bits                     |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|-------------------------|-------|--------------------------|----|----|----|-----------------|----|---|---------|-----------------|---|---|---|------------------------------|---------|---------|---------|
|                         |       | 15                       | 14 | 13 | 12 | 11              | 10 | 9 | 8       | 7               | 6 | 5 | 4 | 3                            | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n     | Not used.                |    |    |    |                 |    |   |         |                 |   |   |   | Peak value hold              |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |         |                 |   |   |   | Input 4                      | Input 3 | Input 2 | Input 1 |
| Input<br>(Unit to CPU)  | n + 1 | Input 1 conversion value |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         |       | 16 <sup>3</sup>          |    |    |    | 16 <sup>2</sup> |    |   |         | 16 <sup>1</sup> |   |   |   | 16 <sup>0</sup>              |         |         |         |
|                         | n + 2 | Input 2 conversion value |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 3 | Input 3 conversion value |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 4 | Input 4 conversion value |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 5 | Not used.                |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 6 | Not used.                |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 7 | Not used.                |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 8 | Not used.                |    |    |    |                 |    |   |         |                 |   |   |   |                              |         |         |         |
|                         | n + 9 | Alarm Flags              |    |    |    |                 |    |   |         | Not used.       |   |   |   | Disconnection detec-<br>tion |         |         |         |
|                         |       |                          |    |    |    |                 |    |   | Input 4 |                 |   |   |   | Input 3                      | Input 2 | Input 1 |         |

**Note** For the CIO word addresses, n = CIO 2000 + (unit number × 10).

#### CJ1W-AD081-V1

| I/O                     | Word  | Bits                     |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|-------------------------|-------|--------------------------|----|----|----|-----------------|----|---|---------|-------------------------|---------|---------|---------|-----------------|---------|---------|---------|
|                         |       | 15                       | 14 | 13 | 12 | 11              | 10 | 9 | 8       | 7                       | 6       | 5       | 4       | 3               | 2       | 1       | 0       |
| Output<br>(CPU to Unit) | n     | Not used.                |    |    |    |                 |    |   |         | Peak value hold         |         |         |         |                 |         |         |         |
|                         |       |                          |    |    |    |                 |    |   |         | Input 8                 | Input 7 | Input 6 | Input 5 | Input 4         | Input 3 | Input 2 | Input 1 |
| Input<br>(Unit to CPU)  | n + 1 | Input 1 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         |       | 16 <sup>3</sup>          |    |    |    | 16 <sup>2</sup> |    |   |         | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup> |         |         |         |
|                         | n + 2 | Input 2 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 3 | Input 3 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 4 | Input 4 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 5 | Input 5 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 6 | Input 6 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 7 | Input 7 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 8 | Input 8 conversion value |    |    |    |                 |    |   |         |                         |         |         |         |                 |         |         |         |
|                         | n + 9 | Alarm Flags              |    |    |    |                 |    |   |         | Disconnection detection |         |         |         |                 |         |         |         |
|                         |       |                          |    |    |    |                 |    |   | Input 8 | Input 7                 | Input 6 | Input 5 | Input 4 | Input 3         | Input 2 | Input 1 |         |

**Note** For the CIO word addresses, n = CIO 2000 + (unit number × 10).



## Set Values and Stored Values

| Item                                   | Contents                                                                                                                                                                                                                                               | Page               |
|----------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------|
| Peak value hold function               | 0: Not used.<br>1: Peak value hold used.                                                                                                                                                                                                               | 114                |
| Conversion value<br>Calculation result | 16-bit binary data                                                                                                                                                                                                                                     | 109                |
| Disconnection detection                | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                | 115                |
| Alarm Flags                            | Bits 00 to 03: Disconnection detection<br>Bits 04 to 07: Disconnection detection<br>(not used for AD041-V1)<br>Bit 08-10: Not used<br>Bit 11: Mean value processing setting error<br>Bit 15: Operating in adjustment mode<br>(always 0 in normal mode) | 106,126<br><br>107 |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

## Allocation for Adjustment Mode

For adjustment mode, set the operation mode switch on the front panel of the Unit as shown in the following diagram, or set bits 00 to 07 in DM word  $m+18$  to C1. When the Unit is set for adjustment mode, the ADJ indicator on the front panel of the Unit will flash.



Switch color: Brown



Switch color: Black

**Note** The pins are ON when set to the right and OFF when set to the left.

The allocation of CIO words and bits is shown in the following table.

| I/O                     | Word      | Bits                                   |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|-------------------------|-----------|----------------------------------------|----|----|----|----|-----------------|---|---|---------------------------------------|-----------------|---------|---------|-------------------------------|-----------------|---------|---------|
|                         |           | 15                                     | 14 | 13 | 12 | 11 | 10              | 9 | 8 | 7                                     | 6               | 5       | 4       | 3                             | 2               | 1       | 0       |
| Output<br>(CPU to Unit) | n         | Not used.                              |    |    |    |    |                 |   |   | Inputs to be adjusted                 |                 |         |         |                               |                 |         |         |
|                         |           |                                        |    |    |    |    |                 |   |   | 2 (fixed)                             |                 |         |         | 1 to 8 (1 to 4) (See note 1.) |                 |         |         |
|                         | n + 1     | Not used.                              |    |    |    |    |                 |   |   | Not used.                             |                 | Clr     | Set     | Up                            | Down            | Gain    | Off-set |
|                         | n + 2     | Not used.                              |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|                         | n + 3     | Not used.                              |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|                         | n + 4     | Not used.                              |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|                         | n + 5     | Not used.                              |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|                         | n + 6     | Not used.                              |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
| n + 7                   | Not used. |                                        |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
| Input<br>(Unit to CPU)  | n + 8     | Conversion value at time of adjustment |    |    |    |    |                 |   |   |                                       |                 |         |         |                               |                 |         |         |
|                         |           | 16 <sup>3</sup>                        |    |    |    |    | 16 <sup>2</sup> |   |   |                                       | 16 <sup>1</sup> |         |         |                               | 16 <sup>0</sup> |         |         |
|                         | n + 9     | Alarm Flags                            |    |    |    |    |                 |   |   | Disconnection detection (See note 2.) |                 |         |         | Not used.                     |                 |         |         |
|                         |           |                                        |    |    |    |    |                 |   |   | Input 8                               | Input 7         | Input 6 | Input 5 | Input 4                       | Input 3         | Input 2 | Input 1 |

**Note** 1. Use settings 1 to 4 for the CJ1W-AD041-V1.

2. With the CJ1W-AD041-V1, bits 04 to 07 in word n+9 (disconnection detection) are not used.

### Set Values and Stored Values

Refer to 3-7-1 *Adjustment Mode Operational Flow* for further details.

| Item                            | Contents                                                                                                                                                                                                                                                  |
|---------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input to be adjusted            | Sets input to be adjusted.<br>Leftmost digit: 2 (fixed)<br>Rightmost digit: 1 to 8 (1 to 4 for CJ1W-AD041-V1)                                                                                                                                             |
| Offset (Offset Bit)             | When ON, adjusts offset error.                                                                                                                                                                                                                            |
| Gain (Gain Bit)                 | When ON, adjusts gain error.                                                                                                                                                                                                                              |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                                                                                                                                                                 |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                                                                                                                                                                 |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                                                                                                                                                                 |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                                                                                                                                                                        |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                                                                                                                                                                  |
| Disconnection detection         | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                   |
| Alarm Flags                     | Bit 12: Input value is outside adjustment limits (in adjustment mode)<br>Bit 13: Input number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode (always 1 in adjustment mode) |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).


| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

## 3-6 Analog Input Functions and Operating Procedures

### 3-6-1 Input Settings and Conversion Values

#### Input Numbers

The Analog Input Unit converts analog inputs specified by input numbers 1 to 8 (1 to 4 for CJ1W-AD041-V1) only. To specify the analog inputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



**Note** There are only four inputs for the CJ1W-AD041-V1.

The analog input sampling interval can be shortened by setting any unused input numbers to 0.

Sampling interval = (1 ms) x (Number of inputs used) (See note.)


**Note** Use 250  $\mu$ s instead of 1 ms is set to a conversion time of 250  $\mu$ s and resolution of 8,000.

The conversion values in words for inputs that have been set to “Not used” will always be “0000.”

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

### Input Signal Range

Any of four types of input signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, and 4 to 20 mA) can be selected for each of the inputs. To specify the input signal range for each input, set from a Programming Device the D(m+1) bits in the DM Area as shown in the following diagram.



**Note** There are only four inputs for the CJ1W-AD041-V1.

- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$
  2. The input signal range of “1 to 5 V” or “4 to 20 mA” is switched using the voltage/current switch.
  3. When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

### Reading Conversion Values

Analog input conversion values are stored for each input number, in CIO words  $n+1$  to  $n+8$ . With the CJ1W-AD041-V1, the values are stored in CIO words  $n+1$  to  $n+4$ .


| Word  | Function                 | Stored value       |
|-------|--------------------------|--------------------|
| $n+1$ | Input 1 conversion value | 16-bit binary data |
| $n+2$ | Input 2 conversion value |                    |
| $n+3$ | Input 3 conversion value |                    |
| $n+4$ | Input 4 conversion value |                    |
| $n+5$ | Input 5 conversion value |                    |
| $n+6$ | Input 6 conversion value |                    |
| $n+7$ | Input 7 conversion value |                    |
| $n+8$ | Input 8 conversion value |                    |

**Note** For the CIO word addresses,  $n = CIO 2000 + (\text{unit number} \times 10)$ .


Use MOV(021) or XFER(070) to read conversion values in the user program.

**Example 1**

In this example, the conversion data from only one input is read. (The unit number is 0.)

**Example 2**

In this example, the conversion data from multiple inputs is read. (The unit number is 0.)




For details regarding conversion value scaling, refer to *Scaling* on page 448.

### 3-6-2 Conversion Time/Resolution Setting

Bits 08 to 15 in DM word  $m+18$  can be used to set the conversion time and resolution for the CJ1W-AD041-V1 and CJ1W-AD081-V1 to increase speed and accuracy.


This setting applies to analog inputs 1 to 8 (1 to 4 for the CJ1W-AD041-V1), i.e., there are not individual settings for each input.



**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

### 3-6-3 Mean Value Processing

The Analog Input Unit can compute the mean value of the conversion values of analog inputs that have been previously sampled. Mean value processing involves an operational mean value in the history buffers, so it has no effect on the data refresh cycle. (The number of history buffers that can be set to use mean value processing is 2, 4, 8, 16, 32, or 64.)



When “n” number of history buffers are being used, the first conversion data will be stored for all “n” number of history buffers immediately data conversion has begun or after a disconnection is restored.

When mean value processing is used together with the peak value hold function, the mean value will be held.

To specify whether or not mean value processing is to be used, and to specify the number of history buffers for mean data processing, use a Programming Device to make the settings in D (m+2) to D (m+9) as shown in the following table. (With the CJ1W-AD041-V1, make the settings in D (m+2) to D (m+5).)


| DM Area word | Function                      | Set value                                   |
|--------------|-------------------------------|---------------------------------------------|
| D (m+2)      | Input 1 mean value processing | 0000: Mean value processing with 2 buffers  |
| D (m+3)      | Input 2 mean value processing | 0001: No mean value processing              |
| D (m+4)      | Input 3 mean value processing | 0002: Mean value processing with 4 buffers  |
| D (m+5)      | Input 4 mean value processing | 0003: Mean value processing with 8 buffers  |
| D (m+6)      | Input 5 mean value processing | 0004: Mean value processing with 16 buffers |
| D (m+7)      | Input 6 mean value processing | 0005: Mean value processing with 32 buffers |
| D (m+8)      | Input 7 mean value processing | 0006: Mean value processing with 64 buffers |
| D (m+9)      | Input 8 mean value processing |                                             |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.


The history buffer moving average is calculated as shown below. (In this example, there are four buffers.)

- 1,2,3...** 1. With the first cycle, data 1 is stored in all the history buffers.




$$\text{Mean value} = (\text{Data 1} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

2. With the second cycle, data 2 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 2} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

3. With the third cycle, data 3 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 3} + \text{Data 2} + \text{Data 1} + \text{Data 1}) \div 4$$

4. With the fourth cycle, data 4 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 4} + \text{Data 3} + \text{Data 2} + \text{Data 1}) \div 4$$

5. With the fifth cycle, data 5 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 5} + \text{Data 4} + \text{Data 3} + \text{Data 2}) \div 4$$

When a disconnection is restored, the mean value processing function begins again from step 1.

- Note** 1. The default setting for mean value processing in the Analog Input Unit is mean value processing with 2 buffers. The response time for the default

setting is different from when there is no mean processing, as shown in the following diagram.

- Specify “no mean value processing” to follow conversion of a rapid change in input signals.
- If the averaging function is used, the delay in the conversion data in comparison to changes in the input signals will be as shown below.



For V = 20 V (–10 to 10 V)

**1-ms Conversion Time/4,000 Resolution**

**Using One Word**

$$t = n + (2 \text{ to } 3)$$

**Using m Words ( $1 \leq m \leq 8$ )**

No averaging ( $n = 1$ ) or two averaging buffers ( $n = 2$ ):

$$t = n \times (m + 2)$$

n averaging buffers ( $4 \leq n \leq 64$ ):

$$t = (n - 2) \times m + 10.5$$

**250-μs Conversion Time/8,000 Resolution (For version-1 Unit)**

**Using One Word**

$$t = n + (2 \text{ to } 3) \times 1/4$$

**Using m Words ( $1 \leq m \leq 8$ )**

No averaging ( $n = 1$ ) or two averaging buffers ( $n = 2$ ):

$$t = n \times (m + 2) \times 1/4$$

n averaging buffers ( $4 \leq n \leq 64$ ):

$$t = \{(n - 2) \times m + 10.5\} \times 1/4$$

**Response Time at 1-ms  
Conversion Time/4,000  
Resolution**

Unit: ms

| m | n     |       |       |      |      |    |    |
|---|-------|-------|-------|------|------|----|----|
|   | 64    | 32    | 16    | 8    | 4    | 2  | 1  |
| 8 | 506.5 | 250.5 | 122.5 | 58.5 | 26.5 | 20 | 10 |
| 7 | 444.5 | 220.5 | 108.5 | 52.5 | 24.5 | 18 | 9  |
| 6 | 382.5 | 190.5 | 94.5  | 46.5 | 22.5 | 16 | 8  |
| 5 | 320.5 | 160.5 | 80.5  | 40.5 | 20.5 | 14 | 7  |
| 4 | 258.5 | 130.5 | 66.5  | 34.5 | 18.5 | 12 | 6  |
| 3 | 196.5 | 100.5 | 52.5  | 28.5 | 16.5 | 10 | 5  |
| 2 | 134.5 | 70.5  | 38.5  | 22.5 | 14.5 | 8  | 4  |
| 1 | 67    | 35    | 19    | 11   | 7    | 5  | 3  |

**Response Time at 250-μs  
Conversion Time/8,000  
Resolution**

Unit: ms

| m | n       |        |        |        |       |      |      |
|---|---------|--------|--------|--------|-------|------|------|
|   | 64      | 32     | 16     | 8      | 4     | 2    | 1    |
| 8 | 126.625 | 62.625 | 30.625 | 14.625 | 6.625 | 5    | 2.5  |
| 7 | 111.125 | 55.125 | 27.125 | 13.125 | 6.125 | 4.5  | 2.25 |
| 6 | 95.625  | 47.625 | 23.625 | 11.625 | 5.625 | 4    | 2    |
| 5 | 80.125  | 40.125 | 20.125 | 10.125 | 5.125 | 3.5  | 1.75 |
| 4 | 64.625  | 32.625 | 16.625 | 8.625  | 4.625 | 3    | 1.5  |
| 3 | 49.125  | 25.125 | 13.125 | 7.125  | 4.125 | 2.5  | 1.25 |
| 2 | 33.625  | 17.625 | 9.625  | 5.625  | 3.625 | 2    | 1    |
| 1 | 16.75   | 8.75   | 4.75   | 2.75   | 1.75  | 1.25 | 0.75 |

**Symbols**

m: Number of input words used in DM Area

n: Average number of buffers set for the input number for which to find the response time


**Calculation Example**

The following example calculations are for a resolution of 8,000 with an application using inputs 1 and 8, 64 averaging buffers set for input 1, and no averaging set for input 8.


- Response time for input 1:  $t = \{(64 - 2) \times 2 + 10.5\} \times 1/4 = 34 \text{ (ms)}$
- Response time for input 8:  $t = 1 \times (2 + 2) \times 1/4 = 1 \text{ (ms)}$

**3-6-4 Peak Value Hold Function**

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). This function can be used with analog input. The following diagram shows how digital conversion values are affected when the peak value hold function is used.



The peak value hold function can be set separately for each input number by turning ON the respective bits (00 to 07) in CIO word n.



The peak value hold function will be in effect for the above input numbers while their respective bits are ON. The conversion values will be reset when the bits are turned OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

In the following example, the peak value hold function is in effect for input number 1, and the unit number is 0.



When mean value processing is used together with the peak value hold function, the mean value will be held.

As long as the peak value hold function is in effect, the peak value hold will be held even in the event of a disconnection.

When the load to the CPU Unit is disconnected, the Peak Value Hold Bits (bits 00 to 07 of the word n for CJ1W-AD081-V1, bits 00 to 03 of the word n for CJ1W-AD041-V1) are cleared and the peak value hold function is disabled.




### 3-6-5 Input Disconnection Detection Function

When an input signal range of 1 to 5 V (4 to 20 mA) is used, input circuit disconnections can be detected. The detection conditions for each of the input signal ranges are shown in the following table. (see note)

| Range      | Current/voltage  |
|------------|------------------|
| 1 to 5 V   | Less than 0.3 V  |
| 4 to 20 mA | Less than 1.2 mA |

**Note** The current/voltage level will fluctuate according to the offset/gain adjustment.

The input disconnection detection signals for each input number are stored in bits 00 to 07 of CIO word n+9. Specify these bits as execution conditions to use disconnection detection in the user's program.



The respective bit turns ON when a disconnection is detected for a given input. When the disconnection is restored, the bit turns OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The conversion value during a disconnection will be 0000.

In the following example, the conversion value is read only if there is no disconnection at analog input number 1. (The unit number is 0.)



## 3-7 Adjusting Offset and Gain

### 3-7-1 Adjustment Mode Operational Flow

The adjustment mode enables the input of the connected devices to be calibrated.


The offset voltage (or current) and gain voltage (or current) at the output device are entered as analog input conversion data 0000 and 0FA0 (07D0 if the range is  $\pm 10$  V) respectively for a resolution of 4,000.

For example, when using in the range 1 to 5 V, the actual output may be in the range 0.8 to 4.8 V, even though the specifications range for the external device is 1 to 5 V. In this case, when an offset voltage of 0.8 V is output at the external device, the conversion data at the Analog Input Unit for a resolution of 4,000 will be FF38, and if a gain voltage of 4.8 V is output, the conversion data will be 0EDA. The offset/gain adjustment function will, for this example, convert 0.8 V and 4.8 V to 0000 and 0FA0 respectively and not to FF38 and 0EDA, as illustrated in the following table.

| Offset/gain voltage at the output device | Conversion data before adjustment | Conversion data after adjustment |
|------------------------------------------|-----------------------------------|----------------------------------|
| 0.8 V                                    | FF38 (FE70)                       | 0000 (0000)                      |
| 4.8 V                                    | 0EDA (0DB4)                       | 0FA0 (1F40)                      |

(Values in parentheses are for a resolution of 8,000.)

The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.



**Caution** Be sure to turn OFF the power to the PLC before changing the setting of the operation mode switch.

**Caution** The power must be cycled or the Unit restarted if the operation mode is set in DM word m+18.

**Caution** Set the PLC to PROGRAM mode when using the Analog Input Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog Input Unit will stop operating, and the input values that existed immediately before this stoppage will be retained.


**Caution** Always perform adjustments in conjunction with offset and gain adjustments.

**Note** Input adjustments can be performed more accurately in conjunction with mean value processing.

### 3-7-2 Input Offset and Gain Adjustment Procedures


#### Specifying Input Number to be Adjusted

To specify the input number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)




#### Bits Used for Adjusting Offset and Gain

The CIO word (n+1) bits shown in the following diagram are used for adjusting offset and gain.



**Offset Adjustment**

The procedure for adjusting the analog input offset is explained below. As shown in the following diagram, the offset is adjusted by sampling inputs so that the conversion value becomes 0.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0

A 0

MON


200100 ^ OFF

SET

200100 ^ ON

The analog input's digital conversion values while the Offset Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/current switch is ON.

3. Input the voltage or current so that the conversion value becomes 0000. The following table shows the offset adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value                                        |
|--------------------|-----------------|--------------------------------------------------------------------|
| 0 to 10 V          | −0.5 to 0.5 V   | FF38 to 00C8 (4,000 resolution)<br>FE70 to 0190 (8,000 resolution) |
| −10 to 10 V        | −1.0 to 1.0 V   |                                                                    |
| 1 to 5 V           | 0.8 to 1.2 V    |                                                                    |
| 0 to 5 V           | −0.25 to 0.25 V |                                                                    |
| 4 to 20 mA         | 3.2 to 4.8 mA   |                                                                    |

4. After inputting the voltage or current so that the conversion value for the analog input terminal is 0000, turn ON bit 04 (the Set Bit) of CIO word n+1, and then turn it OFF again.

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

E  
4

MON

SET

200104 ^ OFF

RESET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

A  
0

MON

RESET

200100 ^ ON

RESET

200100 ^ OFF


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
- The EEPROM can be overwritten 50,000 times.
  - While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

## Gain Adjustment


The procedure for adjusting the analog input gain is explained below. As shown in the following diagram, the gain is adjusted by sampling inputs so that the conversion value is maximized.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)



1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)



The analog input's digital conversion values while the Gain Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/current switch is ON.

3. Input the voltage or current so that the conversion value is maximized (0FA0 or 07D0 at a resolution of 4,000). The following table shows the gain adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value |
|--------------------|-----------------|-----------------------------|
| 0 to 10 V          | 9.5 to 10.5 V   | 0ED8 to 1068 (1DB0 to 20D0) |
| –10 to 10 V        | 9.0 to 11.0 V   | 0708 to 0898 (0E10 to 1130) |
| 1 to 5 V           | 4.8 to 5.2 V    | 0ED8 to 1068 (1DB0 to 20D0) |
| 0 to 5 V           | 4.75 to 5.25 V  | 0ED8 to 1068 (1DB0 to 20D0) |
| 4 to 20 mA         | 19.2 to 20.8 mA | 0ED8 to 1068 (1DB0 to 20D0) |

(Values in parentheses are for a resolution of 8,000.)

4. With the voltage or current having been input so that the conversion value for the Analog Input Unit is maximized (0FA0 or 07D0 for a resolution of 4,000), turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200101 ^ ON

RESET

200101 ^ OFF

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
- The EEPROM can be overwritten 50,000 times.
  - While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.



**Clearing Offset and Gain Adjusted Values**

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the input value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

200104 ^ ON

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ ON

200105 ^ OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Note** The EEPROM can be overwritten 50,000 times.

## 3-8 Handling Errors and Alarms

### 3-8-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog Input Unit, the ERC or ERH indicators on the front panel of the Unit will light.


Front panel of Unit

- ☐ RUN  
☐ ERC  
☐ ERH  
☐ ADJ

| LED          | Meaning                | Indicator | Operating status                                                                        |
|--------------|------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                                               |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit   | Operating normally.                                                                     |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit   | Other than the above.                                                                   |


### Troubleshooting Procedure

Use the following procedure for troubleshooting Analog Input Unit errors.




### 3-8-2 Alarms Occurring at the Analog Input Unit

The ERC indicator will light when the Analog Input Unit detects an alarm. The alarm flags in bits 08 to 15 of CIO word n+9 will turn ON.



#### ERC and RUN Indicators: Lit



The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| Word n + 9                     | Alarm flag                                | Error contents                                                 | Input status                                                         | Countermeasure                                                                                                                  |
|--------------------------------|-------------------------------------------|----------------------------------------------------------------|----------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 07<br>(See note 1.) | Disconnection Detection                   | A disconnection was detected.<br>(See note 2.)                 | Conversion data becomes 0000.                                        | Check the rightmost byte of CIO word n+9. The inputs for bits that are ON may be disconnected. Restore any disconnected inputs. |
| Bit 14                         | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the values immediately prior to the error. No data is changed. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog Input Unit.          |

- Note**
1. With the CJ1W-AD041-V1, the Disconnection Detection Flags are stored in bits 00 to 03. Bits 04 to 07 are not used (always OFF).
  2. Disconnection detection operates for input numbers used with a range of 1 to 5 V (4 to 20 mA).

## ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing




This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.

| Word n + 9     | Alarm flag                                                 | Error contents                                                                                                                                           | Input status                                                                | Countermeasure                                                                                                                                                                                      |
|----------------|------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 12         | (Adjustment mode)<br>Input Value Adjustment Range Exceeded | In adjustment mode, offset or gain cannot be adjusted because input value is out of the permissible range for adjustment.                                | Conversion data corresponding to the input signal is monitored in word n+8. | If making the adjustment by means of a connected input device, first adjust the input device before adjusting the Analog Input Unit.                                                                |
| Bit 13         | (Adjustment mode)<br>Input Number Setting Error            | In adjustment mode, adjustment cannot be performed because the specified input number is not set for use or because the wrong input number is specified. | Holds the values immediately prior to the error. No data is changed.        | Check whether the word n input number to be adjusted is set from 21 to 28 (21 to 24 for CJ1W-AD041-V1.)<br>Check whether the input number to be adjusted is set for use by means of the DM setting. |
| Bit 15 only ON | (Adjustment Mode)<br>PLC Error (See note 1.)               | The PLC is in either MONITOR or RUN mode while the Analog Input Unit is operating in adjustment mode.                                                    | Holds the values immediately prior to the error. No data is changed.        | Switch the front panel DIP switch pin to OFF. Restart the Unit in normal mode. (See note 2.)                                                                                                        |

- Note**
1. When a PLC error occurs in the adjustment mode, the Unit will stop operating. (The input values immediately prior to the error are held.)
  2. The operating mode can be set either with the DIP switch or with bits 00 to 07 of D (m+18).

## ERC Indicator: Lit, RUN Indicator: Not Lit




The ERC indicator will be lit when the initial settings for the Analog Input Unit are not set correctly. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF when the error is cleared and the Unit is restarted, or the Special I/O Unit Restart Bit is turned ON and then OFF again.

| Word n + 9 | Alarm flag                          | Error contents                                                        | Input status                                     | Countermeasure                      |
|------------|-------------------------------------|-----------------------------------------------------------------------|--------------------------------------------------|-------------------------------------|
| Bit 11     | Mean Value Processing Setting Error | The wrong number of samplings has been specified for mean processing. | Conversion does not start and data becomes 0000. | Specify a number from 0000 to 0006. |

### 3-8-3 Errors in the CPU Unit

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Input Unit from operating.

#### ERH and RUN Indicators: Lit




The ERH and RUN indicators will be lit if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog Input Unit.

Turn ON the power supply again or restart the system.

For further details, refer to *CJ-series CJ1G-CPU□□, CJ1G/H-CPU□□H Programmable Controllers Operation Manual (W393)*.

| Error                                | Error contents                                             | Input status                                       |
|--------------------------------------|------------------------------------------------------------|----------------------------------------------------|
| I/O bus error                        | Error has occurred during data exchange with the CPU Unit. | Conversion data becomes 0000.                      |
| CPU Unit monitoring error (see note) | No response from CPU Unit during fixed period.             | Maintains the condition existing before the error. |
| CPU Unit WDT error                   | Error has been generated in CPU Unit.                      | Changes to undefined state.                        |

#### ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number for the Analog Input Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Input status                                     |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
| Duplicate Unit Number          | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | Conversion does not start and data becomes 0000. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                                                  |

### 3-8-4 Restarting Special I/O Units

To restart the Analog Input Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

#### Special I/O Unit Restart Bits

| Bits   | Functions            |                                                                                |
|--------|----------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit  | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit  |                                                                                |
| to     | to                   |                                                                                |
| A50215 | Unit #15 Restart Bit |                                                                                |
| A50300 | Unit #16 Restart Bit |                                                                                |
| to     | to                   |                                                                                |
| A50715 | Unit #95 Restart Bit |                                                                                |

The previous conversion data will be held while the Unit is being restarted.

**Note** If the error is not cleared even after turning the Special I/O Unit Restart Bit ON and then OFF again, then replace the Unit.

### 3-8-5 Troubleshooting

The following tables explain the probable causes of troubles that may occur, and the countermeasures for dealing with them.

#### Conversion Data Does Not Change

| Probable cause                                                                           | Countermeasure                                                            | Page |
|------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|------|
| The input is not set for being used.                                                     | Set the input to be used.                                                 | 108  |
| The peak value hold function is in operation.                                            | Turn OFF the peak value hold function if it is not required.              | 114  |
| The input device is not working, the input wiring is wrong, or there is a disconnection. | Using a tester, check to see if the input voltage or current is changing. | ---  |
|                                                                                          | Use Unit's alarm flags to check for a disconnection.                      | 126  |

#### Value Does Not Change as Intended

| Probable cause                                                                                                                | Countermeasure                                                                                    | Page |
|-------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|------|
| The input device's signal range does not match the input signal range for the relevant input number at the Analog Input Unit. | Check the specifications of the input device, and match the settings for the input signal ranges. | 82   |
| The offset and gain are not adjusted.                                                                                         | Adjust the offset and gain.                                                                       | 116  |
| When using the 4 mA to 20 mA range, the voltage/current switch is not turned ON.                                              | Turn ON the voltage/current switch.                                                               | 96   |

#### Conversion Values are Inconsistent

| Probable cause                                          | Countermeasure                                                                                                        | Page |
|---------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|------|
| The input signals are being affected by external noise. | Change the shielded cable connection to the Unit's COM terminal.                                                      | 100  |
|                                                         | Insert a 0.01- $\mu$ F to 0.1- $\mu$ F ceramic capacitor or film capacitor between the input's (+) and (–) terminals. | ---  |
|                                                         | Try increasing the number of mean value processing buffers.                                                           | 111  |





## SECTION 4

# CJ-series Analog Input Units (CJ1W-AD042)

This section explains how to use the CJ1W-AD042 Analog Input Units.

|       |                                                       |     |
|-------|-------------------------------------------------------|-----|
| 4-1   | Specifications .....                                  | 132 |
| 4-1-1 | Specifications .....                                  | 132 |
| 4-1-2 | Input Function Block Diagram .....                    | 134 |
| 4-1-3 | Inputs Specifications .....                           | 134 |
| 4-2   | Operating Procedure .....                             | 137 |
| 4-3   | Components and Switch Settings .....                  | 142 |
| 4-3-1 | Component Names .....                                 | 142 |
| 4-3-2 | Indicators .....                                      | 143 |
| 4-3-3 | Unit Number Switches .....                            | 143 |
| 4-4   | Wiring .....                                          | 144 |
| 4-4-1 | Terminal Arrangement .....                            | 144 |
| 4-4-2 | Internal Circuitry .....                              | 145 |
| 4-4-3 | Voltage Input Disconnection .....                     | 146 |
| 4-4-4 | Input Wiring Example .....                            | 146 |
| 4-4-5 | Input Wiring Considerations .....                     | 148 |
| 4-5   | Exchanging Data with the CPU Unit .....               | 149 |
| 4-5-1 | Outline of Data Exchange .....                        | 149 |
| 4-5-2 | Allocations for Initial Settings Data .....           | 151 |
| 4-5-3 | I/O Refresh Data Allocations .....                    | 154 |
| 4-6   | Analog Input Functions and Operating Procedures ..... | 157 |
| 4-6-1 | Input Settings and Conversion Values .....            | 157 |
| 4-6-2 | Conversion Mode Setting .....                         | 158 |
| 4-6-3 | Mean Value Processing .....                           | 160 |
| 4-6-4 | Input Scaling Function .....                          | 162 |
| 4-6-5 | Peak Value Hold Function .....                        | 164 |
| 4-6-6 | Input Disconnection Detection Function .....          | 165 |
| 4-7   | Handling Errors and Alarms .....                      | 166 |
| 4-7-1 | Indicators and Error Flowchart .....                  | 166 |
| 4-7-2 | Alarms Occurring at the Analog Input Unit .....       | 168 |
| 4-7-3 | Errors in the CPU Unit .....                          | 169 |
| 4-7-4 | Restarting Special I/O Units .....                    | 170 |
| 4-7-5 | Troubleshooting .....                                 | 170 |

## 4-1 Specifications

### 4-1-1 Specifications

|                                           |                                   |                                                                                                                                                |                                                                               |                                                        |
|-------------------------------------------|-----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------|--------------------------------------------------------|
| Unit model                                |                                   | CJ1W-AD042                                                                                                                                     |                                                                               |                                                        |
| Unit type                                 |                                   | CJ-series Special I/O Unit                                                                                                                     |                                                                               |                                                        |
| Isolation (See note 1.)                   |                                   | Between inputs and PLC signals: Digital isolator (No isolation between input signals.)                                                         |                                                                               |                                                        |
| External terminals                        |                                   | 18-point detachable terminal block (M3 screws)                                                                                                 |                                                                               |                                                        |
| Affect on CPU Unit cycle time             |                                   | CJ2 CPU Unit                                                                                                                                   | 0.05 ms                                                                       |                                                        |
|                                           |                                   | CJ1 CPU Unit                                                                                                                                   | 0.2 ms                                                                        |                                                        |
| Current consumption                       |                                   | 520 mA at 5 VDC                                                                                                                                |                                                                               |                                                        |
| Dimensions (mm) (See note 2.)             |                                   | 31 × 90 × 65 (W × H × D)                                                                                                                       |                                                                               |                                                        |
| Weight                                    |                                   | 150 g max.                                                                                                                                     |                                                                               |                                                        |
| General specifications                    |                                   | Conforms to general specifications for SYSMAC CJ Series.                                                                                       |                                                                               |                                                        |
| Mounting position                         |                                   | CJ-series CPU Rack or CJ-series Expansion Rack                                                                                                 |                                                                               |                                                        |
| Maximum number of Units                   |                                   | Per CPU Rack or Expansion Rack (See note 3.)                                                                                                   | Power Supply Unit                                                             | No. of mountable Units                                 |
|                                           |                                   |                                                                                                                                                | CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025                                      | CPU Rack: 8 Units/Rack<br>Expansion Rack: 9 Units/Rack |
|                                           |                                   |                                                                                                                                                | CJ1W-PA202                                                                    | CPU Rack: 4 Units/Rack<br>Expansion Rack: 5 Units/Rack |
|                                           |                                   |                                                                                                                                                | CJ1W-PD022                                                                    | CPU Rack: 3 Units/Rack<br>Expansion Rack: 3 Units/Rack |
| Data exchange with CPU Unit (See note 4.) |                                   | Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959): 10 words/Unit<br>Special I/O Unit Area in DM Area (D20000 to D29599): 100 words/Unit |                                                                               |                                                        |
| Inputs specifications                     | Number of analog inputs           |                                                                                                                                                | 4                                                                             |                                                        |
|                                           | Input signal range (See note 5.)  |                                                                                                                                                | 1 to 5 V/0 to 10 V/−5 to 5 V/−10 to 10 V/4 to 20 mA (See note 6.)             |                                                        |
|                                           | Maximum rated input (See note 7.) |                                                                                                                                                | Voltage Input: ±15 V<br>Current Input: ±30 mA                                 |                                                        |
|                                           | Input impedance                   |                                                                                                                                                | Voltage Input: 1 MΩ min.<br>Current Input: 250 Ω (typical)                    |                                                        |
|                                           | Resolution                        | 1 to 5 V                                                                                                                                       | 1/10,000 (full scale)                                                         |                                                        |
|                                           |                                   | 0 to 10 V                                                                                                                                      | 1/20,000 (full scale)                                                         |                                                        |
|                                           |                                   | −5 to 5 V                                                                                                                                      | 1/20,000 (full scale)                                                         |                                                        |
|                                           |                                   | −10 to 10 V                                                                                                                                    | 1/40,000(full scale)                                                          |                                                        |
|                                           |                                   | 4 to 20 mA                                                                                                                                     | 1/10,000(full scale)                                                          |                                                        |
|                                           | A/D conversion data               |                                                                                                                                                | 16-bit binary data                                                            |                                                        |
|                                           | Accuracy                          | 25°C                                                                                                                                           | Voltage Input: ±0.2% of full scale<br>Current Input: ±0.4% of full scale      |                                                        |
|                                           |                                   | 0 to 55°C                                                                                                                                      | Voltage Input: ±0.4% of full scale<br>Current Input: ±0.6% of full scale      |                                                        |
|                                           | Conversion period (See note 8.)   |                                                                                                                                                | 20 μs for 1 point, 25 μs for 2 points, 30 μs for 3 points, 35 μs for 4 points |                                                        |


|                 |                               |                                                                                                                                                                                                                                                       |
|-----------------|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input functions | Mean value processing         | Stores the last “n” data conversions in the buffer, and stores the mean value of the conversion values. (Number of mean value buffers n = 2, 4, 8, 16, 32, 64, 128, 256, or 512)                                                                      |
|                 | Peak value hold               | Stores the maximum conversion value (including mean value processing) while the Peak Value Hold Bit is ON.                                                                                                                                            |
|                 | Scaling                       | Setting values in any specified unit within a range of $\pm 32,000$ as the upper and lower limits allows A/D conversion to be executed and analog signals to be output using the set values as full scale.                                            |
|                 | Input disconnection detection | Detects a disconnection and turns ON the Disconnection Detection Flag. (See note 9.)                                                                                                                                                                  |
|                 | Direct conversion             | A/D conversion is performed and the converted value is refreshed immediately when the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is executed. A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion. |

- Note**
1. Do not apply a voltage higher than 600 VAC to the terminal block when performing withstand voltage test on this Unit. Otherwise, internal elements may deteriorate.
  2. Refer to page 441 for Unit dimensions.
  3. This is the maximum number of Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP). The maximum number of Analog Input Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack.
  4. Data exchange methods with the CPU Unit are as follows:

|                                                                                      |                                                      |                               |                                                                                                                                                                                                                                             |
|--------------------------------------------------------------------------------------|------------------------------------------------------|-------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959, CIO 2000.00 to CIO 2959.15) | 10 words transferred per Unit                        | CPU Unit to Analog Input Unit | Peak value hold function                                                                                                                                                                                                                    |
|                                                                                      |                                                      | Analog Input Unit to CPU Unit | <ul style="list-style-type: none"> <li>• Conversion value</li> <li>• Input disconnection detection</li> <li>• Alarm flags, etc.</li> </ul>                                                                                                  |
| Special I/O Unit Area in DM Area (D20000 to D29599)                                  | 100 words per Unit transferred at startup or restart | CPU Unit to Analog Input Unit | <ul style="list-style-type: none"> <li>• Number of analog inputs used</li> <li>• Conversion mode setting</li> <li>• Input signal range setting</li> <li>• Number of mean value buffers</li> <li>• Scaling lower and upper limits</li> </ul> |

5. Input signal ranges can be set for each input.
6. To use a current input, connect the positive current input terminal and positive voltage input terminal with the enclosed short bar.
7. The Analog Input Unit must be operated according to the input specifications provided here. Operating the Unit outside these specifications will cause the Unit to malfunction.
8. The A/D conversion period is the time it takes for an analog signal to be stored in memory in the Analog Input Unit as converted data after it has been input. With direct conversion, A/D conversion can be performed and the results read within the processing time of the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction. With cyclic conversion, it takes at least one cycle before the converted data is read by the CPU Unit.
9. Input disconnection detection is supported only when the range is set to 1 to 5 V or 4 to 20 mA. If there is no input signal when the 1 to 5-V or 4 to 20-mA range is set, the Disconnection Detection Flag will turn ON.


### 4-1-2 Input Function Block Diagram







### 4-1-3 Inputs Specifications

If signals that are outside the specified range provided below are input, the conversion values (16-bit binary data) used will be either the maximum or minimum value.

**Range: 1 to 5 V**



**Range: 0 to 10 V****Range: -5 to 5 V****Range: -10 to 10 V**

**Range: 4 to 20 mA**

**Note** The conversion values for a range of –10 to 10 V will be as follows (for a resolution of 40,000):

| 16-bit binary data | BCD     |
|--------------------|---------|
| AA10               | –22,000 |
| :                  | :       |
| FFFF               | –1      |
| 0000               | 0       |
| 0001               | 1       |
| :                  | :       |
| 55F0               | 22,000  |

## 4-2 Operating Procedure

Follow the procedure outlined below when using Analog Input Units.

### Installation and Settings


- 1,2,3...**
1. Use the unit number switches on the front panel of the Unit to set the unit number.
  2. Wire the Unit.
  3. Turn ON the power to the PLC.
  4. Create the I/O tables.
  5. Make the Special I/O Unit settings in the DM Area.
    - Set the number of analog inputs to be used.
    - Set the conversion mode.
    - Set the input signal ranges.
    - Set the number of mean value buffers.
    - Set upper and lower limits for scaling.
  6. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

### Operation

- 1,2,3...**
1. Ladder program
    - Read conversion values or write set values by means of MOV(021) and XFER(070).
    - Specify the peak hold function.
    - Obtain disconnection notifications and error codes.

### Procedure Examples


An example application procedure is given below.



\* In Cyclic Conversion Mode, A/D conversion is performed once each conversion cycle, the same way as it is for the CJ1W-AD041-V1/AD081-V1.


## Setting the Analog Input Unit

- 1,2,3... 1. Set the unit number switches. (Refer to page 143.)



If the unit number is set to 1, words CIO 2010 to CIO 2019 in the Special I/O Unit Area in the CIO Area and words D20100 to D20199 in the Special I/O Unit Area in the DM Area will be allocated to the Analog Input Unit.


2. Connect and wire the Analog Input Unit. (Refer to pages 12, 142, and 146.)



3. Turn ON the power to the PLC.

## Creating I/O Tables

After turning ON the power to the PLC, be sure to create the I/O tables.






## Initial Data Settings

- 1,2,3... 1. Specify the Special I/O Unit settings in the DM Area. (Refer to page 151.)


## Setting Examples

- Unit number: 1
- Cyclic Conversion Mode
- Analog input 1: 1 to 5 V  
Analog input 2: 4 to 20 mA  
Analog input 3: 0 to 10 V  
Analog input 4: -10 to 10 V

- a) Set the number of analog inputs to use. (Refer to page 157.)




- b) Set the conversion mode. (Refer to page 158.)




- c) Set the input signal ranges. (Refer to page 157.)


## 1. Input Signal Range Setting for Input 1




## 2. Input Signal Range Setting for Input 2



## 3. Input Signal Range Setting for Input 3




## 4. Input Signal Range Setting for Input 4




## 2. Cycle the power to the PLC.

Power turned ON again  
(or Special I/O Unit Restart Bit is turned ON).



## Creating Ladder Programs




The data that is converted from analog to digital and output to CIO words (n + 1) to (n + 4) of the Special I/O Unit Area (CIO 2011 to CIO 2014), is stored in the specified addresses D00100 to D00103 as signed binary values 0000 to 0FA0 hex.

## ■ Analog Inputs

| Input number | Input signal range | Input conversion value address<br>(n = CIO 2010)<br>(See note 1.) | Conversion data holding address<br>(See note 2.) |
|--------------|--------------------|-------------------------------------------------------------------|--------------------------------------------------|
| 1            | 1 to 5 V           | n+1 = CIO 2011                                                    | D00100                                           |
| 2            | 4 to 20 mA         | n+2 = CIO 2012                                                    | D00101                                           |
| 3            | 0 to 10 V          | n+3 = CIO 2013                                                    | D00102                                           |
| 4            | -10 to 10 V        | n+4 = CIO 2014                                                    | D00103                                           |

**Note** 1. The addresses are determined by the unit number of the Special I/O Unit.  
(Refer to page 143.)


2. Set as required.




3. Bits 00 to 03 of word (n + 9) are allocated to the Input Disconnection Detection Flags. (Refer to page 165.)

## 4-3 Components and Switch Settings

### 4-3-1 Component Names



- Note**
1. The terminal block is attached using a connector. It can be removed by lowering the lever at the bottom of the terminal block.
  2. The lever must normally be in the raised position. Confirm this before operation.



## 4-3-2 Indicators

The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.


| Indicator   | Meaning                | Indicator status | Operating status                                                                        |
|-------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green) | Operating              | Lit              | Operation normal.                                                                       |
|             |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)   | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|             |                        | Not lit          | Operating normally.                                                                     |
| ERH (red)   | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit.                              |
|             |                        | Not lit          | Operating normally.                                                                     |

## 4-3-3 Unit Number Switches


The CPU Unit and Analog Input Unit exchange data via the Special I/O Unit Areas in the CIO Area and DM Area. The words that are allocated to each Analog Input Unit in the Special I/O Unit Areas in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Unit number switches

MACH  
No.  
 $\times 10^1$



$\times 10^0$




| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | 0           | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | 1           | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | 2           | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | 3           | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | 4           | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | 5           | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | 6           | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | 7           | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | 8           | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | 9           | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | 10          | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | n           | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | 95          | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

## 4-4 Wiring

**⚠ Caution** Always connect surge suppressors to inductive loads in the system (e.g., magnetic contactors, relays, and solenoids). Always separate devices that generate surge from the Analog Input Unit. Faulty Unit operation may cause unexpected system operation.

If inductive loads are connected to output signals from Relay Contact Output Units, connect a surge suppressor in an AC circuit and a diode in a DC circuit close to the inductive load to absorb the back electromotive force.



Connect a surge suppressor in an AC circuit and a diode in a DC circuit.

### 4-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

|                       |    |    |                       |
|-----------------------|----|----|-----------------------|
| Current input 2 (+) * | B1 | A1 | Current input 1 (+) * |
| Voltage input 2 (+)   | B2 | A2 | Voltage input 1 (+)   |
| Input 2 (–)           | B3 | A3 | Input 1 (–)           |
| AG                    | B4 | A4 | AG                    |
| Current input 4 (+) * | B5 | A5 | Current input 3 (+) * |
| Voltage input 4 (+)   | B6 | A6 | Voltage input 3 (+)   |
| Input 4 (–)           | B7 | A7 | Input 3 (–)           |
| AG                    | B8 | A8 | AG                    |
| NC                    | B9 | A9 | N.C.                  |

\* To use a current input, connect the positive current input terminal and positive voltage input terminal with the enclosed short bar.

- Note**
1. The number of analog inputs that can be used is set in the DM Area.
  2. The input signal ranges for individual inputs are set in the DM Area. The input signal range can be set separately for each input.
  3. The AG terminals are connected to the 0-V analog circuit in the Unit. Connecting the input line shield can improve noise resistance.
  4. Do not make any connections to the NC terminals.

The following diagrams show the internal circuitry of the analog input section.

Current input (+)

Voltage input (+)

Input (-)

AG (analog 0 V)

250  $\Omega$

2.2 k $\Omega$

510 k $\Omega$

2.2 k $\Omega$


510 k $\Omega$

Input circuit and conversion circuit

AG (common to all inputs)

The diagram illustrates the internal architecture of the CJ-series PLC. It features a central MPU (Microprocessor Unit) containing RAM and ROM. The MPU is connected to a Bus interface, which in turn connects to an Oscillator. The MPU also connects to another Oscillator and Non-volatile memory. An Indicators/Switch is connected to the MPU. A Digital isolator separates the MPU from the Input Circuitry and A/D converter. The Input Circuitry and A/D converter are connected to External terminals. A Regulator and Insulating DC-to-DC converter are shown, with the DC-to-DC converter receiving +5 V and outputting +15 V, +5 V, and -15 V. The entire system is powered by a +5 V supply.

### 4-4-3 Voltage Input Disconnection




When voltage inputs are used and a disconnection occurs, separate the power supply at the side of the connected devices or use an insulating device (isolator) for each input to avoid the following problems.

When the power supply at the connected devices is shared and section a or b is disconnected, power will flow in the direction of the dotted line and the output voltage of the other connected devices will be reduced to between a third to a half of the voltage. If 1 to 5 V is used and the reduced voltage occurs, disconnection may not be detectable. If section c is disconnected, the power at the negative input terminal will be shared and disconnection will not be detectable.

For current inputs, sharing the power supply between the connected devices will not cause any problems.


### 4-4-4 Input Wiring Example

#### ■ Wiring Example for a Voltage Input






### ■ Wiring Example for a Current Input



\* Connect the positive current input terminal and positive voltage input terminal with the enclosed short bar.

**Note** Crimp terminals must be used for terminal connections, and the screws must be tightened securely. Use M3 screws and tighten them to a torque of 0.5 N·m.



- Note**
1. Set the number of analog inputs to be used so that unused inputs are set so that they are not used. (Refer to pages 152 and 157.) If an input that is not used is set to be used, the input data for it may be unstable. The input data can be made stable by cross-connecting the voltage input terminals (V+) and (V-). However, if these terminals are connected and the inputs are set for the 1 to 5-V or 4 to 20-mA range, the Disconnection Detection Flag will turn ON.
  2. When connecting the shield of the analog input cable\* to the Unit's AG terminal, as shown in the above diagram, use a wire that is 30 cm or shorter if possible.
  3. Do not connect anything to NC terminals shown in the wiring diagram on page 144.
  4. Connect the analog input line shield to the AG terminal on the Analog Input Unit to improve noise resistance.

### **4-4-5 Input Wiring Considerations**

When wiring inputs, apply the following points to avoid noise interference and optimize Analog Input Unit performance.

- Use two-core shielded twisted-pair cables for input connections.
- Route input cables separately from power cables (e.g., AC and three-phase lines), and do not place them in the same duct with power cables.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby), install a noise filter at the power supply input.

## 4-5 Exchanging Data with the CPU Unit

### 4-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the CJ1W-AD042 Analog Input Unit via the Special I/O Unit Area in the CIO Area (for data used to operate the Unit) and the Special I/O Unit Area in the DM Area (for data used for initial settings).

#### ■ I/O Refresh Data

Analog input conversion values, which are used as data for Unit operation, are allocated in the Special I/O Unit Area in the CIO Area of the CPU Unit according to the unit number. These exchanged are updated during I/O refreshing.

#### ■ Initial Settings Data



The Unit's initial settings, such as the number of analog inputs used, the conversion mode, the analog input signal ranges, and the number of mean value buffers, are allocated in the Special I/O Unit Area in the DM Area of the CPU Unit according to the unit number. The settings are exchanged when the power is turned ON or the Unit is restarted.



## Unit Number Setting

The words in the Special I/O Unit Areas in the CIO Area and DM Area that are allocated to each Analog Input Unit are determined by the unit number switches on the front panel of the Unit.

Unit number switches



| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | 0           | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | 1           | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | 2           | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | 3           | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | 4           | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | 5           | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | 6           | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | 7           | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | 8           | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | 9           | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | 10          | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | n           | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | 95          | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

## Special I/O Unit Restart Bits

To restart the Unit after changing the contents of the DM Area or correcting an error, cycle the power supply to the PLC or turn ON the Special I/O Unit Restart Bit.

### ■ Special I/O Unit Restart Bits


| Bit     | Function                |                                   |
|---------|-------------------------|-----------------------------------|
| A502.00 | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON. |
| A502.01 | Unit No. 1 Restart Bit  |                                   |
| to      | to                      |                                   |
| A502.15 | Unit No. 15 Restart Bit |                                   |
| A503.00 | Unit No. 16 Restart Bit |                                   |
| to      | to                      |                                   |
| A507.15 | Unit No. 95 Restart Bit |                                   |

**Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

## 4-5-2 Allocations for Initial Settings Data

### DM Area

The initial settings of the Analog Input Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the number of analog inputs used, the conversion mode, and the analog input signal ranges, must be set in this area.



- Note**
1. The words in the Special I/O Unit Area in the DM Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. (Refer to page 150.)
  2. If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

**Allocations in DM Area**

The following table shows the allocation of DM Area words and bits.

| DM Area word (See note.) | Bits                                     |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
|--------------------------|------------------------------------------|----|----|----|----|----|----|----|---------------------------------------------------------------------------------------------|----|----|----|------------------------------|----|----|----|
|                          | 15                                       | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                                                                          | 06 | 05 | 04 | 03                           | 02 | 01 | 00 |
| D (m)                    | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    |                                                                                             |    |    |    | Number of analog inputs used |    |    |    |
| D (m+1)                  | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    | Conversion mode setting<br>00 hex: Cyclic Conversion Mode<br>A5 hex: Direct Conversion Mode |    |    |    |                              |    |    |    |
| D (m+2)                  | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    | Input 1 signal range                                                                        |    |    |    |                              |    |    |    |
| D (m+3)                  | Number of mean value buffers for input 1 |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+4)                  | Input 1 scaling lower limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+5)                  | Input 1 scaling upper limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+6)                  | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    | Input 2 signal range                                                                        |    |    |    |                              |    |    |    |
| D (m+7)                  | Number of mean value buffers for input 2 |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+8)                  | Input 2 scaling lower limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+9)                  | Input 2 scaling upper limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+10)                 | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    | Input 3 signal range                                                                        |    |    |    |                              |    |    |    |
| D (m+11)                 | Number of mean value buffers for input 3 |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+12)                 | Input 3 scaling lower limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+13)                 | Input 3 scaling upper limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+14)                 | Not used. (Settings are ignored.)        |    |    |    |    |    |    |    | Input 4 signal range                                                                        |    |    |    |                              |    |    |    |
| D (m+15)                 | Number of mean value buffers for input 4 |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+16)                 | Input 4 scaling lower limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |
| D (m+17)                 | Input 4 scaling upper limit              |    |    |    |    |    |    |    |                                                                                             |    |    |    |                              |    |    |    |

**Note** For the DM Area word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .


## ■ Set Values and Stored Values

| Item                                        | Contents                                                                                                                                                                                                                                                                                                                                                                                                                                       | Page |
|---------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Number of analog inputs used                | 0: No inputs used.<br>1: One input used (input 1 used).<br>2: Two inputs used (inputs 1 and 2 used).<br>3: Three inputs used (inputs 1, 2, and 3 used).<br>4: Four inputs used (inputs 1, 2, 3, and 4 used).                                                                                                                                                                                                                                   | 157  |
| Conversion mode setting                     | 00 hex: Cyclic Conversion Mode<br>A5 hex: Direct Conversion Mode (See note 1.)                                                                                                                                                                                                                                                                                                                                                                 | 158  |
| Input signal range                          | 0: -10 to 10 V<br>2: 0 to 10 V<br>3: 4 to 20 mA<br>6: -5 to 5 V<br>7: 1 to 5 V                                                                                                                                                                                                                                                                                                                                                                 | 157  |
| Numbers of mean value buffers (See note 2.) | 0: Mean value processing not used.<br>1: Mean value processing with 2 buffers<br>2: Mean value processing with 4 buffers<br>3: Mean value processing with 8 buffers<br>4: Mean value processing with 16 buffers<br>5: Mean value processing with 32 buffers<br>6: Mean value processing with 64 buffers<br>7: Mean value processing with 128 buffers<br>8: Mean value processing with 256 buffers<br>9: Mean value processing with 512 buffers | 160  |
| Scaling settings                            | Any value other than 0 within range of $\pm 32,000$ (8300 hex to 7D00 hex) as long as the upper limit is not equal to the lower limit.                                                                                                                                                                                                                                                                                                         | 162  |

- Note**
1. A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion. Direct conversion is not supported by CJ1 CPU Units.
  2. Mean value processing cannot be used in Direct Conversion Mode.

### 4-5-3 I/O Refresh Data Allocations

I/O refresh data for the Analog Input Unit is exchanged according to the allocations in the Special I/O Unit Area.



- Note**
1. The words in the Special I/O Unit Area in the CIO Area that are allocated to the Analog Input Unit are determined by the setting of the unit number switches on the front panel of the Unit. (Refer to pages 143 and 150.)
  2. If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.



**Allocations in CIO Area**

The allocations of words and bits in the CIO Area for Cyclic Conversion Mode are shown in the following table. In Direct Conversion Mode, the peak value hold function, Disconnection Detection Bits, and the Alarm Flag in bit 11 are not used.

| I/O                                               | Word | Bits                        |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|---------------------------------------------------|------|-----------------------------|----|----|----|-----------------|----|----|----|-----------------|----|----|----|--------------------------|------------|------------|------------|
|                                                   |      | 15                          | 14 | 13 | 12 | 11              | 10 | 09 | 08 | 07              | 06 | 05 | 04 | 03                       | 02         | 01         | 00         |
| Outputs<br>(CPU Unit<br>to Analog<br>Input Unit)  | n    | Not used.                   |    |    |    |                 |    |    |    |                 |    |    |    | Peak value hold function |            |            |            |
|                                                   |      |                             |    |    |    |                 |    |    |    |                 |    |    |    | Input<br>4               | Input<br>3 | Input<br>2 | Input<br>1 |
| Inputs (Ana-<br>log Input<br>Unit to CPU<br>Unit) | n+1  | Input 1 conversion value    |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   |      | 16 <sup>3</sup>             |    |    |    | 16 <sup>2</sup> |    |    |    | 16 <sup>1</sup> |    |    |    | 16 <sup>0</sup>          |            |            |            |
|                                                   | n+2  | Input 2 conversion value    |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+3  | Input 3 conversion value    |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+4  | Input 4 conversion value    |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+5  | Not used.                   |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+6  | Not used.                   |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+7  | Not used.                   |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+8  | Not used.                   |    |    |    |                 |    |    |    |                 |    |    |    |                          |            |            |            |
|                                                   | n+9  | Alarm Flags/Conversion Mode |    |    |    |                 |    |    |    | Not used.       |    |    |    | Disconnection detection  |            |            |            |
|                                                   |      |                             |    |    |    |                 |    |    |    |                 |    |    |    | Input<br>4               | Input<br>3 | Input<br>2 | Input<br>1 |

For the CIO Area word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

## ■ Set Values and Stored Values

| Item                            | Contents                                                                      | Yes: Settable or usable<br>No: Not settable or usable |                        | Page |
|---------------------------------|-------------------------------------------------------------------------------|-------------------------------------------------------|------------------------|------|
|                                 |                                                                               | Cyclic Conversion Mode                                | Direct Conversion Mode |      |
| Peak value hold function        | 0: Peak value hold not used.<br>1: Peak value hold used.                      | Yes                                                   | No                     | 164  |
| Conversion values               | 16-bit binary data                                                            | Yes                                                   | Yes<br>(See note 1.)   | 157  |
| Input disconnection detection   | 0: No disconnection<br>1: Disconnected                                        | Yes                                                   | No                     | 165  |
| Alarm Flags/<br>Conversion Mode | Bits 00 to 03: Disconnection detection                                        | Yes                                                   | No                     | 168  |
|                                 | Bits 04 to 07: Not used.                                                      | Not used.                                             |                        |      |
|                                 | Bit 08: Scaling data setting error                                            | Yes                                                   | No                     |      |
|                                 | Bit 09: Input signal range setting error or error in number of inputs setting | Yes                                                   | No                     |      |
|                                 | Bit 10: Not used                                                              | Not used.                                             |                        |      |
|                                 | Bit 11: Error in setting of number of mean value buffers                      | Yes                                                   | No<br>(See note 2.)    |      |
|                                 | Bit 12: Error in setting of conversion mode                                   | Yes                                                   | Yes                    |      |
|                                 | Bit 13: Direct Conversion Mode                                                | Yes                                                   | Yes                    |      |
|                                 | Bit 14: A/D converter error                                                   | Yes                                                   | Yes                    |      |
|                                 | Bit 15: Not used                                                              | Not used.                                             |                        |      |

- Note**
1. Data is stored when the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is executed.
  2. Turns ON when there is a setting error.
  3. The input disconnection detection function can be used when the input signal range is set to 1 to 5 V or 4 to 20 mA.
  4. In PROGRAM mode, all CIO Area data for the Analog Input Units will be exchanged regardless of the conversion mode.


| Input signal range | Voltage/current for disconnection detection |
|--------------------|---------------------------------------------|
| 1 to 5 V           | Less than 0.3 V                             |
| 4 to 20 mA         | Less than 1.2 mA                            |

## 4-6 Analog Input Functions and Operating Procedures

### 4-6-1 Input Settings and Conversion Values

#### Number of Analog Inputs Used

The Analog Input Unit performs conversion processing only for the specified number of analog inputs. To specify the number of analog inputs, use a Programming Device to set DM word m as shown in the following diagram.




- 0: No inputs used.
- 1: One input used (input 1 used).
- 2: Two inputs used (inputs 1 and 2 used).
- 3: Three inputs used (inputs 1, 2, and 3 used).
- 4: Four inputs used (inputs 1, 2, 3, and 4 used).

$$m = 20000 + (\text{unit number} \times 100)$$

- Note**
1. In Cyclic Conversion Mode, the conversion period for analog inputs can be made shorter by setting fewer analog inputs. 20  $\mu$ s for 1 point, 25  $\mu$ s for 2 points, 30  $\mu$ s for 3 points, 35  $\mu$ s for 4 points
  2. The conversion value for unused analog inputs will be 0000.

#### Input Signal Range

Each of inputs 1 to 4 can be set to one of the following input signal ranges: -10 to 10 V, 0 to 10 V, 4 to 20 mA, -5 to 5 V, 1 to 5 V. To specify the input signal range for each input, use a Programming Device to set DM words m+2, m+6, m+10, and m+14 as shown in the following diagram.



- 0: -10 to 10 V
- 2: 0 to 10 V
- 3: 4 to 20 mA
- 6: -5 to 5 V
- 7: 1 to 5 V

$$m = 20000 + (\text{unit number} \times 100)$$

- Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

#### Reading Conversion Values

Analog input conversion values are written to CIO words n+1 to n+4 as 16-bit binary data.


| Word | Contents                 |
|------|--------------------------|
| n+1  | Input 1 conversion value |
| n+2  | Input 2 conversion value |
| n+3  | Input 3 conversion value |
| n+4  | Input 4 conversion value |

For the CIO Area word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

Use MOV(021) or XFER(070) to read conversion values in the user program.


### Example 1

In this example, the conversion value from only one input is read. (The unit number is 0.)



### Example 2

In this example, the conversion values from multiple inputs are read. (The unit number is 0.)




## 4-6-2 Conversion Mode Setting

Bits 00 to 07 in DM word m+1 can be used to set the conversion mode. The conversion mode that is set determines the timing of refreshing analog input values. This setting applies to analog inputs 1 to 4. There are not individual settings for each input.

The following table describes the conversion modes that can be set.

| Conversion mode        | Operation                                                                                                                                                                                                                                                                                                                                                                                               | Features                                                                                                                                                                                                                                                                                                               | Remarks                                                                                          |
|------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|
| Cyclic Conversion Mode | A/D conversion is performed once each conversion period and conversion values are refreshed during the I/O refresh period. It takes at least one cycle before the converted data is read by the CPU Unit.                                                                                                                                                                                               | Operation is the same as that of the CJ1W-AD041-V1/AD081-V1 Analog Input Units.                                                                                                                                                                                                                                        | This is the default setting.                                                                     |
| Direct Conversion Mode | A/D conversion is performed and the converted value is refreshed immediately when the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is executed in the CPU Unit. The converted value is not refreshed unless the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is executed. If the CPU Unit is in PROGRAM mode, the conversion values are automatically refreshed using Cyclic Conversion Mode. | AIDC can be used together with the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction for the CJ1W-DA042V Analog Output Unit to create a consistent input-processing-output time. If these instructions are used in a scheduled interrupt task, a constant and consistent input-processing-output time can be created. | A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion. |


To specify the conversion mode, use a Programming Device to set DM word (m+1) as shown in the following diagram.



- Note**
1. When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.
  - 2.


### Example 1

In this example, the conversion value from analog input 1 is read in Direct Conversion Mode. (The unit number is 0.)



### Example 2

In this example, the conversion values from analog inputs 1 to 4 are read in Direct Conversion Mode. (The unit number is 0.)




The ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is used in Direct Conversion Mode.

3. Refer to the *CS/CJ/NSJ-series Instruction Reference Manual* (Cat. No. W474) for information on the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction.  
Refer to page 481 for the instruction execution times for the ANALOG INPUT DIRECT CONVERSION instruction.

### 4-6-3 Mean Value Processing

In Cyclic Conversion Mode, the Analog Input Unit can compute the mean value of the conversion values of analog inputs that have been previously sampled. Mean value processing uses a moving average of the values in the history buffers. It has no effect on the data refresh cycle. (The number of history buffers that can be set for mean value processing is 2, 4, 8, 16, 32, 64, 128, 256, or 512.)



- Note**
1. When “n” number of history buffers are being used, the first conversion data will be stored for all “n” history buffers when data conversion is started or after a disconnection is restored.
  2. When mean value processing is used together with the peak value hold function, the peak mean value will be held.


Use a Programming Device to set the words shown in the following table to enable or disable mean value processing and to set the number of history buffers to use.

| DM Area word | Contents                      | Set value                                                                                                                                                                                                                                                                                                                                                                                                                                      |
|--------------|-------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+3)      | Input 1 mean value processing | 0: Mean value processing not used.<br>1: Mean value processing with 2 buffers<br>2: Mean value processing with 4 buffers<br>3: Mean value processing with 8 buffers<br>4: Mean value processing with 16 buffers<br>5: Mean value processing with 32 buffers<br>6: Mean value processing with 64 buffers<br>7: Mean value processing with 128 buffers<br>8: Mean value processing with 256 buffers<br>9: Mean value processing with 512 buffers |
| D (m+7)      | Input 2 mean value processing |                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| D (m+11)     | Input 3 mean value processing |                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| D (m+15)     | Input 4 mean value processing |                                                                                                                                                                                                                                                                                                                                                                                                                                                |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$


- Note**
1. When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.
  2. The history buffer moving average is calculated as shown below. (In this example, there are four buffers.)

a) With the first cycle, data 1 is stored in all the history buffers.




$$\text{Mean value} = (\text{Data 1} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

b) With the second cycle, data 2 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 2} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

c) With the third cycle, data 3 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 3} + \text{Data 2} + \text{Data 1} + \text{Data 1}) \div 4$$

d) With the fourth cycle, data 4 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 4} + \text{Data 3} + \text{Data 2} + \text{Data 1}) \div 4$$

- e) With the fifth cycle, data 5 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 5} + \text{Data 4} + \text{Data 3} + \text{Data 2}) \div 4$$

- When a disconnection is restored, the mean value processing function begins again from step 1.

## 4-6-4 Input Scaling Function

When upper and lower limits have been preset in 16-bit binary data in the CPU Unit's DM Area between -32,000 and 32,000 decimal (8300 and 7D00 hex), analog inputs are converted from analog to digital and the result is automatically converted to user-specified units with the upper and lower limits taken as full scale based on the conversion resolution. (See note.) This scaling function eliminates the previous necessity of providing programs for numeric conversion to specified units.

**Note** To set the upper or lower limit to a negative number, use two's complement (i.e., -32,000 to -1 are set as 8300 to FFFF hex).

- Note**
1. The upper limit is normally set to be greater than the lower limit, but it is also possible to set lower limit to be greater than the upper limit for reverse scaling.
  2. Actual A/D conversion is executed at up to -5% to +105% of full scale.
  3. When setting upper and lower limits in the DM Area in the specified units, be sure to make the settings in 16-bit binary data (with negative values set as two's complement). For decimal numbers -32,000 to 32,000, set 16-bit binary data (8300 to 7D00 hex).
  4. If the scaling upper limit equals the scaling lower limit, or if the scaling upper limit or scaling lower limit is outside the range of  $\pm 32,000$ , a scaling data setting error will occur and scaling will not be executed. Normal operation is performed without scaling if both the upper and lower limits are set to 0000 (the default values).

### Setting Upper and Lower Limits for Scaling

Set the upper and lower limits for scaling for inputs 1 to 4 in the following DM Area words.

| DM Area word | Bits                        |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|--------------|-----------------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|              | 15                          | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| DM (m+4)     | Input 1 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+5)     | Input 1 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+8)     | Input 2 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+9)     | Input 2 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+12)    | Input 3 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+13)    | Input 3 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+16)    | Input 4 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+17)    | Input 4 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

$$m = 20000 + (\text{unit number} \times 100)$$




**Note** For decimal numbers –32,000 to 32,000, set 16-bit binary data (8300 to 7D00 hex).

### Example Setting 1

For this example, the following conditions are set in the DM Area.

| Condition           | The values shown in parentheses are 16-bit binary data. |
|---------------------|---------------------------------------------------------|
| Input signal range  | 0 to 10 V                                               |
| Scaling lower limit | 0 (0000 hex)                                            |
| Scaling upper limit | 10,000 (2710 hex)                                       |

The following diagram shows the correspondence between input signals and converted scaling values.




| Input signal range | The conversion results shown in parentheses are 16-bit binary data. |
|--------------------|---------------------------------------------------------------------|
| 0 V                | 0 (0000 hex)                                                        |
| 10 V               | 10,000 (2710 hex)                                                   |
| –0.5 V             | –500 (FE0C hex)                                                     |
| 10.5 V             | 10,500 (2904 hex)                                                   |

### Example Setting 2 (Reverse Scaling)

For this example, the following conditions are set in the DM Area.

| Condition           | The values shown in parentheses are 16-bit binary data. |
|---------------------|---------------------------------------------------------|
| Input signal range  | 0 to 10 V                                               |
| Scaling lower limit | 10,000 (2710 hex)                                       |
| Scaling upper limit | 0 (0000 hex)                                            |


The following diagram shows the correspondence between input signals and converted scaling values.




| Input signal range | The conversion results shown in parentheses are 16-bit binary data. |
|--------------------|---------------------------------------------------------------------|
| 0 V                | 10,000 (2710 hex)                                                   |
| 10 V               | 0 (0000 hex)                                                        |
| -0.5 V             | 10,500 (2904 hex)                                                   |
| 10.5 V             | -500 (FE0C hex)                                                     |

#### 4-6-5 Peak Value Hold Function

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). The peak value hold function can be used only in Cyclic Conversion Mode.




The peak value hold function can be set separately for each input by turning ON the corresponding bit (00 to 03) in CIO word n.



The peak value is held as long as the bit for the corresponding input is ON.  
The conversion value is reset when the bit is turned OFF.

- Note** 1. Example: In the following example, the peak value hold function is in effect for input number 1. (The unit number is 0.)




2. When mean value processing is used together with the peak value hold function, the peak mean value will be held.
3. If a disconnection occurs when the peak value hold function is enabled, the conversion value will be 7FFF hex. When the disconnection is restored, the peak hold function will be executed using the previous peak value. (The input signal range must be set to 1 to 5 V or 4 to 20 mA.)
4. The peak value hold function will be disabled when the loads are turned OFF from the CPU Unit.

### 4-6-6 Input Disconnection Detection Function

When an input signal range of 1 to 5 V or 4 to 20 mA is used, input wiring disconnections can be detected. The detection condition for each of the input signal ranges is shown in the following table.

| Input signal range | Voltage/current for disconnection detection |
|--------------------|---------------------------------------------|
| 1 to 5 V           | Less than 0.3 V                             |
| 4 to 20 mA         | Less than 1.2 mA                            |

The input disconnection detection signals for the inputs are stored in bits 00 to 03 of CIO word n+9. Specify these bits as execution conditions to use disconnection detection in the user's program.




The corresponding bit turns ON when a disconnection is detected for a given input. When the disconnection is restored, the bit turns OFF.

$$n = \text{CIO } 2000 + (\text{unit number} \times 10)$$

- Note** The conversion value will be 7FFF hex during a disconnection. This conversion value can be used to detect disconnections during Direct Conversion Mode.

#### Example

In the following example, the conversion value for analog input 1 is read only when there is no disconnection (The unit number is 00.)




## 4-7 Handling Errors and Alarms

### 4-7-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog Input Unit, the ERC or ERH indicator on the front panel of the Unit will light.


Front panel of Unit



| Indicator   | Meaning                | Indicator status | Operating status                                                                        |
|-------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green) | Operating              | Lit              | Operation normal.                                                                       |
|             |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)   | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|             |                        | Not lit          | Operating normally.                                                                     |
| ERH (red)   | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit.                              |
|             |                        | Not lit          | Operating normally.                                                                     |


**Troubleshooting Procedure**

Use the following procedure for troubleshooting Analog Input Unit errors.




## 4-7-2 Alarms Occurring at the Analog Input Unit

The ERC indicator will light when the Analog Input Unit detects an alarm. The alarm flags in bits 08 to 15 of CIO word n+9 will turn ON.



### ERH and RUN Indicators: Lit



The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally.

The following alarm flags will turn ON in CIO word n+9


The alarms will be cleared automatically when the error has been eliminated.

| n+9           | Alarm flag                    | Error contents                                               | Input status                                                         | Countermeasure                                                                                                                                                                                                                                                                               |
|---------------|-------------------------------|--------------------------------------------------------------|----------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 03 | Input disconnection detection | A disconnection was detected. (See note.)                    | Conversion data becomes 7FFF hex.                                    | Check the rightmost byte of CIO word n+9.<br><br>The input for bits that are ON may be disconnected. Restore any disconnected inputs.                                                                                                                                                        |
| Bit 14        | A/D converter error           | An error occurred in the A/D converter or in A/D conversion. | Holds the values immediately prior to the error. No data is changed. | <ul style="list-style-type: none"> <li>If the error persists even after the power supply is cycled or the Unit is restarted, check for a source of noise in the environment.</li> <li>If the error persists even when there is no source of noise, replace the Analog Input Unit.</li> </ul> |

$$n = \text{CIO } 2000 + (\text{unit number} \times 10)$$

**Note** The input disconnection detection function can be used for analog inputs that are in Cyclic Conversion Mode and for which the input signal range is set to 1 to 5 V or 4 to 20 mA.

### ERC Indicator: Lit, RUN Indicator: Not Lit



The ERC indicator will be lit when the initial settings for the Analog Input Unit are not set correctly. The following alarm flags will turn ON in CIO word n+9.


These alarm flags will turn OFF when the error is cleared and the power supply to the PLC is cycled, or the Special I/O Unit Restart Bit is turned ON.

| n+9    | Alarm flag                                                            | Error contents                                                                            | Input status                                         | Countermeasure                                                                                      |
|--------|-----------------------------------------------------------------------|-------------------------------------------------------------------------------------------|------------------------------------------------------|-----------------------------------------------------------------------------------------------------|
| Bit 08 | Scaling data setting error                                            | The scaling settings are out of range. The upper limit equals the lower limit (not 0000). | Conversion does not start and data becomes 0000 hex. | Correct the settings.                                                                               |
| Bit 09 | Input signal range setting error or error in number of inputs setting | The setting of the number of inputs used or an input signal range is wrong.               |                                                      | Set the number of analog inputs used to 0 to 4 and set the input signal ranges to 0, 2, 3, 6, or 7. |
| Bit 11 | Error in setting of number of mean value buffers                      | The wrong number of samplings has been specified for mean processing.                     |                                                      | Specify a number from 0 to 9.                                                                       |
| Bit 12 | Error in setting of conversion mode                                   | The setting for Cyclic Conversion Mode or Direct Conversion Mode is wrong.                |                                                      | Set 00 hex or A5 hex.                                                                               |

### 4-7-3 Errors in the CPU Unit

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Input Unit from operating.


#### ERH and RUN Indicators: Lit



The ERH and RUN indicators will light if an I/O bus error occurs or if a WDT (watchdog timer) error occurs in the CPU Unit, resulting in incorrect I/O refresh with the Analog Input Unit. Cycle the power supply to the PLC or restart the Analog Input Unit.

| Error                     | Error contents                                             | Input status                                |
|---------------------------|------------------------------------------------------------|---------------------------------------------|
| I/O bus error             | Error has occurred during data exchange with the CPU Unit. | Conversion data becomes 0000 hex.           |
| CPU Unit monitoring error | No response from CPU Unit for a specified period of time.  | Maintains the status from before the error. |
| CPU Unit WDT error        | Error has occurred in CPU Unit.                            | Changes to undefined state.                 |

#### ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number of the Analog Input Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Input status                                         |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------|
| Unit Number Duplication Error  | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | Conversion does not start and data becomes 0000 hex. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O tables are different from the ones actually mounted.                        |                                                      |

#### 4-7-4 Restarting Special I/O Units

To restart the Analog Input Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

##### ■ Special I/O Unit Restart Bits

| Bit     | Function                |                                   |
|---------|-------------------------|-----------------------------------|
| A502.00 | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON. |
| A502.01 | Unit No. 1 Restart Bit  |                                   |
| to      | to                      |                                   |
| A502.15 | Unit No. 15 Restart Bit |                                   |
| A503.00 | Unit No. 16 Restart Bit |                                   |
| to      | to                      |                                   |
| A507.15 | Unit No. 95 Restart Bit |                                   |

- The previous conversion data will be held while the Unit is being restarted.

**Note** If the error is not cleared even after turning the Special I/O Unit Restart Bit ON, then replace the Unit.

#### 4-7-5 Troubleshooting

The following tables list the probable causes of troubles that may occur, and the countermeasures for dealing with them.



**Conversion Data Does Not Change**

| Probable cause                                                                                         | Countermeasure                                                                                                                                                              | Page |
|--------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Number of analog inputs used is not set correctly.                                                     | Set the number of analog inputs used to enable all inputs that are being used.                                                                                              | 157  |
| The ANALOG INPUT DIRECT CONVERSION (AIDC) instruction is not being executed in Direct Conversion Mode. | Execute the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction in the user program.                                                                                          | 158  |
| The peak value hold function is in operation.                                                          | Turn OFF the peak value hold function if it is not required.                                                                                                                | 164  |
| The input device is not working, the input wiring is wrong, or there is a disconnection.               | Using a tester, check to see if the input voltage or current is changing.                                                                                                   | ---  |
|                                                                                                        | Use Unit's alarm flags to check for a disconnection. In Direct Conversion Mode, see if the conversion value is 7FFF hex in RUN or MONITOR mode to check for disconnections. | 165  |

**Value Does Not Change as Intended**

| Probable cause                                                                                                                                   | Countermeasure                                                                                               | Page     |
|--------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------|----------|
| The input device's signal range does not match the input signal range for the relevant input number at the Analog Input Unit.                    | Check the specifications of the input device, and match the settings for the input signal ranges.            | 132, 134 |
| For the 4 to 20 mA range, the positive current input terminal and positive voltage input terminal are not connected with the enclosed short bar. | Connect the positive current input terminal and positive voltage input terminal with the enclosed short bar. | 144      |

**Conversion Values are Inconsistent**

| Probable cause                                          | Countermeasure                                                                                                               | Page |
|---------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------|------|
| The input signals are being affected by external noise. | Try connecting the cable shield to the AG terminal on the Analog Input Unit, or disconnecting it if it is already connected. | 146  |
|                                                         | Insert a 0.01- $\mu$ F ceramic capacitor or film capacitor between the input's (+) and (-) terminals.                        | ---  |
|                                                         | Try increasing the number of mean value processing buffers.                                                                  | 160  |



# SECTION 5

## CS-series Analog Output Units (CS1W-DA041/08V/08C)

This section explains how to use the CS1W-DA041/08V/08C Analog Output Units.

|       |                                                        |     |
|-------|--------------------------------------------------------|-----|
| 5-1   | Specifications .....                                   | 174 |
| 5-1-1 | Specifications .....                                   | 174 |
| 5-1-2 | Output Function Block Diagram .....                    | 176 |
| 5-1-3 | Output Specifications .....                            | 176 |
| 5-2   | Operating Procedure .....                              | 178 |
| 5-2-1 | Procedure Examples .....                               | 179 |
| 5-3   | Components and Switch Settings .....                   | 184 |
| 5-3-1 | Indicators .....                                       | 185 |
| 5-3-2 | Unit Number Switches .....                             | 186 |
| 5-3-3 | Operation Mode Switch .....                            | 186 |
| 5-4   | Wiring .....                                           | 187 |
| 5-4-1 | Terminal Arrangement .....                             | 187 |
| 5-4-2 | Internal Circuitry .....                               | 188 |
| 5-4-3 | Output Wiring Example .....                            | 189 |
| 5-4-4 | Output Wiring Considerations .....                     | 190 |
| 5-5   | Exchanging Data with the CPU Unit .....                | 190 |
| 5-5-1 | Outline of Data Exchange .....                         | 190 |
| 5-5-2 | Unit Number Settings .....                             | 191 |
| 5-5-3 | Special I/O Unit Restart Bits .....                    | 191 |
| 5-5-4 | Fixed Data Allocations .....                           | 192 |
| 5-5-5 | I/O Refresh Data Allocations .....                     | 194 |
| 5-6   | Analog Output Functions and Operating Procedures ..... | 197 |
| 5-6-1 | Output Settings and Conversions .....                  | 197 |
| 5-6-2 | Starting and Stopping Conversion .....                 | 199 |
| 5-6-3 | Output Hold Function .....                             | 200 |
| 5-6-4 | Output Setting Errors .....                            | 201 |
| 5-7   | Adjusting Offset and Gain .....                        | 201 |
| 5-7-1 | Adjustment Mode Operational Flow .....                 | 201 |
| 5-7-2 | Output Offset and Gain Adjustment Procedures .....     | 203 |
| 5-8   | Handling Errors and Alarms .....                       | 211 |
| 5-8-1 | Indicators and Error Flowchart .....                   | 211 |
| 5-8-2 | Alarms Occurring at the Analog Output Unit .....       | 213 |
| 5-8-3 | Errors in the CPU Unit .....                           | 214 |
| 5-8-4 | Restarting Special I/O Units .....                     | 215 |
| 5-8-5 | Troubleshooting .....                                  | 216 |

## 5-1 Specifications

### 5-1-1 Specifications

| Item                                          |                                        | CS1W-DA041                                                                                                                                                                                                                                                                                                                                                                                        | CS1W-DA08V                                       | CS1W-DA08C                                     |
|-----------------------------------------------|----------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|------------------------------------------------|
| Unit type                                     |                                        | CS-series Special I/O Unit                                                                                                                                                                                                                                                                                                                                                                        |                                                  |                                                |
| Isolation (See note 1.)                       |                                        | Between outputs and PLC signals: Photocoupler<br>(No isolation between output signals.)                                                                                                                                                                                                                                                                                                           |                                                  |                                                |
| External terminals                            |                                        | 21-point detachable terminal block (M3 screws)                                                                                                                                                                                                                                                                                                                                                    |                                                  |                                                |
| Current consumption                           |                                        | 130 mA max. at 5 VDC,<br>180 mA max. at 26 VDC                                                                                                                                                                                                                                                                                                                                                    | 130 mA max. at 5 VDC,<br>180 mA max. at 26 VDC   | 130 mA max. at 5 VDC,<br>250 mA max. at 26 VDC |
| Dimensions (mm)<br>(See note 2.)              |                                        | 35 × 130 × 126 (W × H × D)                                                                                                                                                                                                                                                                                                                                                                        |                                                  |                                                |
| Weight                                        |                                        | 450 g max.                                                                                                                                                                                                                                                                                                                                                                                        |                                                  |                                                |
| General specifications                        |                                        | Conforms to general specifications for SYSMAC CS-series Series.                                                                                                                                                                                                                                                                                                                                   |                                                  |                                                |
| Mounting position                             |                                        | CS-series CPU Rack or CS-series Expansion Rack<br>(Cannot be mounted to a C200H Expansion I/O Rack or a SYSMAC BUS Slave Rack.)                                                                                                                                                                                                                                                                   |                                                  |                                                |
| Maximum number of Units (See note 3.)         |                                        | Depends on the Power Supply Unit.                                                                                                                                                                                                                                                                                                                                                                 |                                                  |                                                |
| Data exchange with CPU Units<br>(See note 4.) |                                        | Special I/O Unit Area<br>CIO 200000 to CIO295915<br>(Words CIO 2000 to CIO 2959)                                                                                                                                                                                                                                                                                                                  |                                                  |                                                |
|                                               |                                        | Internal Special I/O Unit DM Area<br>(D20000 to D29599)                                                                                                                                                                                                                                                                                                                                           |                                                  |                                                |
| Output specifications                         | Number of analog outputs               | 4                                                                                                                                                                                                                                                                                                                                                                                                 | 8                                                | 8                                              |
|                                               | Output signal ranges<br>(See note 5.)  | 1 to 5 V/4 to 20 mA<br>0 to 5 V<br>0 to 10 V<br>-10 to 10V                                                                                                                                                                                                                                                                                                                                        | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>-10 to 10 V | 4 to 20 mA                                     |
|                                               | Output impedance                       | 0.5 Ω max. (for voltage output)                                                                                                                                                                                                                                                                                                                                                                   |                                                  |                                                |
|                                               | Max. output current (for 1 point)      | 12 mA (for voltage output)                                                                                                                                                                                                                                                                                                                                                                        |                                                  |                                                |
|                                               | Maximum permissible load resistance    | 600 Ω (current output)<br>(See note 9.)                                                                                                                                                                                                                                                                                                                                                           | ---                                              | 600 Ω (current output)<br>(See note 8.)        |
|                                               | Resolution                             | 4,000 (full scale)                                                                                                                                                                                                                                                                                                                                                                                |                                                  |                                                |
|                                               | Set data                               | 16-bit binary data                                                                                                                                                                                                                                                                                                                                                                                |                                                  |                                                |
|                                               | Accuracy<br>(See note 6.)              | 23±2°C: Voltage output: ±0.3% of full scale<br>Current output: ±0.5% of full scale                                                                                                                                                                                                                                                                                                                |                                                  |                                                |
|                                               |                                        | 0°C to 55°C: Voltage output: ±0.5% of full scale<br>Current output: ±0.8% of full scale                                                                                                                                                                                                                                                                                                           |                                                  |                                                |
|                                               | D/A conversion period<br>(See note 7.) | 1.0 ms/point max.                                                                                                                                                                                                                                                                                                                                                                                 |                                                  |                                                |
| Output functions                              | Output hold function                   | Outputs the specified output status (CLR, HOLD, or MAX) under any of the following circumstances.<br>When the Conversion Enable Bit is OFF. (See note 8.)<br>In adjustment mode, when a value other than the output number is output during adjustment.<br>When there is an output setting error or a fatal error occurs at the PLC.<br>When the CPU Unit is on standby.<br>When the Load is OFF. |                                                  |                                                |

- Note**
- Do not apply a voltage higher than 600 V to the terminal block when performing withstand voltage test on this Unit.
  - Refer to *Dimensions* on page 441 for details on the Unit's dimensions.

## 3. Maximum Number of Units

| Power Supply Unit                                              | CS1W-DA041/08V | CS1W-DA08C   |
|----------------------------------------------------------------|----------------|--------------|
| C200HW-PA204<br>C200HW-PA204S<br>C200HW-PA204R<br>C200HW-PD204 | 3 Units max.   | 2 Units max. |
| C200HW-PA209R                                                  | 7 Units max.   | 5 Units max. |

The maximum number of Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack and may be less than the number shown in the above table.


## 4. Data Exchange with CPU Units

|                                                                                   |                                                                                 |                                |                                                                                                       |
|-----------------------------------------------------------------------------------|---------------------------------------------------------------------------------|--------------------------------|-------------------------------------------------------------------------------------------------------|
| Special I/O Unit Area<br>CIO 200000 to CIO 295915<br>(Words CIO 2000 to CIO 2959) | Exchanges 10 words of data per Unit.                                            | CPU Unit to Analog Output Unit | Analog output setting data<br>Conversion Enable Bit                                                   |
|                                                                                   |                                                                                 | Analog Output Unit to CPU Unit | Alarm flags                                                                                           |
| Internal Special I/O Unit DM Area<br>(D20000 to D29599)                           | Transmits 100 words of data per Unit at power-up or when the Unit is restarted. | CPU Unit to Analog Output Unit | Output signal conversion enable/disable, output signal range setting<br>Output status for output hold |

5. Output signal ranges can be set for each output.
6. The accuracy is given for full scale. For example, an accuracy of  $\pm 0.3\%$  means a maximum error of  $\pm 12$  (BCD).
7. D/A conversion time is the time required for converting and outputting the PLC data. It takes at least one cycle for the data stored in the PLC to be read by the Analog Output Unit.
8. When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Output Conversion Enable Bit will turn OFF. The output status specified according to the output hold function will be output.
9. The load resistance is adjusted to  $250\ \Omega$  at the factory. Always adjust the offset gain before application when the load resistance is not  $250\ \Omega$ .

The CS1W-DA041 is adjusted for current outputs (load resistance:  $250\ \Omega$ ) at the factory. Adjust the offset gain before application when using voltage outputs.

## 5-1-2 Output Function Block Diagram




**Note** There are only four analog outputs for the CS1W-DA041.

## 5-1-3 Output Specifications

If the set value is outside the specified range provided below, an output setting error will occur, and the output specified by the output hold function will be output.

**Range: 1 to 5 V (4 to 20 mA)**


Analog output signal



Set value (16-bit binary data)

**Range: 0 to 10 V**


Analog output signal



Set value (16-bit binary data)


**Range: 0 to 5 V**

Analog output signal



Set value (16-bit binary data)

Range: -10 to 10 V



**Note** The set values for a range of -10 to 10 V will be as follows:

| 16-bit binary data | BCD   |
|--------------------|-------|
| F768               | -2200 |
| :                  | :     |
| FFFF               | -1    |
| 0000               | 0     |
| 0001               | 1     |
| :                  | :     |
| 0898               | 2200  |

## 5-2 Operating Procedure

Follow the procedure outlined below when using Analogue Output Units.

### Installation and Settings

**1,2,3...**

- Set the operation mode switch on the rear panel of the Unit to normal mode.
- Wire the Unit.
- Use the unit number switches on the front panel of the Unit to set the unit number.
- Turn ON the power to the PLC.
- Create the I/O tables.
- Make the Special I/O Unit DM Area settings.
  - Set the output numbers to be used.
  - Set the output signal ranges.
  - Set the output hold function.
- Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the output for the connected devices needs to be calibrated, follow the procedures in *Offset and Gain Adjustment* below. Otherwise, skip to *Operation* below.




**Offset and Gain Adjustment**


- 1,2,3...**
1. Set the operation mode switch on the rear panel of the Unit to adjustment mode.
  2. Turn ON the power to the PLC.
  3. Adjust the offset and gain.
  4. Turn OFF the power to the PLC.
  5. Change the setting of the operation mode switch on the rear panel of the Unit back to normal mode.

**Operation**


- 1,2,3...**
1. Turn ON the power to the PLC.
  2. Ladder program
    - Write set values by means of MOV(021) and XFER(070).
    - Start and stop conversion output.
    - Obtain error codes.

**5-2-1 Procedure Examples****Setting the Analog Output Unit**


- 1,2,3...**
1. Set the operation mode switch on the rear panel of the Unit. Refer to 5-3-3 *Operation Mode Switch* for further details.




2. Mount and wire the Analog Output Unit. Refer to *1-2-1 Mounting Procedure*, *5-4 Wiring* or *5-4-3 Output Wiring Example* for further details.



3. Set the unit number switches. Refer to *5-3-2 Unit Number Switches* for further details.




4. Turn ON the power to the PLC.



Creating I/O Tables


After turning ON the power to the PLC, be sure to create the I/O tables.



Initial Data Settings

- 1,2,3...
1.

Specify the Special I/O Unit settings in the DM Area. Refer to *DM Allocation Contents* on page 193 for further details.




Setting conditions


Unit No. 1

- Analogue output 1: 1 to 5 V
- Analogue output 2: 1 to 5 V
- Analogue output 3: -10 to 10 V
- Analogue output 4: Not used.


- The following diagram shows the output settings used. Refer to 5-6-1 *Output Settings and Conversions* for more details.




- The following diagram shows the output range settings. Refer to 5-6-1 *Output Settings and Conversions* for more details.



2. Restart the CPU Unit.



### Creating Ladder Programs




The setting address D00200 is stored in words (n + 1) to (n + 3) of the Special I/O Unit Area (CIO 2011 to CIO 2013) as a signed binary value between 0000 to 0FA0 hex.


The following table shows the addresses used for analog output.

| Output number | Output signal range | Address of output set value<br>(n = CIO 2010)<br>See note 1. | Conversion source address |
|---------------|---------------------|--------------------------------------------------------------|---------------------------|
| 1             | 1 to 5 V            | (n+1) = CIO 2011                                             | D00200                    |
| 2             | 0 to 10 V           | (n+2) = CIO 2012                                             | D00201                    |
| 3             | −10 to 10 V         | (n+3) = CIO 2013                                             | D00202                    |
| 4             | Not used.           | ---                                                          | ---                       |

- Note**
1. The addresses are determined by the unit number of the Special I/O Unit. Refer to *5-3-2 Unit Number Switches* for further details.
  2. Set as required.




## 5-3 Components and Switch Settings



The terminal block is attached using a connector. It can be removed by loosening the two black mounting screws located at the top and bottom of the terminal block.

Check to be sure that the black terminal block mounting screw is securely tightened to a torque of 0.5 N·m.



### 5-3-1 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| Indicator    | Meaning                | Indicator status | Operating status                                                                        |
|--------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit              | Operating in normal mode.                                                               |
|              |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit          | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing         | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit          | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit          | Operating normally.                                                                     |

### 5-3-2 Unit Number Switches

The CPU Unit and Analog Output Unit exchange data via the Special I/O Unit Areas in the CIO Area and DM Area. The words that are allocated to each Analog Output Unit in the Special I/O Unit Areas in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings




| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | Unit #1     | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | Unit #2     | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | Unit #3     | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | Unit #4     | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | Unit #5     | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | Unit #6     | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | Unit #7     | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | Unit #8     | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | Unit #9     | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | Unit #10    | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | Unit #95    | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 5-3-3 Operation Mode Switch

The operation mode switch on the back panel of the Unit is used to set the operation mode to either normal mode or adjustment mode (for adjusting off-set and gain).



| Pin number |     | Mode            |
|------------|-----|-----------------|
| 1          | 2   |                 |
| OFF        | OFF | Normal mode     |
| ON         | OFF | Adjustment mode |

**Caution** Do not set the pins to any combination other than those shown in the above table. Be sure to set pin 2 to OFF.

**Caution** Be sure to turn OFF the power to the PLC before installing or removing the Unit.



## 5-4 Wiring

### 5-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

#### CS1W-DA08V/08C

|              |     |     |              |
|--------------|-----|-----|--------------|
| N.C.         | B1  | A1  | N.C.         |
| Output 2 (+) | B2  | A2  | Output 1 (+) |
| Output 2 (-) | B3  | A3  | Output 1 (-) |
| Output 4 (+) | B4  | A4  | Output 3 (+) |
| Output 4 (-) | B5  | A5  | Output 3 (-) |
| Output 6 (+) | B6  | A6  | Output 5 (+) |
| Output 6 (-) | B7  | A7  | Output 5 (-) |
| Output 8 (+) | B8  | A8  | Output 7 (+) |
| Output 8 (-) | B9  | A9  | Output 7 (-) |
| N.C.         | B10 | A10 | N.C.         |
|              |     | A11 | N.C.         |

#### CS1W-DA041

|                      |     |     |                      |
|----------------------|-----|-----|----------------------|
| N.C.                 | B1  | A1  | N.C.                 |
| Output voltage 2 (+) | B2  | A2  | Output voltage 1 (+) |
| Output 2 (-)         | B3  | A3  | Output 1 (-)         |
| Output current 2 (+) | B4  | A4  | Output current 1 (+) |
| N.C.                 | B5  | A5  | N.C.                 |
| N.C.                 | B6  | A6  | N.C.                 |
| Output voltage 4 (-) | B7  | A7  | Output voltage 3 (+) |
| Output 4 (-)         | B8  | A8  | Output 3 (-)         |
| Output current 4 (+) | B9  | A9  | Output current 3 (+) |
| N.C.                 | B10 | A10 | N.C.                 |
|                      |     | A11 | N.C.                 |


- Note**
1. The number of analog outputs that can be used is set in the DM Area.
  2. The output signal ranges for individual outputs are set in the DM Area. The output signal range can be set separately for each output.
  3. The N.C. terminals are not connected to internal circuitry.

## 5-4-2 Internal Circuitry

The following diagrams show the internal circuitry of the analog output section.


### Voltage Output Circuitry

Voltage output section for CS1W-DA08V/DA041




### Current Output Circuitry


Current output section for CS1W-DA08C/DA041




### Internal Configuration



### 5-4-3 Output Wiring Example



**Note** Crimp terminals must be used for terminal connections, and the screws must be tightened securely. M3 terminal screws are used. The applicable tightening torque is 0.5 N·m.



To minimize output wiring noise, ground the output signal line to the input device.

### 5-4-4 Output Wiring Considerations

When wiring outputs, apply the following points to avoid noise interference and optimize Analog Output Unit performance.

- Use two-core shielded twisted-pair cables for output connections.
- Route output cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable or a high voltage cable. Do not insert output cables into the same duct.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.

## 5-5 Exchanging Data with the CPU Unit

### 5-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the CS1W-DA08V/08C/041 Analog Output Unit via the Special I/O Unit Area (for data used to operate the Unit) and the Special I/O Unit DM Area (for data used for initial settings).

#### I/O Refresh Data

Analog output setting values and other data used to operate the Unit are allocated in the Special I/O Unit Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.


#### Fixed Data

The Unit's fixed data, such as the analog output signal ranges and the output status when conversion is stopped, is allocated in the Special I/O Unit DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.



### 5-5-2 Unit Number Settings

The words in the Special I/O Unit Areas in the CIO Area and DM Area that are allocated to each Analog Output Unit are determined by the setting of the unit number switches on the front panel of the Unit.



| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | Unit #1     | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | Unit #2     | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | Unit #3     | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | Unit #4     | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | Unit #5     | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | Unit #6     | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | Unit #7     | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | Unit #8     | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | Unit #9     | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | Unit #10    | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | Unit #95    | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 5-5-3 Special I/O Unit Restart Bits

To restart the Unit operations after changing the contents of the data memory or correcting an error, turn ON the power to the PLC again or turn the Special I/O Unit Restart Bit ON and then OFF again.


| Special I/O Unit Area word address | Function                |                                                      |
|------------------------------------|-------------------------|------------------------------------------------------|
| A50200                             | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON and then OFF again. |
| A50201                             | Unit No. 1 Restart Bit  |                                                      |
| to                                 | to                      |                                                      |
| A50215                             | Unit No. 15 Restart Bit |                                                      |
| A50300                             | Unit No. 16 Restart Bit |                                                      |
| to                                 | to                      |                                                      |
| A50715                             | Unit No. 95 Restart Bit |                                                      |

**Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

### 5-5-4 Fixed Data Allocations

#### Allocations in DM Area

The initial settings of the Analog Output Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the outputs used, and the analog output signal ranges must be set in this area.



- Note**
1. The words in the Special I/O Unit Area in the DM Area that are allocated to the Analog Output Unit are set using the unit number switches on the front panel of the Unit. Refer to 5-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

**Allocations in DM Area**

The following table shows the allocation of DM words and bits for both normal and adjustment mode.

**CS1W-DA08V/08C**

| DM Area word | Bits                        |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
|--------------|-----------------------------|----|----------|----|----------|----|----------|---|-------------------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
|              | 15                          | 14 | 13       | 12 | 11       | 10 | 9        | 8 | 7                                               | 6         | 5         | 4         | 3         | 2         | 1         | 0         |
| D (m)        | Not used.                   |    |          |    |          |    |          |   | Output use setting                              |           |           |           |           |           |           |           |
|              |                             |    |          |    |          |    |          |   | Out-put 8                                       | Out-put 7 | Out-put 6 | Out-put 5 | Out-put 4 | Out-put 3 | Out-put 2 | Out-put 1 |
| D (m+1)      | Output signal range setting |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
|              | Output 8                    |    | Output 7 |    | Output 6 |    | Output 5 |   | Output 4                                        |           | Output 3  |           | Output 2  |           | Output 1  |           |
| D (m+2)      | Not used.                   |    |          |    |          |    |          |   | Output 1: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+3)      | Not used.                   |    |          |    |          |    |          |   | Output 2: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+4)      | Not used.                   |    |          |    |          |    |          |   | Output 3: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+5)      | Not used.                   |    |          |    |          |    |          |   | Output 4: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+6)      | Not used.                   |    |          |    |          |    |          |   | Output 5: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+7)      | Not used.                   |    |          |    |          |    |          |   | Output 6: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+8)      | Not used.                   |    |          |    |          |    |          |   | Output 7: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+9)      | Not used.                   |    |          |    |          |    |          |   | Output 8: Output status when conversion stopped |           |           |           |           |           |           |           |

**CS1W-DA041**

| DM Area word | Bits      |    |    |    |    |    |   |   |                                                 |   |          |   |                    |           |           |           |
|--------------|-----------|----|----|----|----|----|---|---|-------------------------------------------------|---|----------|---|--------------------|-----------|-----------|-----------|
|              | 15        | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                               | 6 | 5        | 4 | 3                  | 2         | 1         | 0         |
| D (m)        | Not used. |    |    |    |    |    |   |   | Not used.                                       |   |          |   | Output use setting |           |           |           |
|              |           |    |    |    |    |    |   |   |                                                 |   |          |   | Out-put 4          | Out-put 3 | Out-put 2 | Out-put 1 |
| D (m+1)      | Not used. |    |    |    |    |    |   |   | Output signal range setting                     |   |          |   |                    |           |           |           |
|              |           |    |    |    |    |    |   |   | Output 4                                        |   | Output 3 |   | Output 2           |           | Output 1  |           |
| D (m+2)      | Not used. |    |    |    |    |    |   |   | Output 1: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+3)      | Not used. |    |    |    |    |    |   |   | Output 2: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+4)      | Not used. |    |    |    |    |    |   |   | Output 3: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+5)      | Not used. |    |    |    |    |    |   |   | Output 4: Output status when conversion stopped |   |          |   |                    |           |           |           |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**Set Values and Stored Values]**


| Item   |                            | Contents                                                                                                                                                  | Page     |
|--------|----------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| Output | Use setting                | 0: Not used.<br>1: Used.                                                                                                                                  | 193, 197 |
|        | Output signal range        | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V/4 to 20 mA (See note 1.)<br>11: 0 to 5 V                                                                 | 193, 197 |
|        | Output status when stopped | 00: CLR Outputs 0 or minimum value of each range. (See note 2.)<br>01: HOLD Holds output just before stopping.<br>02: MAX Outputs maximum value of range. | 199      |

- Note** 1. With the CS1W-DA041, the output signal ranges 1 to 5 V and 4 to 20 mA are switched using the output terminal connections. For details, refer to 5-4-3 *Output Wiring Example*. With the CS1W-DA08C, these ranges are invalid. Regardless of the settings made, the output range will be 4 to 20 mA. The CS1W-DA08V does not support an output range of 4 to 20 mA.

- The values output for the signal ranges will be 0 V for the range of  $\pm 10$  V, and the minimum value for the other ranges. For details, refer to 5-6-3 *Output Hold Function*.

## 5-5-5 I/O Refresh Data Allocations

I/O refresh data for the Analog Output Unit is exchanged according to the allocations in the Special I/O Unit Area.




- Note**
- The Special I/O Unit Area words that are occupied by the Analog Output Unit are set using the unit number switches on the front panel of the Unit. Refer to 5-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  - If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.



**Allocations for Normal Mode**

For normal mode, set the operation mode switch on the rear panel of the Unit as shown in the following diagram.



The allocation of words and bits in the CIO Area is shown in the following table.

**CS1W-DA08V/08C**

| I/O                     | Word               | Bits               |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|-------------------------|--------------------|--------------------|----|----|----|-----------------|----|---|---|----------------------|-----------|-----------|-----------|-----------------|-----------|-----------|-----------|
|                         |                    | 15                 | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                    | 6         | 5         | 4         | 3               | 2         | 1         | 0         |
| Output<br>(CPU to Unit) | n                  | Not used.          |    |    |    |                 |    |   |   | Conversion enable    |           |           |           |                 |           |           |           |
|                         | Out-put 8          |                    |    |    |    |                 |    |   |   | Out-put 7            | Out-put 6 | Out-put 5 | Out-put 4 | Out-put 3       | Out-put 2 | Out-put 1 |           |
|                         | n + 1              | Output 1 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         |                    | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>      |           |           |           | 16 <sup>0</sup> |           |           |           |
|                         | n + 2              | Output 2 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         | n + 3              | Output 3 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         | n + 4              | Output 4 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         | n + 5              | Output 5 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         | n + 6              | Output 6 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
|                         | n + 7              | Output 7 set value |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
| n + 8                   | Output 8 set value |                    |    |    |    |                 |    |   |   |                      |           |           |           |                 |           |           |           |
| Input<br>(Unit to CPU)  | n + 9              | Alarm Flags        |    |    |    |                 |    |   |   | Output setting error |           |           |           |                 |           |           |           |
|                         |                    |                    |    |    |    |                 |    |   |   | Out-put 8            | Out-put 7 | Out-put 6 | Out-put 5 | Out-put 4       | Out-put 3 | Out-put 2 | Out-put 1 |

**CS1W-DA041**

| I/O                     | Word      | Bits               |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|-------------------------|-----------|--------------------|----|----|----|-----------------|----|---|---|-----------------|---|---|---|----------------------|-----------|-----------|-----------|
|                         |           | 15                 | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7               | 6 | 5 | 4 | 3                    | 2         | 1         | 0         |
| Output<br>(CPU to Unit) | n         | Not used.          |    |    |    |                 |    |   |   | Not used.       |   |   |   | Conversion enable    |           |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |
|                         | n + 1     | Output 1 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         |           | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup> |   |   |   | 16 <sup>0</sup>      |           |           |           |
|                         | n + 2     | Output 2 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 3     | Output 3 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 4     | Output 4 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 5     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 6     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 7     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
| n + 8                   | Not used. |                    |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
| Input<br>(Unit to CPU)  | n + 9     | Alarm Flags        |    |    |    |                 |    |   |   | Not used.       |   |   |   | Output setting error |           |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |


**Note** For the CIO word addresses, n = CIO 2000 + unit number × 10.

## Set Values and Stored Values

| Item                 | Contents                                                                                                                                                                                       | Page     |
|----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| Conversion enable    | 0: Conversion output stopped.<br>1: Conversion output begun.                                                                                                                                   | 199      |
| Set value            | 16-bit binary data                                                                                                                                                                             | 198      |
| Output setting error | 0: No error<br>1: Output setting error                                                                                                                                                         | 201      |
| Alarm Flags          | Bits 00 to 03: Output set value error<br>Bits 04 to 09: Not used<br>Bit 10: Output hold setting error<br>Bit 11: Not used<br>Bit 15: Operating in adjustment mode<br>(always 0 in normal mode) | 195, 213 |

## Allocation for Adjustment Mode

For adjustment mode, set the operation mode switch on the rear panel of the Unit as shown in the following diagram. When the Unit is set for adjustment mode, the ADJ indicator on the front panel of the Unit will flash.



The allocation of CIO words and bits is shown in the following table.

| I/O                     | Word      | Bits                                                |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|-------------------------|-----------|-----------------------------------------------------|----|----|----|-----------------|----|---|---|------------------------|---|-----|-----|----------------------|------|------|---------|
|                         |           | 15                                                  | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                      | 6 | 5   | 4   | 3                    | 2    | 1    | 0       |
| Output<br>(CPU to Unit) | n         | Not used.                                           |    |    |    |                 |    |   |   | Outputs to be adjusted |   |     |     |                      |      |      |         |
|                         |           |                                                     |    |    |    |                 |    |   |   | 1 (fixed)              |   |     |     | 1 to 8 (See note 2.) |      |      |         |
|                         | n + 1     | Not used.                                           |    |    |    |                 |    |   |   | Not used.              |   | Clr | Set | Up                   | Down | Gain | Off-set |
|                         | n + 2     | Not used.                                           |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|                         | n + 3     | Not used.                                           |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|                         | n + 4     | Not used.                                           |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|                         | n + 5     | Not used.                                           |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|                         | n + 6     | Not used.                                           |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
| n + 7                   | Not used. |                                                     |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
| Input<br>(Unit to CPU)  | n + 8     | Conversion value or set value at time of adjustment |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |
|                         |           | 16 <sup>3</sup>                                     |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>        |   |     |     | 16 <sup>0</sup>      |      |      |         |
|                         | n + 9     | Alarm Flags                                         |    |    |    |                 |    |   |   | Not used.              |   |     |     |                      |      |      |         |
|                         |           |                                                     |    |    |    |                 |    |   |   |                        |   |     |     |                      |      |      |         |

- Note**
1. For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .
  2. The range is 1 to 4 for the CS1W-DA04.

**Set Values and Stored Values**

Refer to 5-7 *Adjusting Offset and Gain* or 5-8-2 *Alarms Occurring at the Analog Output Unit* for further details.


| Item                            | Contents                                                                                                                                                                                              |
|---------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Output to be adjusted           | Sets output to be adjusted.<br>Leftmost digit: 1 (fixed)<br>Rightmost digit: 1 to 8 (1 to 4 for CS1W-DA041)                                                                                           |
| Offset (Offset Bit)             | When ON, adjusts offset deviation.                                                                                                                                                                    |
| Gain (Gain Bit)                 | When ON, adjusts gain deviation.                                                                                                                                                                      |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                                                                                                             |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                                                                                                             |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                                                                                                             |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                                                                                                                    |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                                                                                                              |
| Alarm Flags                     | Bit 12: Not used<br>Bit 13: Output number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode (always 1 in adjustment mode) |

## 5-6 Analog Output Functions and Operating Procedures

### 5-6-1 Output Settings and Conversions

**Output Numbers**

The Analog Output Unit converts only analog outputs specified by output numbers 1 to 8 (output numbers 1 to 4 for CS1W-DA041). To specify the analog outputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



**Note** There are only four outputs (1 to 4) for the CS1W-DA041.


The analog output conversion cycle can be shortened by setting any unused output numbers to 0.

$$\text{Conversion cycle} = (1 \text{ ms}) \times (\text{Number of outputs used})$$

- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  2. Output numbers not used (set to 0) will be output at 0 V.

**Output Signal Range**

Any of four types of output signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V/4 to 20 mA, and 0 to 5 V) can be selected for each of the outputs. To specify the output signal range for each output, use a Programming Device to set the D(m+1) bits in the DM Area shown in the following diagram.



- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  2. With the CS1W-DA041, the 1 to 5 V output range and the 4 to 20 mA output range are switched by changing the terminal connections.
  3. There is no 4 to 20 mA output range for the CS1W-DA08V.
  4. Output setting range settings for the CS1W-DA08C are invalid. The output signal range will be 4 to 20 mA, regardless of the settings.
  5. When data memory settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the data memory settings will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is ON.

**Writing Set Values**

Analog output set values are written to CIO words (n+1) to (n+8). For the CS1W-DA041, they are written to CIO words (n+1) to (n+4).


| Word | Function           | Stored value       |
|------|--------------------|--------------------|
| n+1  | Output 1 set value | 16-bit binary data |
| n+2  | Output 2 set value |                    |
| n+3  | Output 3 set value |                    |
| n+4  | Output 4 set value |                    |
| n+5  | Output 5 set value |                    |
| n+6  | Output 6 set value |                    |
| n+7  | Output 7 set value |                    |
| n+8  | Output 8 set value |                    |

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


Use MOV(021) or XFER(070) to write values in the user program.

**Example 1**

In this example, the set value from only one output is written. (The unit number is 0.)




**Example 2** In this example, multiple set values are written. (The unit number is #0.)



**Note** If the set value has been written outside the specified range, an output setting error will occur, and the value set by the output hold function will be output.

5-6-2 Starting and Stopping Conversion

To begin analog output conversion, turn ON the corresponding Conversion Enable Bit (word n, bits 00 to 07 for the CS1W-DA08V and CS1W-DA08C; word n, bits 00 to 03 for the CS1W-DA041) from the user's program.



Analog conversion is executed while these bits are ON. When the bits are turned OFF, the conversion is stopped and the output data is held.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


The analog output when conversion is stopped will differ depending on the output signal range setting and output hold setting. Refer to *5-6-1 Output Settings and Conversions* and *5-6-3 Output Hold Function*.

Conversion will not begin under the following conditions even if the Conversion Enable Bit is turned ON. Refer to *5-6-3 Output Hold Function*.

- 1,2,3...
1. In adjustment mode, when something other than the output number is output during adjustment.
  2. When there is an output setting error.
  3. When a fatal error occurs at the PLC.

When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, the Conversion Enable Bits will all turn OFF. They will also turn OFF when the power supply to the PLC is turned ON. The output status at this time depends on the output hold function.

In this example, conversion is begun for analog output number 1. (The unit number is 0.)



### 5-6-3 Output Hold Function

The Analog Output Unit stops conversion under the following conditions and outputs the value set for the output hold function.

- 1,2,3...**
1. When the Conversion Enable Bit is OFF. Refer to *Allocations for Normal Mode* on page 195 and 5-6-2 *Starting and Stopping Conversion*.
  2. In adjustment mode, when something other than the output number is output during adjustment. Refer to *Allocation for Adjustment Mode* on page 196.
  3. When there is an output setting error. Refer to *Allocations for Normal Mode* on page 195 and 5-6-4 *Output Setting Errors*.
  4. When a fatal error occurs at the PLC.
  5. When there is an I/O bus error.
  6. When the CPU Unit is in LOAD OFF status.
  7. When there is a WDT (watchdog timer) error in the CPU Unit.

CLR, HOLD, or MAX can be selected for the output status when conversion stops.

| Output signal range | CLR                              | HOLD                                            | MAX                              |
|---------------------|----------------------------------|-------------------------------------------------|----------------------------------|
| 0 to 10 V           | −0.5 V (Min. −5% of full scale)  | Voltage that was output just prior to stopping. | 10.5 V (Max. +5% of full scale)  |
| −10 to 10 V         | 0.0 V                            | Voltage that was output just prior to stopping. | 11.0 V (Max. +5% of full scale)  |
| 1 to 5 V            | 0.8 V (Min. −5% of full scale)   | Voltage that was output just prior to stopping. | 5.2 V (Max. +5% of full scale)   |
| 0 to 5 V            | −0.25 V (Min. −5% of full scale) | Voltage that was output just prior to stopping. | 5.25 V (Max. +5% of full scale)  |
| 4 to 20 mA          | 3.2 mA (Min. −5% of full scale)  | Current that was output just prior to stopping. | 20.8 mA (Max. +5% of full scale) |

The above values may fluctuate if offset/gain adjustment has been applied.

To specify the output hold function, use a Programming Device to set the DM Area words D(m+2) to D(m+9) as shown in the following table. (DM Area words D(m+2) to D(m+5) for the CS1W-DA041.)

| DM word | Function                                      | Set value                                                                                                                                                                                                  |
|---------|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D(m+2)  | Output 1: Output status when conversion stops | xx00:CLR<br>Output 0 or minimum value of range (−5%).<br>xx01:HOLD<br>Hold output value prior to stop.<br>xx02: MAX<br>Output maximum value of range (105%).<br>Set any value in the left-most bytes (xx). |
| D(m+3)  | Output 2: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+4)  | Output 3: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+5)  | Output 4: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+6)  | Output 5: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+7)  | Output 6: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+8)  | Output 7: Output status when conversion stops |                                                                                                                                                                                                            |
| D(m+9)  | Output 8: Output status when conversion stops |                                                                                                                                                                                                            |


For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be

transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

## 5-6-4 Output Setting Errors

If the analog output set value is greater than the specified range, a setting error signal will be stored in CIO word n+9, bits 00 to 07. (Bits 00 to 03 for the CS1W-DA041.)



When a setting error is detected for a particular output, the corresponding bit turns ON. When the error is cleared, the bit turns OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The voltage for an output number at which a setting error has occurred will be output according to the output hold function.

## 5-7 Adjusting Offset and Gain

### 5-7-1 Adjustment Mode Operational Flow

The adjustment mode enables the output of the connected devices to be calibrated.


This function adjusts the output voltage according to the offset value and gain value at the input device, and sets the settings values at the Unit at that time to 0000 and 0FA0 (07D0 if the range is  $\pm 10$  V) respectively.

For example, suppose that the specifications range for the external input device (e.g., indicator, etc.) is 100.0 to 500.0 when using in the range 1 to 5 V. Also, suppose that when voltage is output at the Analog Output Unit at a set value of 0000, the external input device actually displays 100.5 and not 100.0. It is possible to make settings to adjust the output voltage (making it smaller in this case) so that 100.0 is displayed and to make 0000 (not FFFB as in this case) the set value for which 100.0 is displayed.

Similarly for gain values, suppose that when voltage is output at the Analog Output Unit at a set value of 0FA0, the external input device actually displays 500.5 and not 500.0. It is possible to make settings to adjust the output voltage (make it smaller in this case) so that 500.0 is displayed and to make 0FA0 (not 0F9B as in this case) the set value for which 500.0 is displayed.

| External input device display | Set value before adjustment (word n+8) | Set value after adjustment |
|-------------------------------|----------------------------------------|----------------------------|
| 100.0                         | FFFB                                   | 0000                       |
| 500.0                         | 0F9B                                   | 0FA0                       |

The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.



**Caution** Be sure to turn OFF the power to the PLC before changing the setting of the operation mode switch.




**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog Output Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog Output Unit will stop operating, and the output values that existed immediately before this stoppage will be retained.

**⚠ Caution** Always perform adjustments in conjunction with offset and gain adjustments.

## 5-7-2 Output Offset and Gain Adjustment Procedures

### Specifying Output Number to be Adjusted

To specify the output number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

|       |             |       |
|-------|-------------|-------|
| CLR   | 000000 CT00 |       |
| SHIFT | CH<br>*DM   | C 2   |
|       | A 0         | A 0   |
|       | A 0         | MON   |
|       | 2000        | 0000  |
| CHG   | 2000        | 0000  |
|       | PRES VAL    | ????  |
| B 1   | B 1         | WRITE |
|       | 2000        | 0011  |


### Bits Used for Adjusting Offset and Gain

The CIO word n+1 bits shown in the following diagram are used for adjusting offset and gain.



## Offset Adjustment

The procedure for adjusting the analog output offset is explained below. As shown in the following diagram, the set value is adjusted so that the analog output reaches the standard value (0 V/1 V/4 mA).



The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0

A 0


MON

200100 ^ OFF


SET

200100 ^ ON

2. Check whether the output devices are connected.



CS1W-DA08V/08C  
CS1W-DA041 (voltage output)



CS1W-DA041 (current output)

3. Monitor CIO word n+8 and check the set value while the Offset Bit is ON.

CLR

000000 CT00

SHIFT

CH  
\*DM

C 2

A 0

A 0

8


MON

2008 0000

4. Change the set value so that the output voltage are as shown in the following table. The data can be set within the indicated ranges.

| Output signal range | Possible output voltage/current adjustment | Output range |
|---------------------|--------------------------------------------|--------------|
| 0 to 10 V           | −0.5 to 0.5 V                              | FF38 to 00C8 |
| −10 to 10 V         | −1.0 to 1.0 V                              |              |
| 1 to 5 V            | 0.8 to 1.2 V                               |              |
| 0 to 5 V            | −0.25 to 0.25 V                            |              |
| 4 to 20 mA          | 3.2 to 4.8 mA                              |              |


Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).



While the Up Bit is ON, the set value will be increased by 1 resolution every 0.5 seconds. After it has been ON for 3 seconds, the set value will be increased by 1 resolution every 0.1 seconds.

While the Down Bit is ON, the set value will be decreased by 1 resolution every 0.5 seconds. After it has been ON for 3 seconds, the set value will be decreased by 1 resolution every 0.1 seconds.

- The following example increases the output voltage.



200103 ^ OFF

The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.


SET

200103 ^ ON

RESET

200103 ^ OFF

- The following example decreases the output voltage.



200102 ^ OFF

The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.

|       |              |
|-------|--------------|
| SET   | 200102 ^ ON  |
| RESET | 200102 ^ OFF |

5. Check the 0-V/1-V/4-mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| SET   |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| RESET |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| SET   |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

## Gain Adjustment

The procedure for adjusting the analog output gain is explained below. As shown in the following diagram, the set value is adjusted so that the analog output is maximized (to 10 V/5 V/20 mA).




The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)

|       |              |
|-------|--------------|
| CLR   | 000000 CT00  |
| SHIFT | CONT #       |
| C 2   | A 0          |
| A 0   | B 1          |
| A 0   | B 1          |
| MON   |              |
|       | 200101 ^ OFF |
| SET   |              |
|       | 200101 ^ ON  |

2. Check whether the output devices are connected.




3. Monitor CIO word n+8 and check the set value while the Gain Bit is ON.

|       |             |
|-------|-------------|
| CLR   | 000000 CT00 |
| SHIFT | CH *DM      |
| C 2   | A 0         |
| A 0   | 8           |
| MON   |             |
|       | 2008 0000   |

4. Change the set value so that the output voltage is as shown in the following table. The data can be set within the indicated ranges.

| Output signal range | Possible output voltage/current adjustment | Output range |
|---------------------|--------------------------------------------|--------------|
| 0 to 10 V           | 9.5 to 10.5 V                              | 0ED8 to 1068 |
| –10 to 10 V         | 9 to 11 V                                  | 0708 to 0898 |
| 1 to 5 V            | 4.8 to 5.2 V                               | 0ED8 to 1068 |
| 0 to 5 V            | 4.75 to 5.25 V                             | 0ED8 to 1068 |
| 4 to 20 mA          | 19.2 to 20.8 mA                            | 0ED8 to 1068 |


Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




While the Up Bit is ON, the set value will be increased by 1 resolution every 0.5 seconds. After it has been ON for 3 seconds, the set value will be increased by 1 resolution every 0.1 seconds.

While the Down Bit is ON, the set value will be decreased by 1 resolution every 0.5 seconds. After it has been ON for 3 seconds, the set value will be decreased by 1 resolution every 0.1 seconds.


- The following example increases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.

|       |              |
|-------|--------------|
| SET   | 200102 ^ ON  |
| RESET | 200102 ^ OFF |

5. Check the 10V/5V/20 mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |     |     |     |     |     |     |     |
|-------|-----------|-----|-----|-----|-----|-----|-----|-----|
| SHIFT | CONT<br># | C 2 | A 0 | A 0 | B 1 | A 0 | E 4 | MON |
|       |           |     |     |     |     |     |     |     |
|       |           |     |     |     |     |     |     |     |
| SET   |           |     |     |     |     |     |     |     |
|       |           |     |     |     |     |     |     |     |
| RESET |           |     |     |     |     |     |     |     |

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |     |     |     |     |     |     |     |
|-------|-----------|-----|-----|-----|-----|-----|-----|-----|
| SHIFT | CONT<br># | C 2 | A 0 | A 0 | B 1 | A 0 | B 1 | MON |
|       |           |     |     |     |     |     |     |     |
|       |           |     |     |     |     |     |     |     |
|       |           |     |     |     |     |     |     |     |
| RESET |           |     |     |     |     |     |     |     |

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

**Clearing Offset and Gain Adjusted Values**

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the set value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

|     |
|-----|
| SET |
|-----|

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

|     |
|-----|
| SET |
|-----|

200104 ^ ON

|       |
|-------|
| RESET |
|-------|

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ ON

|       |
|-------|
| RESET |
|-------|

200105 ^ OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Note** The EEPROM can be overwritten 50,000 times.




## 5-8 Handling Errors and Alarms

### 5-8-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog Output Unit, the ERC or ERH indicators on the front panel of the Unit will light.


Front panel of Unit



| LED          | Meaning                | Indicator | Operating status                                                                        |
|--------------|------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                                               |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit   | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit   | Operating normally.                                                                     |


# Troubleshooting Procedure

Use the following procedure for troubleshooting Analog Output Unit errors.



## 5-8-2 Alarms Occurring at the Analog Output Unit


The ERC indicator will light when the Analog Output Unit detects an alarm. The Alarm Flags in bits 08 to 15 of CIO word n+9 will turn ON.



**Note** With the CS1W-DA041, the Output Setting Error Flags are bits 00 to 03.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


### ERC and RUN Indicators: Lit



The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| Word n + 9                     | Alarm flag                                | Error contents                                                 | Output status                                           | Countermeasure                                                                                                          |
|--------------------------------|-------------------------------------------|----------------------------------------------------------------|---------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 07<br>(See note 1.) | Output Set Value Error                    | The output setting range has been exceeded.                    | Output value set by output hold function.               | Correct the set value.                                                                                                  |
| Bit 14                         | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the output status immediately prior to the error. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog Output Unit. |


- Note**
- $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .
  - The Output Setting Error Flags for the CS1W-DA041 are bits 00 to 03. Bits 04 to 07 are not used (always OFF).

**ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing**

This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.

| Word n + 9     | Alarm flag                                       | Error contents                                                                                                                                             | Output status                                      | Countermeasure                                                                                                                                                           |
|----------------|--------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 13         | (Adjustment mode)<br>Output Number Setting Error | In adjustment mode, adjustment cannot be performed because the specified output number is not set for use or because the wrong output number is specified. | The output voltage or current becomes 0 V or 0 mA. | Check whether the word n output number to be adjusted is set from 11 to 14.<br>Check whether the output number to be adjusted is set for use by means of the DM setting. |
| Bit 15 only ON | (Adjustment Mode)<br>PLC Error                   | The PLC is in either MONITOR or RUN mode while the Analog Output Unit is operating in adjustment mode.                                                     | The output voltage or current becomes 0 V or 0 mA. | Detach the Unit. Switch the rear panel DIP switch pin to OFF. Restart the Unit in normal mode.                                                                           |

**Note** When a PLC error occurs in the adjustment mode, Unit operations will stop operating. (The input and output values immediately prior to the error will be held.)

**ERC Indicator: Lit, RUN Indicator: Not Lit**


The ERC indicator will be lit when the initial settings for the Analog Output Unit are not set correctly. The alarm flags for the following errors will turn ON in CIO word n+9. These alarm flags will turn OFF when the error is cleared and the power to the PLC is cycled, or the Special I/O Unit Restart Bit is turned ON and then OFF again.

| Word n + 9 | Alarm flag                | Error contents                                                            | Countermeasure                      |
|------------|---------------------------|---------------------------------------------------------------------------|-------------------------------------|
| Bit 10     | Output Hold Setting Error | The setting of the output status for when conversion is stopped is wrong. | Specify a number from 0000 to 0002. |

**Note** Bit 15 is normally turned OFF (i.e., set to 0).

**5-8-3 Errors in the CPU Unit**

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Output Unit from operating.

**ERH and RUN Indicators: Lit**

The ERH and RUN indicators will light if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog Output Unit.


Turn ON the power supply again or restart the system.

For further details, refer to *CS-series CS1G/H-CPU□□-E Programmable Controllers Operation Manual (W339)*.

| Error                                 | Error contents                                             | Output condition                            |
|---------------------------------------|------------------------------------------------------------|---------------------------------------------|
| I/O bus error                         | Error has occurred during data exchange with the CPU Unit. | Output value set by output hold function.   |
| CPU Unit monitoring error (See note.) | No response from CPU Unit for a specified period of time.  | Maintains the status from before the error. |
| CPU Unit WDT error                    | Error has been generated in CPU Unit.                      | Output value set by output hold function.   |

**Note** No error will be detected by the CPU Unit or displayed on the Programming Console, because the CPU Unit is continuing operation.

**ERH Indicator: Lit, RUN Indicator: Not Lit**



The unit number for the Analog Output Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Output condition              |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------------------|
| Duplicate Unit Number          | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | The output value will be 0 V. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                               |

## 5-8-4 Restarting Special I/O Units

To restart the Analog Output Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

### Special I/O Unit Restart Bits

| Bits   | Functions            |                                                                                |
|--------|----------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit  | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit  |                                                                                |
| to     | to                   |                                                                                |
| A50215 | Unit #15 Restart Bit |                                                                                |
| A50300 | Unit #16 Restart Bit |                                                                                |
| to     | to                   |                                                                                |
| A50715 | Unit #95 Restart Bit |                                                                                |

The output becomes 0 V or 0 mA during restart.

Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

## 5-8-5 Troubleshooting

The following tables list the probable causes of troubles that may occur, and the countermeasures for dealing with them.

### Analog Output Does Not Change

| Probable Cause                                                | Countermeasure                            | Page |
|---------------------------------------------------------------|-------------------------------------------|------|
| The output is not set for being used.                         | Set the output for being used.            | 197  |
| The output hold function is in operation.                     | Turn ON the Output Conversion Enable Bit. | 200  |
| The conversion value is set outside of the permissible range. | Set the data within the range.            | 176  |

### Value Does Not Change as Intended

| Probable Cause                                                                                                                    | Countermeasure                           | Page |
|-----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------|
| The output signal range setting is wrong.                                                                                         | Correct the output signal range setting. | 198  |
| The specifications of the output device do not match those of the Analog Output Unit (e.g., input signal range, input impedance). | Change the output device.                | 174  |
| The offset or gain is not adjusted.                                                                                               | Adjust the offset or gain.               | 201  |

### Outputs Are Inconsistent

| Probable Cause                                           | Countermeasure                                                                         | Page |
|----------------------------------------------------------|----------------------------------------------------------------------------------------|------|
| The output signals are being affected by external noise. | Try changing the shielded cable connection (e.g., the grounding at the output device). | 190  |

# SECTION 6

## CJ-series Analog Output Unit (CJ1W-DA021/041/08V/08C)

This section explains how to use the CJ1W-DA021/041/08V/08C Analog Output Units.

|       |                                                             |     |
|-------|-------------------------------------------------------------|-----|
| 6-1   | Specifications .....                                        | 218 |
| 6-1-1 | Specifications .....                                        | 218 |
| 6-1-2 | Output Function Block Diagram .....                         | 220 |
| 6-1-3 | Output Specifications .....                                 | 220 |
| 6-2   | Operating Procedure .....                                   | 222 |
| 6-2-1 | Procedure Examples .....                                    | 224 |
| 6-3   | Components and Switch Settings .....                        | 230 |
| 6-3-1 | Indicators .....                                            | 231 |
| 6-3-2 | Unit Number Switches .....                                  | 231 |
| 6-3-3 | Operation Mode Switch (DA021/041) .....                     | 232 |
| 6-4   | Wiring .....                                                | 232 |
| 6-4-1 | Terminal Arrangement .....                                  | 232 |
| 6-4-2 | Internal Circuitry .....                                    | 234 |
| 6-4-3 | Output Wiring Example .....                                 | 235 |
| 6-4-4 | Output Wiring Considerations .....                          | 235 |
| 6-5   | Exchanging Data with the CPU Unit .....                     | 236 |
| 6-5-1 | Outline of Data Exchange .....                              | 236 |
| 6-5-2 | Unit Number Setting .....                                   | 237 |
| 6-5-3 | Special I/O Unit Restart Bits .....                         | 237 |
| 6-5-4 | Fixed Data Allocations .....                                | 238 |
| 6-5-5 | I/O Refresh Data Allocations .....                          | 241 |
| 6-6   | Analog Output Functions and Operating Procedures .....      | 245 |
| 6-6-1 | Output Settings and Conversions .....                       | 245 |
| 6-6-2 | Conversion Time/Resolution Setting (CJ1W-DA08V/08C Only) .. | 247 |
| 6-6-3 | Starting and Stopping Conversion .....                      | 247 |
| 6-6-4 | Output Hold Function .....                                  | 248 |
| 6-6-5 | Output Scaling (CJ1W-DA08V/08C Only) .....                  | 249 |
| 6-6-6 | Output Setting Errors .....                                 | 251 |
| 6-7   | Adjusting Offset and Gain .....                             | 252 |
| 6-7-1 | Adjustment Mode Operational Flow .....                      | 252 |
| 6-7-2 | Output Offset and Gain Adjustment Procedures .....          | 255 |
| 6-8   | Handling Errors and Alarms .....                            | 263 |
| 6-8-1 | Indicators and Error Flowchart .....                        | 263 |
| 6-8-2 | Alarms Occurring at the Analog Output Unit .....            | 265 |
| 6-8-3 | Errors in the CPU Unit .....                                | 267 |
| 6-8-4 | Restarting Special I/O Units .....                          | 268 |
| 6-8-5 | Troubleshooting .....                                       | 268 |

## 6-1 Specifications

### 6-1-1 Specifications

| Item                             | CJ1W-DA021                                                                              | CJ1W-DA041                               | CJ1W-DA08V                                               | CJ1W-DA08C  |
|----------------------------------|-----------------------------------------------------------------------------------------|------------------------------------------|----------------------------------------------------------|-------------|
| Unit type                        | CJ-series Special I/O Unit                                                              |                                          |                                                          |             |
| Isolation (See note 1.)          | Between outputs and PLC signals: Photocoupler<br>(No isolation between output signals.) |                                          |                                                          |             |
| External terminals               | 18-point detachable terminal block (M3 screws)                                          |                                          |                                                          |             |
| Affect on CPU Unit cycle time    | 0.2 ms                                                                                  |                                          |                                                          |             |
| Current consumption              | 5 VDC, 120 mA max.                                                                      |                                          | 5 VDC, 140 mA max.                                       |             |
| External power supply            | 24 VDC +10%, -15% (inrush current: 20 A max., pulse width: 1 ms min.)                   |                                          |                                                          |             |
|                                  | 140 mA max.                                                                             | 200 mA max.                              | 140 mA max.                                              | 170 mA max. |
| Dimensions (mm)<br>(See note 2.) | 31 × 90 × 65 (W × H × D)                                                                |                                          |                                                          |             |
| Weight                           | 150 g max.                                                                              |                                          |                                                          |             |
| General specifications           | Conforms to general specifications for SYSMAC CJ-series Series.                         |                                          |                                                          |             |
| Mounting position                | CJ-series CPU Rack or CJ-series Expansion Rack                                          |                                          |                                                          |             |
| Maximum number of Units          | Per CPU Rack or Expansion Rack (See note 3.)                                            | Power Supply Unit                        | No. of mountable Units                                   |             |
|                                  |                                                                                         | CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025 | CPU Rack: 10 Units/Rack<br>Expansion Rack: 10 Units/Rack |             |
|                                  |                                                                                         | CJ1W-PA202                               | CPU Rack: 10 Units/Rack<br>Expansion Rack: 10 Units/Rack |             |
|                                  |                                                                                         | CJ1W-PD022                               | CPU Rack: 10 Units/Rack<br>Expansion Rack: 10 Units/Rack |             |
| Data exchange with CPU Unit      | Special I/O Unit Area<br>CIO 200000 to CIO295915<br>(Words CIO 2000 to CIO 2959)        |                                          |                                                          |             |
|                                  | Internal Special I/O Unit DM Area<br>(D20000 to D29599)                                 |                                          |                                                          |             |

#### Output Specifications and Functions

| Item                                 |             | CJ1W-DA021                                                                 | CJ1W-DA041 | CJ1W-DA08V                                        | CJ1W-DA08C          |
|--------------------------------------|-------------|----------------------------------------------------------------------------|------------|---------------------------------------------------|---------------------|
| Number of analog outputs             |             | 2                                                                          | 4          | 8                                                 | 8                   |
| Output signal range<br>(See note 4.) |             | 1 to 5 V/4 to 20 mA<br>0 to 5 V<br>0 to 10 V<br>−10 to +10 V               |            | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>−10 to +10 V | 4 to 20 mA          |
| Output impedance                     |             | 0.5 Ω max. (for voltage output)                                            |            |                                                   |                     |
| Max. output current (for 1 point)    |             | 12 mA (for voltage output)                                                 |            | 2.4 mA<br>(for voltage output)                    | ---                 |
| Maximum permissible load resistance  |             | 600 Ω (current output)                                                     |            | ---                                               | 350 Ω               |
| Resolution                           |             | 4,000 (full scale)                                                         |            | 4,000/8,000 (See note 9.)                         |                     |
| Set data                             |             | 16-bit binary data                                                         |            |                                                   |                     |
| Accuracy<br>(See note 6.)            | 23±2°C      | Voltage output: ±0.3% of full scale<br>Current output: ±0.5% of full scale |            | ±0.3% of full scale                               | ±0.3% of full scale |
|                                      | 0°C to 55°C | Voltage output: ±0.5% of full scale<br>Current output: ±0.8% of full scale |            | ±0.5% of full scale                               | ±0.6% of full scale |
| D/A conversion period (See note 7.)  |             | 1.0 ms/point max.                                                          |            | 1.0 ms or 250 μs max. per point                   |                     |



| Item                 | CJ1W-DA021                                                                                                                                                                                                                                                                                                                                                                   | CJ1W-DA041 | CJ1W-DA08V | CJ1W-DA08C |
|----------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------|------------|------------|
| Output hold function | Outputs the specified output status (CLR, HOLD, or MAX) under any of the following circumstances.<br>When the Conversion Enable Bit is OFF. (See note 8.)<br>In adjustment mode, when a value other than the output number is output during adjustment.<br>When there is an output setting error or a fatal error occurs at the PLC. (See note 10.)<br>When the Load is OFF. |            |            |            |
| Scaling function     | Setting values in any specified unit within a range of $\pm 32,000$ as the upper and lower limits allows D/A conversion to be executed and analog signals to be output with these values as full scale.<br>(With the CJ1W-DA08V/DA08C, this function is enabled only for a conversion time of 1.0 s and a resolution of 4,000.)                                              |            |            |            |


- Note**
- Do not apply a voltage higher than 600 V to the terminal block when performing withstand voltage test on this Unit.
  - Refer to *Dimensions* on page 441 for details on the Unit's dimensions.
  - This is the maximum number of Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP). The maximum number of Analog Input Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack.  
Select a 24-VDC power supply based on the surge current. The following OMRON power supplies are recommended.  
S82K-05024: 100 VAC, 50 W  
S82K-10024: 100 VAC, 100 W

- Data exchange methods with the CPU Unit are as follows:

|                                                                                         |                                                          |                             |                                                                                           |
|-----------------------------------------------------------------------------------------|----------------------------------------------------------|-----------------------------|-------------------------------------------------------------------------------------------|
| Special I/O Unit Area in CIO Area<br>CIO 2000 to CIO 2959<br>(CIO 200000 to CIO 295915) | 10 words per Unit<br>Refreshed cyclically                | CPU Unit to Analog I/O Unit | Analog output values<br>Conversion enable bits                                            |
|                                                                                         |                                                          | Analog I/O Unit to CPU Unit | Alarm flags                                                                               |
| Special I/O Unit Area in DM Area<br>D20000 to D29599                                    | 100 words per Unit<br>Refreshed at power ON and restarts | CPU Unit to Analog I/O Unit | Output signal conversion settings and signal ranges<br>Output status when holding outputs |

- Output signal ranges can be set for each output.
- The accuracy is given for full scale. For example, an accuracy of  $\pm 0.3\%$  means a maximum error of  $\pm 12$  (BCD) at a resolution of 4,000. For the CJ1W-DA021/041, the accuracy is at the factory setting for a current output. When using a voltage output, adjust the offset gain as required.
- D/A conversion time is the time required for converting and outputting the PLC data. It takes at least one cycle for the data stored in the PLC to be read by the Analog Output Unit.
- When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Output Conversion Enable Bit will turn OFF. The output status specified according to the output hold function will be output.
- The CJ1W-DA08V/08C can be set to a conversion cycle of 250  $\mu$ s and a resolution of 8,000 using the setting in D(m+18).

## 6-1-2 Output Function Block Diagram




## 6-1-3 Output Specifications

If the set value is outside the specified range provided below, an output setting error will occur, and the output specified by the output hold function will be output.

**Range: 1 to 5 V (4 to 20 mA)**


Analog output signal



Set value (16-bit binary data)  
( ): Values in parentheses are for a resolution of 8,000.

**Range: 0 to 10 V**


Analog output signal



Set value (16-bit binary data)  
 ( ): Values in parentheses are for a  
 resolution of 8,000.

**Range: 0 to 5 V**


Analog output signal



Set value (16-bit binary data)  
 ( ): Values in parentheses are for a  
 resolution of 8,000.

Range: -10 to 10 V

Analog output signal



Set value (16-bit binary data)  
( ): Values in parentheses are for a resolution of 8,000.

**Note** The set values for a range of -10 to 10 V will be as follows:

| 16-bit binary data<br>(when resolution is 4,000) | BCD   |
|--------------------------------------------------|-------|
| F768                                             | -2200 |
| :                                                | :     |
| FFFF                                             | -1    |
| 0000                                             | 0     |
| 0001                                             | 1     |
| :                                                | :     |
| 0898                                             | 2200  |

## 6-2 Operating Procedure

Follow the procedures outlined below when using CJ1W-DA021/041 and CJ1W-DA08V/08C Analog Output Units.

### Installation and Settings

#### CJ1W-DA021/041

**1,2,3...**

1. Set the operation mode switch on the front panel of the Unit to normal mode.
2. Use the unit number switches on the front panel of the Unit to set the unit number.
3. Wire the Unit.
4. Turn ON the power to the PLC.
5. Turn ON the power to the external devices.
6. Create the I/O tables.
7. Make the Special I/O Unit DM Area settings.
  - Set the output numbers to be used.
  - Set the output signal ranges.

- Set the output hold function.

8. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the output for the connected devices needs to be calibrated, follow the procedures in *Offset and Gain Adjustment* below. Otherwise, skip to *Operation* below.

### Offset and Gain Adjustment

- 1,2,3... 1. Set the operation mode switch on the front panel of the Unit to adjustment mode.
2. Turn ON the power to the PLC.  
Be sure to set the PLC to PROGRAM mode.
3. Turn ON the power to the external devices.
4. Adjust the offset and gain.
5. Turn OFF the power to the external devices.
6. Turn OFF the power to the PLC.
7. Change the setting of the operation mode switch on the front panel of the Unit back to normal mode.

### Operation

- 1,2,3... 1. Turn ON the power to the PLC.
2. Turn ON the power to the external devices.
3. Ladder program
  - Write set values by means of MOV(021) and XFER(070).
  - Start and stop conversion output.
  - Obtain error codes.

**Note** Turn the external power supply ON and OFF while power is supplied to the CPU Unit or simultaneously with the CPU Unit. Do not turn the external power supply ON or OFF when power is not supplied to the CPU Unit.

### Installation and Settings

#### CJ1W-DA08V/08C

- 1,2,3... 1. Use the unit number switches on the front panel of the Unit to set the unit number.
2. Wire the Unit.
3. Turn ON the power to the PLC.
4. Turn ON the power to the external devices.
5. Create the I/O tables.
6. Make the Special I/O Unit DM Area settings.
  - Set the output numbers to be used.
  - Set the output signal ranges. (Not required for the CJ1W-DA08C.)
  - Set the output hold function.
  - Set the conversion time and resolution.
  - Set the scaling function
7. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the output for the connected devices needs to be calibrated, follow the procedures in *Offset and Gain Adjustment* below. Otherwise, skip to *Operation* below.

### Offset and Gain Adjustment

- 1,2,3...**
1. Turn ON the power to the PLC.  
Be sure to set the PLC to PROGRAM mode.
  2. Turn ON the power to the external devices.
  3. Set the mode to adjustment mode in the Special I/O Unit DM Area.
  4. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.
  5. Adjust the offset and gain.
  6. Set the mode to normal mode in the Special I/O Unit DM Area.
  7. Restart the Analog Output Unit using its Special I/O Unit Restart Bit or turn the power supply to the PLC OFF and ON.


### Operation

Ladder program

- Write set values by means of MOV(021) and XFER(070).
- Start and stop conversion output.
- Obtain error codes.

**Note** Turn the external power supply ON and OFF while power is supplied to the CPU Unit or simultaneously with the CPU Unit. Do not turn the external power supply ON or OFF when power is not supplied to the CPU Unit.


## 6-2-1 Procedure Examples




## Setting the Analog Output Unit

1,2,3...


1. Set the operation mode switch on the front panel of the Unit. Refer to 6-3-3 *Operation Mode Switch (DA021/041)* for further details. The CJ1W-DA08V/08C does not have this switch. Change the mode by making the setting in D (m+18).



2. Set the unit number switches. Refer to 6-3-2 *Unit Number Switches* for further details.




3. Connect and wire the Analog Output Unit. Refer to 1-2-1 *Mounting Procedure*, Note The CJ1W-DA08V/08C Analog Output Unit has a software setting for the operation mode in bits 00 to 07 of DM word m+18. The contents of DM word m+18 are shown below. or 6-4-3 *Output Wiring Example* for further details.



4. Turn ON the power to the PLC.
5. Turn ON the power to the external devices. (Can be turned ON at the same time as the PLC.)


### Creating I/O Tables

After turning ON the power to the PLC, be sure to create the I/O tables.



### Initial Data Settings

- 1,2,3...** 1. Specify the Special I/O Unit settings in the DM Area. Refer to *DM Allocation Contents* on page 238 for further details.




#### Conditions


Unit number: 1  
 Analog output 1: 1 to 5 V  
 Analog output 2: 1 to 5 V  
 Analog output 3: -10 to 10 V  
 Analog output 4: Not used



- The following diagram shows the output settings used. Refer to 6-6-1 *Output Settings and Conversions* for more details.




- The following diagram shows the output range settings. Refer to 6-6-1 *Output Settings and Conversions* for more details.




**Note** The output range setting is not required for the CJ1W-DA08C.

- The following diagram shows the conversion time/resolution setting for the DA08V. (Refer to 6-6-2 *Conversion Time/Resolution Setting (CJ1W-DA08V/08C Only)*.)



- Turn OFF the external power supply.
- Restart the CPU Unit.
- Turn ON the external power supply.

## Creating Ladder Programs




The setting address D00200 is stored in words (n + 1) to (n + 3) of the Special I/O Unit Area (CIO 2011 to CIO 2013) as a signed binary value between 0000 to 0FA0 hex.

The following table shows the addresses used for analog output.


| Output number | Output signal range | Address of output set value<br>(n = CIO 2010)<br>See note 1. | Conversion source address |
|---------------|---------------------|--------------------------------------------------------------|---------------------------|
| 1             | 1 to 5 V            | (n+1) = CIO 2011                                             | D00200                    |
| 2             | 0 to 10 V           | (n+2) = CIO 2012                                             | D00201                    |
| 3             | −10 to 10 V         | (n+3) = CIO 2013                                             | D00202                    |
| 4             | Not used.           | ---                                                          | ---                       |

- Note**
1. The addresses are determined by the unit number of the Special I/O Unit. Refer to 6-3-2 *Unit Number Switches* for further details.


2. Set as required.



## 6-3 Components and Switch Settings



The terminal block is attached using a connector. It can be removed by pressing down on the lever at the bottom of the terminal block. The lever must normally be in the raised position. Confirm this before operation.



### 6-3-1 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| Indicator    | Meaning                | Indicator status | Operating status                                                                        |
|--------------|------------------------|------------------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit              | Operating in normal mode.                                                               |
|              |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit              | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit          | Operating normally.                                                                     |
| ERH (red)    | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit          | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing         | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit          | Other than the above.                                                                   |

### 6-3-2 Unit Number Switches

The CPU Unit and Analog Output Unit exchange data via the Special I/O Unit Areas in the CIO Area and DM Area. The words that are allocated to each Analog Output Unit in the Special I/O Unit Areas in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings.



| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | Unit #1     | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | Unit #2     | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | Unit #3     | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | Unit #4     | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | Unit #5     | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | Unit #6     | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | Unit #7     | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | Unit #8     | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | Unit #9     | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | Unit #10    | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | Unit #95    | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 6-3-3 Operation Mode Switch (DA021/041)

The operation mode switch on the front panel of the Unit is used to set the operation mode to either normal mode or adjustment mode (for adjusting off-set and gain).

(The CJ1W-DA08V/08C does not have this switch. Change the mode by making the setting in bits 00 to 07 of DM word m+18. Set 00 for adjustment mode or 01 for normal mode.)



| Pin number |     | Mode            |
|------------|-----|-----------------|
| 1          | 2   |                 |
| OFF        | OFF | Normal mode     |
| ON         | OFF | Adjustment mode |

**Caution** Do not set the pins to any combination other than those shown in the above table. Be sure to set pin 2 to OFF.

**Caution** Be sure to turn OFF the power to the PLC before installing or removing the Unit.

**Note** The CJ1W-DA08V/08C Analog Output Unit has a software setting for the operation mode in bits 00 to 07 of DM word m+18. The contents of DM word m+18 are shown below.

| Bit      | 15                                                                                                                                                 | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                                               | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|----------|----------------------------------------------------------------------------------------------------------------------------------------------------|----|----|----|----|----|----|----|------------------------------------------------------------------|----|----|----|----|----|----|----|
| D (m+18) | Conversion time/resolution setting<br>00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 250 μs and resolution of 8,000 |    |    |    |    |    |    |    | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |    |    |    |    |    |    |    |

$$m = D20000 + (\text{unit number} \times 100)$$

## 6-4 Wiring

### 6-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

CJ1W-DA021

|                      |    |    |                      |
|----------------------|----|----|----------------------|
| Voltage output 2 (+) | B1 | A1 | Voltage output 1 (+) |
| Output 2 (-)         | B2 | A2 | Output 1 (-)         |
| Current output 2 (+) | B3 | A3 | Current output 1 (+) |
| N.C.                 | B4 | A4 | N.C.                 |
| N.C.                 | B5 | A5 | N.C.                 |
| N.C.                 | B6 | A6 | N.C.                 |
| N.C.                 | B7 | A7 | N.C.                 |
| N.C.                 | B8 | A8 | N.C.                 |
| 0 V                  | B9 | A9 | 24 V                 |

## CJ1W-DA041

|                      |    |    |                      |
|----------------------|----|----|----------------------|
| Voltage output 2 (+) | B1 | A1 | Voltage output 1 (+) |
| Output 2 (–)         | B2 | A2 | Output 1 (–)         |
| Current output 2 (+) | B3 | A3 | Current output 1 (+) |
| Voltage output 4 (+) | B4 | A4 | Voltage output 3 (+) |
| Output 4 (–)         | B5 | A5 | Output 3 (–)         |
| Current output 4 (+) | B6 | A6 | Current output 3 (+) |
| N.C.                 | B7 | A7 | N.C.                 |
| N.C.                 | B8 | A8 | N.C.                 |
| 0 V                  | B9 | A9 | 24 V                 |

CJ1W-DA08V (Voltage Output)  
and CJ1W-DA08C (Current Output)

|              |    |    |              |
|--------------|----|----|--------------|
| Output 2 (+) | B1 | A1 | Output 1 (+) |
| Output 2 (–) | B2 | A2 | Output 1 (–) |
| Output 4 (+) | B3 | A3 | Output 3 (+) |
| Output 4 (–) | B4 | A4 | Output 3 (–) |
| Output 6 (+) | B5 | A5 | Output 5 (+) |
| Output 6 (–) | B6 | A6 | Output 5 (–) |
| Output 8 (+) | B7 | A7 | Output 7 (+) |
| Output 8 (–) | B8 | A8 | Output 7 (–) |
| 0 V          | B9 | A9 | 24 V         |

1. The number of analog outputs that can be used is set in the DM Area.
2. The output signal ranges for individual outputs are set in the DM Area. The output signal range can be set separately for each output.
3. The N.C. terminals are not connected to internal circuitry.
4. We recommend the following external power supplies.


| Maker | Model number | Specifications |
|-------|--------------|----------------|
| OMRON | S82K-05024   | 100 VAC, 50 W  |
|       | S82K-10024   | 100 VAC, 100 W |

 **Caution** Use a separate power supply from the one used for Basic I/O Units. Faulty Unit operation may be caused by noise if power is supplied from the same source.


## 6-4-2 Internal Circuitry

The following diagrams show the internal circuitry of the analog output section.


### Voltage Output Circuitry



### Current Output Circuitry




### Internal Configuration






### 6-4-3 Output Wiring Example



**Note** Crimp terminals must be used for terminal connections, and the screws must be tightened securely. M3 terminal screws are used. The applicable tightening torque is 0.5 N·m.



To minimize output wiring noise, ground the output signal line to the input device.

### 6-4-4 Output Wiring Considerations

When wiring outputs, apply the following points to avoid noise interference and optimize Analog Output Unit performance.

- Use two-core shielded twisted-pair cables for output connections.
- Route output cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable or a high voltage cable. Do not insert output cables into the same duct.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.
- Use a separate power supply for the external power supply from the one used for Basic I/O Units. If the same power supply is used, noise may cause Units to malfunction.

## 6-5 Exchanging Data with the CPU Unit

### 6-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the Analog Output Unit via the Special I/O Unit Area (for data used to operate the Unit) and the Special I/O Unit DM Area (for data used for initial settings).

#### I/O Refresh Data


Analog output setting values and other data used to operate the Unit are allocated in the Special I/O Unit Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.

#### Fixed Data

The Unit's fixed data, such as the analog output signal ranges and the output status when conversion is stopped, is allocated in the Special I/O Unit DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.



## 6-5-2 Unit Number Setting



The words in the Special I/O Unit Areas in the CIO Area and DM Area that are allocated to each Analog Output Unit are determined by the setting of the unit number switches on the front panel of the Unit.

| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | Unit #1     | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | Unit #2     | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | Unit #3     | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | Unit #4     | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | Unit #5     | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | Unit #6     | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | Unit #7     | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | Unit #8     | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | Unit #9     | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | Unit #10    | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | Unit #95    | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

## 6-5-3 Special I/O Unit Restart Bits

To restart the Analog Output Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.


| Special I/O Unit Area word address | Function                |                                   |
|------------------------------------|-------------------------|-----------------------------------|
| A50200                             | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON. |
| A50201                             | Unit No. 1 Restart Bit  |                                   |
| to                                 | to                      |                                   |
| A50215                             | Unit No. 15 Restart Bit |                                   |
| A50300                             | Unit No. 16 Restart Bit |                                   |
| to                                 | to                      |                                   |
| A50715                             | Unit No. 95 Restart Bit |                                   |

**Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

### 6-5-4 Fixed Data Allocations

#### DM Area

The initial settings of the Analog Output Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the outputs used, and the analog output signal ranges must be set in this area.



- Note**
1. The words in the Special I/O Unit Area in the DM Area that are allocated to the Analog Output Unit are set using the unit number switches on the front panel of the Unit. Refer to 6-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

#### Allocations in DM Area

The following table shows the allocation of DM words and bits for both normal and adjustment mode.

##### CJ1W-DA021

| DM Area word | Bits      |    |    |    |    |    |   |   |                                                 |   |   |   |                             |   |                    |           |
|--------------|-----------|----|----|----|----|----|---|---|-------------------------------------------------|---|---|---|-----------------------------|---|--------------------|-----------|
|              | 15        | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                               | 6 | 5 | 4 | 3                           | 2 | 1                  | 0         |
| D (m)        | Not used. |    |    |    |    |    |   |   | Not used.                                       |   |   |   |                             |   | Output use setting |           |
|              |           |    |    |    |    |    |   |   |                                                 |   |   |   |                             |   | Out-put 2          | Out-put 1 |
| D (m+1)      | Not used. |    |    |    |    |    |   |   | Not used.                                       |   |   |   | Output signal range setting |   |                    |           |
|              |           |    |    |    |    |    |   |   |                                                 |   |   |   | Output 2                    |   | Output 1           |           |
| D (m+2)      | Not used. |    |    |    |    |    |   |   | Output 1: Output status when conversion stopped |   |   |   |                             |   |                    |           |
| D (m+3)      | Not used. |    |    |    |    |    |   |   | Output 2: Output status when conversion stopped |   |   |   |                             |   |                    |           |

## CJ1W-DA041

| DM Area word | Bits      |    |    |    |    |    |   |   |                                                 |   |          |   |                    |           |           |           |
|--------------|-----------|----|----|----|----|----|---|---|-------------------------------------------------|---|----------|---|--------------------|-----------|-----------|-----------|
|              | 15        | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                               | 6 | 5        | 4 | 3                  | 2         | 1         | 0         |
| D (m)        | Not used. |    |    |    |    |    |   |   | Not used.                                       |   |          |   | Output use setting |           |           |           |
|              |           |    |    |    |    |    |   |   |                                                 |   |          |   | Out-put 4          | Out-put 3 | Out-put 2 | Out-put 1 |
| D (m+1)      | Not used. |    |    |    |    |    |   |   | Output signal range setting                     |   |          |   |                    |           |           |           |
|              |           |    |    |    |    |    |   |   | Output 4                                        |   | Output 3 |   | Output 2           |           | Output 1  |           |
| D (m+2)      | Not used. |    |    |    |    |    |   |   | Output 1: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+3)      | Not used. |    |    |    |    |    |   |   | Output 2: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+4)      | Not used. |    |    |    |    |    |   |   | Output 3: Output status when conversion stopped |   |          |   |                    |           |           |           |
| D (m+5)      | Not used. |    |    |    |    |    |   |   | Output 4: Output status when conversion stopped |   |          |   |                    |           |           |           |

## CJ1W-DA08V/08C

| DM Area word     | Bits                               |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
|------------------|------------------------------------|----|----------|----|----------|----|----------|---|-------------------------------------------------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
|                  | 15                                 | 14 | 13       | 12 | 11       | 10 | 9        | 8 | 7                                               | 6         | 5         | 4         | 3         | 2         | 1         | 0         |
| D (m)            | Not used.                          |    |          |    |          |    |          |   | Output use setting                              |           |           |           |           |           |           |           |
|                  |                                    |    |          |    |          |    |          |   | Out-put 8                                       | Out-put 7 | Out-put 6 | Out-put 5 | Out-put 4 | Out-put 3 | Out-put 2 | Out-put 1 |
| D (m+1)          | Output signal range setting        |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
|                  | Output 8                           |    | Output 7 |    | Output 6 |    | Output 5 |   | Output 4                                        |           | Output 3  |           | Output 2  |           | Output 1  |           |
| D (m+2)          | Not used.                          |    |          |    |          |    |          |   | Output 1: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+3)          | Not used.                          |    |          |    |          |    |          |   | Output 2: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+4)          | Not used.                          |    |          |    |          |    |          |   | Output 3: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+5)          | Not used.                          |    |          |    |          |    |          |   | Output 4: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+6)          | Not used.                          |    |          |    |          |    |          |   | Output 5: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+7)          | Not used.                          |    |          |    |          |    |          |   | Output 6: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+8)          | Not used.                          |    |          |    |          |    |          |   | Output 7: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+9)          | Not used.                          |    |          |    |          |    |          |   | Output 8: Output status when conversion stopped |           |           |           |           |           |           |           |
| D (m+10 to m+17) | Not used.                          |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+18)         | Conversion time/resolution setting |    |          |    |          |    |          |   | Operation mode setting                          |           |           |           |           |           |           |           |
| D (m+19)         | Output 1 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+20)         | Output 1 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+21)         | Output 2 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+22)         | Output 2 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+23)         | Output 3 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+24)         | Output 3 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+25)         | Output 4 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+26)         | Output 4 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+27)         | Output 5 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+28)         | Output 5 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+29)         | Output 6 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+30)         | Output 6 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+31)         | Output 7 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+32)         | Output 7 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+33)         | Output 8 scaling lower limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |
| D (m+34)         | Output 8 scaling upper limit       |    |          |    |          |    |          |   |                                                 |           |           |           |           |           |           |           |

**Note** For the DM word addresses, m = D20000 + (unit number × 100).


## Set Values and Stored Values

| Item   |                                       | Contents                                                                                                                                                     | Page     |
|--------|---------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| Output | Use setting                           | 0: Not used.<br>1: Used.                                                                                                                                     | 238, 244 |
|        | Output signal range<br>(See note 1.)  | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V/4 to 20 mA (See note 2.)<br>11: 0 to 5 V                                                                    | 238, 244 |
|        | Output status when stopped            | 00: CLR Outputs 0 or minimum value of each range.<br>(See note 3.)<br>01: HOLD Holds output just before stopping.<br>02: MAX Outputs maximum value of range. | 247      |
|        | Conversion time/resolution<br>setting | 00: Conversion time: 1 ms; resolution: 4,000<br>01: Conversion time: 250 $\mu$ s; resolution: 8,000                                                          | 247      |
|        | Operation mode setting                | 00: Normal mode<br>01: Adjustment mode                                                                                                                       | 232      |
|        | Scaling settings                      | Any value other than 0 within range of $\pm 32,000$ (8300 hex to 7D00 hex)<br>as long as the upper limit is not equal to the lower limit.                    | 249      |

- Note**
1. When using a CJ1W-DA08C, these output signal range settings are invalid and the contents will be ignored. The output signal range for the CJ1W-DA08C is fixed at 4 to 20 mA.
  2. The output signal ranges 1 to 5 V and 4 to 20 mA are switched using the output terminal connections. For details, refer to *6-4 Wiring*. (The CJ1W-DA08V supports only voltage outputs.)
  3. The values output for the signal ranges will be 0 V for the range of  $\pm 10$  V, and the minimum value for the other ranges. For details, refer to *6-6-4 Output Hold Function*.

### 6-5-5 I/O Refresh Data Allocations


I/O refresh data for the Analog Output Unit is exchanged according to the allocations in the Special I/O Unit Area.



- Note**
1. The Special I/O Unit Area words that are occupied by the Analog Output Unit are set using the unit number switches on the front panel of the Unit. Refer to 6-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

#### Allocations for Normal Mode

For normal mode, with CJ1W-DA021/041 Units, set the operation mode switch on the front panel of the Unit as shown in the following diagram. (The CJ1W-DA08V/08C does not have this switch. Change the mode by setting bits 00 to 07 in D(m+18) to 00 hex.)



**Note** The pins are ON when set to the right and OFF when set to the left.

The allocation of words and bits in the CIO Area is shown in the following table.

**CJ1W-DA021**

| I/O                     | Word      | Bits               |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|-------------------------|-----------|--------------------|----|----|----|-----------------|----|---|---|-----------------|---|---|---|----------------------|-----|-----------|-----------|
|                         |           | 15                 | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7               | 6 | 5 | 4 | 3                    | 2   | 1         | 0         |
| Output<br>(CPU to Unit) | n         | Not used.          |    |    |    |                 |    |   |   | Not used.       |   |   |   | Conversion enable    |     |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | ---                  | --- | Out-put 2 | Out-put 1 |
|                         | n + 1     | Output 1 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         |           | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup> |   |   |   | 16 <sup>0</sup>      |     |           |           |
|                         | n + 2     | Output 2 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         | n + 3     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         | n + 4     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         | n + 5     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         | n + 6     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
|                         | n + 7     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
| n + 8                   | Not used. |                    |    |    |    |                 |    |   |   |                 |   |   |   |                      |     |           |           |
| Input<br>(Unit to CPU)  | n + 9     | Alarm Flags        |    |    |    |                 |    |   |   | Not used.       |   |   |   | Output setting error |     |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | ---                  | --- | Out-put 2 | Out-put 1 |

CJ1W-DA041

| I/O                     | Word      | Bits               |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|-------------------------|-----------|--------------------|----|----|----|-----------------|----|---|---|-----------------|---|---|---|----------------------|-----------|-----------|-----------|
|                         |           | 15                 | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7               | 6 | 5 | 4 | 3                    | 2         | 1         | 0         |
| Output<br>(CPU to Unit) | n         | Not used.          |    |    |    |                 |    |   |   | Not used.       |   |   |   | Conversion enable    |           |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |
|                         | n + 1     | Output 1 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         |           | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup> |   |   |   | 16 <sup>0</sup>      |           |           |           |
|                         | n + 2     | Output 2 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 3     | Output 3 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 4     | Output 4 set value |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 5     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 6     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
|                         | n + 7     | Not used.          |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
| n + 8                   | Not used. |                    |    |    |    |                 |    |   |   |                 |   |   |   |                      |           |           |           |
| Input<br>(Unit to CPU)  | n + 9     | Alarm Flags        |    |    |    |                 |    |   |   | Not used.       |   |   |   | Output setting error |           |           |           |
|                         |           |                    |    |    |    |                 |    |   |   |                 |   |   |   | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |



## CJ1W-DA08V/08C

| I/O                        | Word  | Bits               |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|----------------------------|-------|--------------------|----|----|----|-----------------|----|---|---|----------------------|---------------|---------------|---------------|-----------------|---------------|---------------|---------------|
|                            |       | 15                 | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                    | 6             | 5             | 4             | 3               | 2             | 1             | 0             |
| Output<br>(CPU to<br>Unit) | n     | Not used.          |    |    |    |                 |    |   |   | Conversion enable    |               |               |               |                 |               |               |               |
|                            |       | ---                |    |    |    |                 |    |   |   | Out-<br>put 8        | Out-<br>put 7 | Out-<br>put 6 | Out-<br>put 5 | Out-<br>put 4   | Out-<br>put 3 | Out-<br>put 2 | Out-<br>put 1 |
|                            | n + 1 | Output 1 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            |       | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>      |               |               |               | 16 <sup>0</sup> |               |               |               |
|                            | n + 2 | Output 2 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 3 | Output 3 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 4 | Output 4 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 5 | Output 5 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 6 | Output 6 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 7 | Output 7 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
|                            | n + 8 | Output 8 set value |    |    |    |                 |    |   |   |                      |               |               |               |                 |               |               |               |
| Input<br>(Unit to<br>CPU)  | n + 9 | Alarm Flags        |    |    |    |                 |    |   |   | Output setting error |               |               |               |                 |               |               |               |
|                            |       |                    |    |    |    |                 |    |   |   | Out-<br>put 8        | Out-<br>put 7 | Out-<br>put 6 | Out-<br>put 5 | Out-<br>put 4   | Out-<br>put 3 | Out-<br>put 2 | Out-<br>put 1 |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .


## Set Values and Stored Values

| Item                 | Contents                                                                                                                                                                                                                                                                                                                                                        | Page     |
|----------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|
| Conversion enable    | 0: Conversion output stopped.<br>1: Conversion output begun.                                                                                                                                                                                                                                                                                                    | 247      |
| Set value            | 16-bit binary data                                                                                                                                                                                                                                                                                                                                              | 246      |
| Output setting error | 0: No error<br>1: Output setting error                                                                                                                                                                                                                                                                                                                          | 251      |
| Alarm Flags          | Bits 00 to 07: Output setting error<br>(CJ1W-DA021: bits 00 and 01, CJ1W-DA041: bits 00 to 03)<br>Bit 08: Scaling data setting error<br>Bit 09: Not used.<br>Bit 10: Output hold setting error<br>Bit 11: Not used.<br>Bit 12: Conversion time/resolution or operation mode setting error<br>Bit 15: Operating in adjustment mode<br>(Always 0 in normal mode.) | 241, 265 |

## Allocation for Adjustment Mode

For adjustment mode, set the operation mode switch on the front panel of the Unit as shown in the following diagram. When the Unit is set for adjustment mode, the ADJ indicator on the front panel of the Unit will flash.

(The CJ1W-DA08V/08C does not have this switch. Change the mode by setting bits 00 to 07 in D (m+18) to C1 hex.)



**Note** The pins are ON when set to the right and OFF when set to the left.

The allocation of CIO words and bits is shown in the following table.

| I/O                     | Word      | Bits                                                |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|-------------------------|-----------|-----------------------------------------------------|----|----|----|-----------------|----|---|---|--------------------------------------------------------|-----|-----|----|-----------------|------|---------|---|
|                         |           | 15                                                  | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                                                      | 6   | 5   | 4  | 3               | 2    | 1       | 0 |
| Output<br>(CPU to Unit) | n         | Not used.                                           |    |    |    |                 |    |   |   | Outputs to be adjusted                                 |     |     |    |                 |      |         |   |
|                         | 1 (fixed) |                                                     |    |    |    |                 |    |   |   | 1 to 8 (1 and 2 for CJ1W-DA021, 1 to 4 for CJ1W-DA041) |     |     |    |                 |      |         |   |
|                         | n + 1     | Not used.                                           |    |    |    |                 |    |   |   | Not used.                                              | Clr | Set | Up | Down            | Gain | Off-set |   |
|                         | n + 2     | Not used.                                           |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|                         | n + 3     | Not used.                                           |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|                         | n + 4     | Not used.                                           |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|                         | n + 5     | Not used.                                           |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|                         | n + 6     | Not used.                                           |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
| n + 7                   | Not used. |                                                     |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
| Input<br>(Unit to CPU)  | n + 8     | Conversion value or set value at time of adjustment |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |
|                         |           | 16 <sup>3</sup>                                     |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>                                        |     |     |    | 16 <sup>0</sup> |      |         |   |
|                         | n + 9     | Alarm Flags                                         |    |    |    |                 |    |   |   | Not used.                                              |     |     |    |                 |      |         |   |
|                         |           |                                                     |    |    |    |                 |    |   |   |                                                        |     |     |    |                 |      |         |   |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

### Set Values and Stored Values

Refer to 6-7 *Adjusting Offset and Gain* or 6-8-2 *Alarms Occurring at the Analog Output Unit* for further details.


| Item                            | Contents                                                                                                                                                                                              |
|---------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Output to be adjusted           | Sets output to be adjusted.<br>Leftmost digit: 1 (fixed)<br>Rightmost digit: 1 to 8 (1 to 4 (DA041), 1 and 2 (DA021))                                                                                 |
| Offset (Offset Bit)             | When ON, adjusts offset deviation.                                                                                                                                                                    |
| Gain (Gain Bit)                 | When ON, adjusts gain deviation.                                                                                                                                                                      |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                                                                                                             |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                                                                                                             |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                                                                                                             |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                                                                                                                    |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                                                                                                              |
| Alarm Flags                     | Bit 12: Not used<br>Bit 13: Output number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode (always 1 in adjustment mode) |

## 6-6 Analog Output Functions and Operating Procedures

### 6-6-1 Output Settings and Conversions

#### Output Numbers

The Analog Output Unit converts only analog outputs specified by output numbers 1 to 8 (1 to 4 for the CJ1W-DA041, and 1 and 2 for the CJ1W-DA021). To specify the analog outputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



The analog output conversion cycle can be shortened by setting any unused output numbers to 0.


$$\text{Conversion cycle} = (1 \text{ ms}) (\text{See note 3.}) \times (\text{Number of outputs used})$$

#### Note

1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
2. Output numbers not used (set to 0) will be output at 0 V.
3. With the CJ1W-DA08V, the value will be 250  $\mu\text{s}$  when set for a conversion time of 250  $\mu\text{s}$  and a resolution of 8,000.

#### Output Signal Range

Any of four types of output signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, 4 to 20 mA, and 0 to 5 V) can be selected for each of the outputs (only voltage output for the CJ1W-DA08V). (The output signal range for the CJ1W-DA08C is 4 to 20 mA only.) To specify the output signal range for each output, use a Programming Device to set the D (m+1) bits in the DM Area as shown in the following diagram.



#### Note

1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
2. The 1 to 5 V output range and the 4 to 20 mA output range are switched by changing the terminal connections.
3. When data memory settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the

Special I/O Unit Restart Bit. The contents of the data memory settings will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is ON.

- The CJ1W-DA08C provides current output (4 to 20 mA) only. The CJ1W-DA08C cannot be used for voltage output.

### Writing Set Values

Analog output set values are written to CIO words n+1 to n+8 (CIO words n+1 to n+4 for the CJ1W-DA041, n+1 and n+2 for the CJ1W-DA021).


| Word | Function           | Stored value       |
|------|--------------------|--------------------|
| n+1  | Output 1 set value | 16-bit binary data |
| n+2  | Output 2 set value |                    |
| n+3  | Output 3 set value |                    |
| n+4  | Output 4 set value |                    |
| n+5  | Output 5 set value |                    |
| n+6  | Output 6 set value |                    |
| n+7  | Output 7 set value |                    |
| n+8  | Output 8 set value |                    |

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

Use MOV(021) or XFER(070) to write values in the user program.


#### Example 1

In this example, the set value from only one output is written. (The unit number is 0.)



#### Example 2

In this example, multiple set values are written. (The unit number is #0.)




**Note** If the set value has been written outside the specified range, an output setting error will occur, and the value set by the output hold function will be output.

## 6-6-2 Conversion Time/Resolution Setting (CJ1W-DA08V/08C Only)

This setting is supported only by version-1 Units.

Bits 08 to 15 in DM word m+18 can be used to set the conversion time and resolution for the CJ1W-AD08V/08C to increase speed and accuracy.

This setting applies to analog outputs 1 to 8, i.e., there are not individual settings for each input.




00: Conversion time = 1 ms, resolution = 4,000  
 C1: Conversion time = 250  $\mu$ s, resolution = 8,000

(m = D20000 + unit number  $\times$  100)

**Note** After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit in order to transfer the contents of the DM settings to the Special I/O Unit.

## 6-6-3 Starting and Stopping Conversion


To begin analog output conversion, turn ON the corresponding Conversion Enable Bit (word n, bits 00 to 03) from the user's program.



Analog conversion is executed while these bits are ON. When the bits are turned OFF, the conversion is stopped and the output data is held.

- Note**
- For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .
  - The analog output when conversion is stopped will depend on the output signal range setting and output hold setting. Refer to 6-6-1 *Output Settings and Conversions* and 6-6-4 *Output Hold Function*.
  - Conversion will not begin under the following conditions even if the Conversion Enable Bit is turned ON. Refer to 6-6-4 *Output Hold Function*.
    - In adjustment mode, when something other than the output number is output during adjustment.
    - When there is an output setting error.
    - When a fatal error occurs at the PLC.
  - When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, the Conversion Enable Bits will all turn OFF. They will also turn OFF when the power supply to the PLC is turned ON. The output status at this time depends on the output hold function.

In this example, conversion is begun for analog output number 1. (The unit number is 0.)



### 6-6-4 Output Hold Function

The Analog Output Unit stops conversion under the following conditions and outputs the value set for the output hold function.

- 1,2,3...**
1. When the Conversion Enable Bit is OFF. Refer to *Allocations for Normal Mode* on page 241 and *6-6-3 Starting and Stopping Conversion*.
  2. In adjustment mode, when something other than the output number is output during adjustment. Refer to *Allocation for Adjustment Mode* on page 243.
  3. When there is an output setting error. Refer to *Allocations for Normal Mode* on page 241 and page 252.
  4. When a fatal error occurs at the PLC.
  5. When there is an I/O bus error.
  6. When the CPU Unit is in LOAD OFF status.
  7. When there is a WDT (watchdog timer) error in the CPU Unit.

CLR, HOLD, or MAX can be selected for the output status when conversion stops.

| Output signal range | CLR                              | HOLD                                            | MAX                              |
|---------------------|----------------------------------|-------------------------------------------------|----------------------------------|
| 0 to 10 V           | -0.5 V (Min. -5% of full scale)  | Voltage that was output just prior to stopping. | 10.5 V (Max. +5% of full scale)  |
| -10 to 10 V         | 0.0 V                            | Voltage that was output just prior to stopping. | 11.0 V (Max. +5% of full scale)  |
| 1 to 5 V            | 0.8 V (Min. -5% of full scale)   | Voltage that was output just prior to stopping. | 5.2 V (Max. +5% of full scale)   |
| 0 to 5 V            | -0.25 V (Min. -5% of full scale) | Voltage that was output just prior to stopping. | 5.25 V (Max. +5% of full scale)  |
| 4 to 20 mA          | 3.2 mA (Min. -5% of full scale)  | Current that was output just prior to stopping. | 20.8 mA (Max. +5% of full scale) |

The above values may fluctuate if offset/gain adjustment has been applied.

To set the output hold function, use a Programming Device to set the DM Area words D(m+2) to D(m+9) as shown in the following table. (See note.)

| DM Area word | Function                                      | Set value                                                                                                                                                                                                  |
|--------------|-----------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+2)      | Output 1: Output status when conversion stops | xx00:CLR<br>Output 0 or minimum value of range (–5%).<br>xx01:HOLD<br>Hold output value prior to stop.<br>xx02: MAX<br>Output maximum value of range (105%).<br>Set any value in the left-most bytes (xx). |
| D (m+3)      | Output 2: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+4)      | Output 3: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+5)      | Output 4: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+6)      | Output 5: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+7)      | Output 6: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+8)      | Output 7: Output status when conversion stops |                                                                                                                                                                                                            |
| D (m+9)      | Output 8: Output status when conversion stops |                                                                                                                                                                                                            |

- Note**
- Only D (m+2) and D (m+3) are used by the CJ1W-DA021, and only D (m+2) to D (m+5) are used by the CJ1W-DA041.
  - For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  - When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

### 6-6-5 Output Scaling (CJ1W-DA08V/08C Only)

When upper and lower limits have been preset in 16-bit binary data in the CPU Unit's DM Area within a range of –32,000 to 32,000 decimal (from 8300 to 7D00 hex), analog output set values with the upper and lower limits taken as full scale and are converted from digital to analog. (See notes 1 and 2.) This scaling function eliminates the previous necessity of providing programs for numeric conversion from specified units. It is only enabled, however, for a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 250  $\mu$ s and a resolution of 8,000).

- Note**
- To set the upper or lower limit to a negative number, use two's complement. (Set 8300 to FFF for –32,000 to –1.)
  - Addresses  $m = D20000 + \text{unit number} \times 100$  are allocated in the DM Area.
  - The upper limit is normally set to be greater than the lower limit, but it is also possible to set lower limit to be greater than the upper limit for reverse scaling.
  - Actual D/A conversion is executed at up to –5% to +105% of full scale. If values exceeding this range are set, an output setting value error will occur and the output hold function will operate.
  - When setting upper and lower limits in the DM Area in the specified units, be sure to make the settings in 16-bit binary data (with negative values set as two's complement).
  - The scaling function is enabled for only a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 250  $\mu$ s and a resolution of 8,000).
  - If the scaling upper limit equals the lower limit, or if the scaling upper limit or lower limit is outside the range of  $\pm 32,000$ , a scaling data setting error is

generated and scaling cannot be executed. Operation starts normally when both the upper and lower limits are set to 0000 (the default values).

### Setting Upper and Lower Limits for Output Scaling

Set the upper and lower limits for scaling for outputs 1 and 2 in words D (m+19) to D (m+22) of the DM Area, as shown below.

**Note** For decimal numbers –32,000 to +32,000, set 16-bit binary data (8300 to 7D00).


| DM word  | Bits                         |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
|----------|------------------------------|----|----|----|----|----|---|---|---|---|---|---|---|---|---|---|
|          | 15                           | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| D (m+19) | Output 1 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+20) | Output 1 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+21) | Output 2 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+22) | Output 2 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |

### Example Setting 1

Set the following conditions in D (m+19) to D (m+22). (The values shown in parentheses are binary data.)

| Setting condition   | Set value     |
|---------------------|---------------|
| Output signal range | 0 to 10 V     |
| Scaling lower limit | 0000 (0000)   |
| Scaling upper limit | 10,000 (2710) |

### When Output Signal Range is 0 V to 10 V



The following table shows the correspondence between output signals and converted scaling values. (The values shown in parentheses are 16-bit binary data.)

| Output set value | Output signal |
|------------------|---------------|
| 0000 (0000)      | 0 V           |
| 10,000 (2710)    | 10 V          |
| –500 (FE0C)      | –0.5 V        |
| 10,500 (2904)    | 10.5 V        |


### Example Setting 2 (Reverse Scaling)

Set the following conditions in D (m+27) to D (m+34). (The values shown in parentheses are binary data.)

| Setting condition   | Set value     |
|---------------------|---------------|
| Output signal range | 0 to 10 V     |
| Scaling lower limit | 10,000 (2710) |
| Scaling upper limit | 0000 (0000)   |



## When Output Signal Range is 0 V to 10 V (Reverse Scaling)




The following table shows the correspondence between output signals and converted scaling values. (The values shown in parentheses are 16-bit binary data.)

| Conversion result | Output signal |
|-------------------|---------------|
| 10,000 (2710)     | 0 V           |
| 0000 (0000)       | 10 V          |
| 10,500 (2904)     | -0.5 V        |
| -500 (FE0C)       | 10.5 V        |

## 6-6-6 Output Setting Errors

If the analog output set value is greater than the specified range, a setting error signal will be stored in CIO word n+9, bits 00 to 07.



When a setting error is detected for a particular output, the corresponding bit turns ON. When the error is cleared, the bit turns OFF.

- Note**
1. For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .
  2. The voltage for an output number at which a setting error has occurred will be output according to the output hold function.

## 6-7 Adjusting Offset and Gain

### 6-7-1 Adjustment Mode Operational Flow

The adjustment mode enables the output of the connected devices to be calibrated.

This function adjusts the output voltage according to the offset value and gain value at the input device, and sets the settings values at the Unit at that time to 0000 and 0FA0 (07D0 if the range is  $\pm 10$  V) respectively.

For example, suppose that the specifications range for the external input device (e.g., indicator, etc.) is 100.0 to 500.0 when using in the range 1 to 5 V. Also, suppose that when voltage is output at the Analog Output Unit at a set value of 0000, the external input device actually displays 100.5 and not 100.0. It is possible to make settings to adjust the output voltage (making it smaller in this case) so that 100.0 is displayed and to make 0000 (not FFFB as in this case) the set value for which 100.0 is displayed.


Similarly for gain values, suppose that when voltage is output at the Analog Output Unit at a set value of 0FA0, the external input device actually displays 500.5 and not 500.0. It is possible to make settings to adjust the output voltage (make it smaller in this case) so that 500.0 is displayed and to make 0FA0 (not 0F9B as in this case) the set value for which 500.0 is displayed.

| External input device display | Set value before adjustment (word n+8) | Set value after adjustment |
|-------------------------------|----------------------------------------|----------------------------|
| 100.0                         | FFFB (FFF0)                            | 0000 (0000)                |
| 500.0                         | 0F9B (1F36)                            | 0FA0 (1F40)                |

(Values in parentheses are for a resolution of 8,000.)

CJ1W-DA021/041

The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.




**Caution** Be sure to turn OFF the power to the PLC before changing the setting of the operation mode switch.

**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog Output Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog Output Unit will stop operating, and the output values that existed immediately before this stoppage will be retained.

**⚠ Caution** Always perform adjustments in conjunction with offset and gain adjustments.

**CJ1W-DA08V/08C**




**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog Output Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog Output Unit will stop operating, and the output values that existed immediately before this stoppage will be retained.

**⚠ Caution** Always perform adjustments in conjunction with offset and gain adjustments.

## 6-7-2 Output Offset and Gain Adjustment Procedures


### Specifying Output Number to be Adjusted

To specify the output number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)




### Bits Used for Adjusting Offset and Gain

The CIO word n+1 bits shown in the following diagram are used for adjusting offset and gain.



## Offset Adjustment

The procedure for adjusting the analog output offset is explained below. As shown in the following diagram, the set value is adjusted so that the analog output reaches the standard value (0 V/1 V/4 mA).



The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

1,2,3...

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0

A 0


MON

200100 ^ OFF


SET

200100 ^ ON

2. Check whether the output devices are connected.



Current output (CJ1W-DA021/041 only)



**Note** The output is current output when using a CJ1W-DA08C.

3. Monitor CIO word n+8 and check the set value while the Offset Bit is ON.

CLR

000000 CT00

SHIFT

CH  
\*DM

C 2

A 0

A 0

8

MON


2008 0000

4. Change the set value so that the output voltage are as shown in the following table. The data can be set within the indicated ranges.


| Output signal range | Possible output voltage/current adjustment | Output range                   |
|---------------------|--------------------------------------------|--------------------------------|
| 0 to 10 V           | −0.5 to 0.5 V                              | FF38 to 00C8<br>(FE70 to 0190) |
| −10 to 10 V         | −1.0 to 1.0 V                              |                                |
| 1 to 5 V            | 0.8 to 1.2 V                               |                                |
| 0 to 5 V            | −0.25 to 0.25 V                            |                                |
| 4 to 20 mA          | 3.2 to 4.8 mA                              |                                |

(Values in parentheses are for a resolution of 8,000.)


Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.



The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.

|       |              |
|-------|--------------|
| SET   | 200102 ^ ON  |
| RESET | 200102 ^ OFF |

5. Check the 0-V/1-V/4 mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| SET   |           |        |        |        |        |        |        |     |
| RESET |           |        |        |        |        |        |        |     |

|              |
|--------------|
| 200104 ^ OFF |
| 200104 ^ ON  |
| 200104 ^ OFF |

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| SET   |           |        |        |        |        |        |        |     |

|              |
|--------------|
| 200100 ^ ON  |
| 200100 ^ OFF |

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.


**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.



## Gain Adjustment

The procedure for adjusting the analog output gain is explained below. As shown in the following diagram, the set value is adjusted so that the analog output is maximized (to 10 V/5 V/20 mA).




The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)

|       |              |
|-------|--------------|
| CLR   | 000000 CT00  |
| SHIFT | CONT #       |
| C 2   | A 0          |
| A 0   | B 1          |
| A 0   | B 1          |
| MON   |              |
|       | 200101 ^ OFF |
| SET   |              |
|       | 200101 ^ ON  |

2. Check whether the output devices are connected.



**Note** The output is current output when using a CJ1W-DA08C.

3. Monitor CIO word n+8 and check the set value while the Gain Bit is ON.


|       |             |
|-------|-------------|
| CLR   | 000000 CT00 |
| SHIFT | CH *DM      |
| C 2   | A 0         |
| A 0   | 8           |
| MON   |             |
|       | 2008 0000   |

4. Change the set value so that the output voltage is as shown in the following table. The data can be set within the indicated ranges.


| Output signal range | Possible output voltage/current adjustment | Output range                |
|---------------------|--------------------------------------------|-----------------------------|
| 0 to 10 V           | 9.5 to 10.5 V                              | 0ED8 to 1068 (1DB0 to 20D0) |
| -10 to 10 V         | 9 to 11 V                                  | 0708 to 0898 (0E10 to 1130) |
| 1 to 5 V            | 4.8 to 5.2 V                               | 0ED8 to 1068 (1DB0 to 20D0) |
| 0 to 5 V            | 4.75 to 5.25 V                             | 0ED8 to 1068 (1DB0 to 20D0) |
| 4 to 20 mA          | 19.2 to 20.8 mA                            | 0ED8 to 1068 (1DB0 to 20D0) |

(Values in parentheses are for a resolution of 8,000.)

Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.

|       |              |
|-------|--------------|
| SET   | 200102 ^ ON  |
| RESET | 200102 ^ OFF |

5. Check the 10V/5V/20 mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| SET   |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| RESET |           |        |        |        |        |        |        |     |

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
|       |           |        |        |        |        |        |        |     |
| RESET |           |        |        |        |        |        |        |     |

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

**Clearing Offset and Gain Adjusted Values**

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the set value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

|     |
|-----|
| SET |
|-----|

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

|     |
|-----|
| SET |
|-----|

200104 ^ ON

|       |
|-------|
| RESET |
|-------|

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ ON

|       |
|-------|
| RESET |
|-------|

200105 ^ OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Note** The EEPROM can be overwritten 50,000 times.


## 6-8 Handling Errors and Alarms

### 6-8-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog Output Unit, the ERC or ERH indicators on the front panel of the Unit will light.


Front panel of Unit



| LED          | Meaning                | Indicator | Operating status                                           |
|--------------|------------------------|-----------|------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                  |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.        |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred or initial settings are incorrect.      |
|              |                        | Not lit   | Operating normally.                                        |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit. |
|              |                        | Not lit   | Operating normally.                                        |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                  |
|              |                        | Not lit   | Other than the above.                                      |


**Troubleshooting Procedure**

Use the following procedure for troubleshooting Analog Output Unit errors.




## 6-8-2 Alarms Occurring at the Analog Output Unit

The ERC indicator will light when the Analog Output Unit detects an alarm. The Alarm Flags in bits 08 to 15 of CIO word n+9 will turn ON.



For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

### ERC and RUN Indicators: Lit



The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| Word n + 9                     | Alarm flag                                | Error contents                                                 | Output status                                           | Countermeasure                                                                                                          |
|--------------------------------|-------------------------------------------|----------------------------------------------------------------|---------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 07<br>(See note 2.) | Output Set Value Error                    | The output setting range has been exceeded.                    | Output value set by output hold function.               | Correct the set value.                                                                                                  |
| Bit 14                         | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the output status immediately prior to the error. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog Output Unit. |


- Note**
- $n = \text{CIO } 2000 + (\text{unit number} \times 10)$
  - Only bits 00 and 01 are used for the CJ1W-DA021 and only bits 00 to 03 are used for the CJ1-DA041.

**ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing**

This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.

| Word n + 9     | Alarm flag                                       | Error contents                                                                                                                                             | Output status                                      | Countermeasure                                                                                                                                                                                                                                         |
|----------------|--------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 13         | (Adjustment mode)<br>Output Number Setting Error | In adjustment mode, adjustment cannot be performed because the specified output number is not set for use or because the wrong output number is specified. | The output voltage or current becomes 0 V or 0 mA. | Check whether the word n output number to be adjusted is set from 11 to 14.<br><br>Check whether the output number to be adjusted is set for use by means of the DM setting.                                                                           |
| Bit 15 only ON | (Adjustment Mode)<br>PLC Error                   | The PLC is in either MONITOR or RUN mode while the Analog Output Unit is operating in adjustment mode.                                                     | The output voltage or current becomes 0 V or 0 mA. | For the CJ1W-DA021 or CJ1W-DA041, set the operation mode to normal mode and restart.<br><br>For the CJ1W-DA08V/08C, set bits 00 to 07 of D(m+18) to 00 hex. Then either power up again or turn the Special I/O Unit Restart Bit ON and then OFF again. |

**Note** When a PLC error occurs in the adjustment mode, Unit operations will stop operating. (The input and output values immediately prior to the error will be held.)

**ERC Indicator: Lit, RUN Indicator: Not Lit**

The ERC indicator will be lit when the initial settings for the Analog Output Unit are not set correctly. The alarm flags for the following errors will turn ON in CIO word n+9. These alarm flags will turn OFF when the error is cleared and the power to the PLC is cycled, or the Special I/O Unit Restart Bit is turned ON and then OFF again.

| Word n + 9 | Alarm flag                                               | Error contents                                                                                                                                                       | Countermeasure                      |
|------------|----------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|
| Bit 08     | Scaling Data Setting Error                               | There is a mistake in the upper or lower limit setting when scaling is used. The setting range has been exceeded. The upper limit equals the lower limit (not 0000). | Correct the settings.               |
| Bit 10     | Output Hold Setting Error                                | The settings of the output status for when conversion is stopped is wrong.                                                                                           | Specify a number from 0000 to 0002. |
| Bit 12     | Conversion Time/Resolution, Operation Mode Setting Error | The conversion time/resolution setting or operation mode setting is incorrect.                                                                                       | Set 00 hex or 01 hex.               |


**Note** Bit 15 is normally turned OFF (i.e., set to 0).



### 6-8-3 Errors in the CPU Unit

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Output Unit from operating.

#### ERH and RUN Indicators: Lit



The ERH and RUN indicators will light if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog Output Unit.

Turn ON the power supply again or restart the system.

For further details, refer to *CJ-series CJ1G-CPU□□, CJ1G/H CPU□□H Programmable Controllers Operation Manual (W393)*.

| Error                                | Error contents                                             | Output condition                            |
|--------------------------------------|------------------------------------------------------------|---------------------------------------------|
| I/O bus error                        | Error has occurred during data exchange with the CPU Unit. | Output value set by output hold function.   |
| CPU Unit monitoring error (see note) | No response from CPU Unit for specified period of time.    | Maintains the status from before the error. |
| CPU Unit WDT error                   | Error has been generated in CPU Unit.                      | Output value set by output hold function.   |

**Note** No error will be detected by the CPU Unit or displayed on the Programming Console, because the CPU Unit is continuing operation.

#### ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number for the Analog Output Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Output condition              |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------------------|
| Duplicate Unit Number          | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | The output value will be 0 V. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                               |

## 6-8-4 Restarting Special I/O Units

To restart the Analog Output Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

### Special I/O Unit Restart Bits

| Bit    | Function             |                                                                                |
|--------|----------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit  | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit  |                                                                                |
| to     | to                   |                                                                                |
| A50215 | Unit #15 Restart Bit |                                                                                |
| A50300 | Unit #16 Restart Bit |                                                                                |
| to     | to                   |                                                                                |
| A50715 | Unit #95 Restart Bit |                                                                                |

The output becomes 0 V or 0 mA during restart.

Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

## 6-8-5 Troubleshooting

The following tables list the probable causes of troubles that may occur, and the countermeasures for dealing with them.

### Analog Output Does Not Change

| Probable Cause                                                | Countermeasure                            | Page |
|---------------------------------------------------------------|-------------------------------------------|------|
| The output is not set for being used.                         | Set the output for being used.            | 244  |
| The output hold function is in operation.                     | Turn ON the Output Conversion Enable Bit. | 248  |
| The conversion value is set outside of the permissible range. | Set the data within the range.            | 220  |

### Value Does Not Change as Intended

| Probable Cause                                                                                                                    | Countermeasure                           | Page |
|-----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------|
| The output signal range setting is wrong.                                                                                         | Correct the output signal range setting. | 245  |
| The specifications of the output device do not match those of the Analog Output Unit (e.g., input signal range, input impedance). | Change the output device.                | 219  |
| The offset or gain is not adjusted.                                                                                               | Adjust the offset or gain.               | 252  |

### Outputs Are Inconsistent

| Probable Cause                                           | Countermeasure                                                                         | Page |
|----------------------------------------------------------|----------------------------------------------------------------------------------------|------|
| The output signals are being affected by external noise. | Try changing the shielded cable connection (e.g., the grounding at the output device). | 235  |

## SECTION 7

# CJ-series Analog Output Unit (CJ1W-DA042V)

This section explains how to use the CJ1W-DA042V Analog Output Units.

|       |                                                        |     |
|-------|--------------------------------------------------------|-----|
| 7-1   | Specifications .....                                   | 270 |
| 7-1-1 | Specifications .....                                   | 270 |
| 7-1-2 | Output Function Block Diagram .....                    | 271 |
| 7-1-3 | Output Specifications .....                            | 272 |
| 7-2   | Operating Procedure .....                              | 274 |
| 7-3   | Components and Switch Settings .....                   | 278 |
| 7-3-1 | Component Names .....                                  | 278 |
| 7-3-2 | Indicators .....                                       | 279 |
| 7-3-3 | Unit Number Switches .....                             | 279 |
| 7-4   | Wiring .....                                           | 280 |
| 7-4-1 | Terminal Arrangement .....                             | 280 |
| 7-4-2 | Internal Circuitry .....                               | 280 |
| 7-4-3 | Output Wiring Example .....                            | 281 |
| 7-4-4 | Output Wiring Considerations .....                     | 282 |
| 7-5   | Exchanging Data with the CPU Unit .....                | 283 |
| 7-5-1 | Outline of Data Exchange .....                         | 283 |
| 7-5-2 | Allocations for Initial Settings Data .....            | 285 |
| 7-5-3 | I/O Refresh Data Allocations .....                     | 287 |
| 7-6   | Analog Output Functions and Operating Procedures ..... | 289 |
| 7-6-1 | Output Settings and Conversion Values .....            | 289 |
| 7-6-2 | Conversion Mode Setting .....                          | 291 |
| 7-6-3 | Output Hold Function .....                             | 292 |
| 7-6-4 | Output Scaling .....                                   | 293 |
| 7-6-5 | Output Setting Errors .....                            | 295 |
| 7-7   | Handling Errors and Alarms .....                       | 296 |
| 7-7-1 | Indicators and Error Flowchart .....                   | 296 |
| 7-7-2 | Alarms Occurring at the Analog Output Unit .....       | 298 |
| 7-7-3 | Errors in the CPU Unit .....                           | 299 |
| 7-7-4 | Restarting Special I/O Units .....                     | 300 |
| 7-7-5 | Troubleshooting .....                                  | 300 |

## 7-1 Specifications

### 7-1-1 Specifications

|                                               |                                     |                                                                               |                                                                                                                                                                                                                                                                                |                                          |                                                          |
|-----------------------------------------------|-------------------------------------|-------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|----------------------------------------------------------|
| Unit model                                    |                                     |                                                                               | CJ1W-DA042V                                                                                                                                                                                                                                                                    |                                          |                                                          |
| Unit type                                     |                                     |                                                                               | CJ-series Special I/O Unit                                                                                                                                                                                                                                                     |                                          |                                                          |
| Isolation                                     |                                     |                                                                               | Between outputs and PLC signals: Digital isolator (No isolation between output signals.) (See note 1.)                                                                                                                                                                         |                                          |                                                          |
| External terminals                            |                                     |                                                                               | 18-point detachable terminal block (M3 screws)                                                                                                                                                                                                                                 |                                          |                                                          |
| Affect on CPU Unit cycle time                 |                                     |                                                                               | CJ2 CPU Unit                                                                                                                                                                                                                                                                   | 0.05 ms                                  |                                                          |
|                                               |                                     |                                                                               | CJ1 CPU Unit                                                                                                                                                                                                                                                                   | 0.2 ms                                   |                                                          |
| Current consumption                           |                                     |                                                                               | 400 mA max. at 5 VDC                                                                                                                                                                                                                                                           |                                          |                                                          |
| Dimensions (mm) (See note 2.)                 |                                     |                                                                               | 31 × 90 × 65 (W × H × D)                                                                                                                                                                                                                                                       |                                          |                                                          |
| Weight                                        |                                     |                                                                               | 150 g max.                                                                                                                                                                                                                                                                     |                                          |                                                          |
| General specifications                        |                                     |                                                                               | Conforms to general specifications for SYSMAC CJ-series Series.                                                                                                                                                                                                                |                                          |                                                          |
| Mounting position                             |                                     |                                                                               | CJ-series CPU Rack or CJ-series Expansion Rack                                                                                                                                                                                                                                 |                                          |                                                          |
| Maximum number of Units                       |                                     |                                                                               | Per CPU Rack or Expansion Rack (See note 3.)                                                                                                                                                                                                                                   | Power Supply Unit                        | No. of mountable Units                                   |
|                                               |                                     |                                                                               |                                                                                                                                                                                                                                                                                | CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025 | CPU Rack: 10 Units/Rack<br>Expansion Rack: 10 Units/Rack |
|                                               |                                     |                                                                               |                                                                                                                                                                                                                                                                                | CJ1W-PA202                               | CPU Rack: 5 Units/Rack<br>Expansion Rack: 6 Units/Rack   |
|                                               |                                     |                                                                               |                                                                                                                                                                                                                                                                                | CJ1W-PD022                               | CPU Rack: 3 Units/Rack<br>Expansion Rack: 4 Units/Rack   |
| Data exchange with the CPU Unit (See note 4.) |                                     |                                                                               | Special I/O Unit Area in CIO Area (CIO 2000 to CIO 2959): 10 words/Unit<br>Special I/O Unit Area in DM Area (D20000 to D29599): 100 words/Unit                                                                                                                                 |                                          |                                                          |
| Output specifications                         | Number of analog outputs            |                                                                               | 4                                                                                                                                                                                                                                                                              |                                          |                                                          |
|                                               | Output signal range (See note 5.)   |                                                                               | 1 to 5 V<br>0 to 10 V<br>–10 to 10 V                                                                                                                                                                                                                                           |                                          |                                                          |
|                                               | Output impedance                    |                                                                               | 0.5 Ω max.                                                                                                                                                                                                                                                                     |                                          |                                                          |
|                                               | Maximum permissible load resistance |                                                                               | 5 kΩ min. (per output)                                                                                                                                                                                                                                                         |                                          |                                                          |
|                                               | Resolution                          |                                                                               | 1 to 5 V                                                                                                                                                                                                                                                                       | 1/10,000 (full scale)                    |                                                          |
|                                               |                                     |                                                                               | 0 to 10 V                                                                                                                                                                                                                                                                      | 1/20,000(full scale)                     |                                                          |
|                                               |                                     |                                                                               | –10 to 10 V                                                                                                                                                                                                                                                                    | 1/40,000(full scale)                     |                                                          |
|                                               | Set data                            |                                                                               | 16-bit binary data                                                                                                                                                                                                                                                             |                                          |                                                          |
|                                               | Accuracy                            | 25°C                                                                          | ±0.3% (full scale)                                                                                                                                                                                                                                                             |                                          |                                                          |
|                                               |                                     | 0 to 55°C                                                                     | ±0.5% (full scale)                                                                                                                                                                                                                                                             |                                          |                                                          |
| Conversion period (See note 6.)               |                                     | 20 μs for 1 point, 25 μs for 2 points, 30 μs for 3 points, 35 μs for 4 points |                                                                                                                                                                                                                                                                                |                                          |                                                          |
| Output functions                              | Output hold function                |                                                                               | Outputs the specified output status (CLR, HOLD, or MAX) under any of the following circumstances.<br>• When the Conversion Enable Bit is OFF. (See note 7.)<br>• When there is an output setting error or a fatal error occurs at the PLC.<br>• When all loads are turned OFF. |                                          |                                                          |
|                                               | Scaling                             |                                                                               | Setting values in any specified unit within a range of ±32,000 as the upper and lower limits allows D/A conversion to be executed and analog signals to be output with these values as full scale.                                                                             |                                          |                                                          |
|                                               | Direct conversion                   |                                                                               | The output set value refreshed and D/A conversion is performed immediately when the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed.<br><br>A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion.                    |                                          |                                                          |

**Note** 1. Do not apply a voltage higher than 600 V to the terminal block when per-


forming withstand voltage test on this Unit. Otherwise, internal elements may deteriorate.

2. Refer to page 441 for Unit dimensions.
3. This is the maximum number of Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP). The maximum number of Analog Output Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack.
4. Data exchange methods with the CPU Unit are as follows:

|                                                                                   |                                                       |                                |                                                                                                                                                                                                                                                      |
|-----------------------------------------------------------------------------------|-------------------------------------------------------|--------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Special I/O Unit Area in CIO Area<br>CIO 2000 to CIO 2959<br>(2000.00 to 2959.15) | 10 words transferred per Unit                         | CPU Unit to Analog Output Unit | <ul style="list-style-type: none"> <li>• Set value</li> <li>• Conversion enable bits</li> </ul>                                                                                                                                                      |
|                                                                                   |                                                       | Analog Output Unit to CPU Unit | <ul style="list-style-type: none"> <li>• Alarm Flags</li> </ul>                                                                                                                                                                                      |
| Special I/O Unit Area in DM Area (D20000 to D29599)                               | 100 words per Unit refreshed at power ON and restarts | CPU Unit to Analog Output Unit | <ul style="list-style-type: none"> <li>• Number of analog outputs used</li> <li>• Conversion mode setting</li> <li>• Output signal range setting</li> <li>• Output status when conversion stops</li> <li>• Scaling lower and upper limits</li> </ul> |

5. Output signal range can be set for each output.
6. D/A conversion time is the time required for converting and outputting the PLC data. With direct conversion, data can be exchanged with the PLC and D/A conversion can be performed within the processing time of the ANALOG OUTPUT DIRECTION CONVERSION (AODC) instruction. It takes at least one cycle for the data stored in the PLC to be transferred to the Analog Output Unit in Cyclic Conversion Mode.
7. When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Output Conversion Enable Bit will turn OFF. The output status specified for the output hold function will be output. In Direct Conversion Mode, the set value specified with the ANALOG OUTPUT DIRECT CONVERSIONS (AODC) instruction will be output in RUN or MONITOR mode even if the Output Conversion Enable Bit is OFF.


## 7-1-2 Output Function Block Diagram




### 7-1-3 Output Specifications

If the set value is outside the specified range given below, an output setting error will occur, and the output specified by the output hold function will be output.


#### Range: 1 to 5 V



#### Range: 0 to 10 V



Range: -10 to 10 V



**Note** The conversion values for a range of -10 to 10 V will be as follows (for a resolution of 40,000):

| 16-bit binary data | BCD     |
|--------------------|---------|
| AA10               | -22,000 |
| :                  | :       |
| FFFF               | -1      |
| 0000               | 0       |
| 0001               | 1       |
| :                  | :       |
| 55F0               | 22,000  |

## 7-2 Operating Procedure

Follow the procedures outlined below when using the Analog Output Unit.

### Installation and Settings


- 1,2,3...**
1. Use the unit number switches on the front panel of the Unit to set the unit number.
  2. Wire the Unit.
  3. Turn ON the power to the PLC.
  4. Create the I/O tables.
  5. Make the Special I/O Unit settings in the DM Area.
    - Set the number of analog outputs to be used.
    - Set the conversion mode.
    - Set the output signal ranges.
    - Set the output hold function.
    - Set upper and lower limits for scaling.
  6. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

### Operation

- 1,2,3...**
1. Ladder program
    - Write set values by means of MOV(021) and XFER(070).
    - Start and stop conversion outputs.
    - Obtain error flags.

### Procedure Example

An example application procedure is given below.




\* In Cyclic Conversion Mode, D/A conversion is performed once each conversion cycle, the same way as it is for the CJ1W-DA021/-DA041/-DA08V/-DA08C.




## Setting the Analog Output Unit

- 1,2,3... 1. Set the unit number switches. (Refer to page 277.)



If the unit number is set to 1, words CIO 2010 to CIO 2019 in the Special I/O Unit Area in the CIO Area and words D20100 to D20199 in the Special I/O Unit Area in the DM Area will be allocated to the Analog Output Unit.


2. Connect and wire the Analog Output Unit. (Refer to pages 12, 280, and 281.)



3. Turn ON the power to the PLC.

## Creating I/O Tables

After turning ON the power to the PLC, be sure to create the I/O tables.




## Initial Data Settings

- 1,2,3... 1. Specify the Special I/O Unit settings in the DM Area. (Refer to page 285.)


## Setting Examples

- Unit number: 1
- Cyclic Conversion Mode
- Analog output 1: 1 to 5 V  
Analog output 2: 1 to 5 V  
Analog output 3: –10 to –10 V  
Analog output 4: Not used.

- a) Set the number of analog outputs to use. (Refer to page 289.)




- b) Set the conversion mode. (Refer to page 291.)




- c) Output Signal Range Settings (Refer to page 289.)


1. Output Signal Range Setting for Output 1



2. Output Signal Range Setting for Output 2




3. Output Signal Range Setting for Output 3



2. Cycle the power to the PLC.

Creating Ladder Programs




The contents of the specified address, D00200, is stored in words (n + 1) to (n + 3) of the Special I/O Unit Area (CIO 2011 to CIO 2013) as a signed binary value.

■ Analog Outputs


| Output number | Output signal range | Address of output set value<br>(n = CIO 2010)<br>(See note 1.) | Conversion source address<br>(See note 2.) |
|---------------|---------------------|----------------------------------------------------------------|--------------------------------------------|
| 1             | 1 to 5 V            | n+1 = CIO 2011                                                 | D00200                                     |
| 2             | 1 to 5 V            | n+2 = CIO 2012                                                 | D00201                                     |
| 3             | −10 to 10 V         | n+3 = CIO 2013                                                 | D00202                                     |
| 4             | Not used.           | ---                                                            | ---                                        |

- Note**
1. The addresses are determined by the unit number of the Special I/O Unit. (Refer to page 279.)
  2. Set as required.




## 7-3 Components and Switch Settings

### 7-3-1 Component Names



- Note**
1. The terminal block is attached using a connector. It can be removed by lowering the lever at the bottom of the terminal block.
  2. The lever must normally be in the raised position. Confirm this before operation.



## 7-3-2 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| Indicator   | Meaning                | Indicator status | Operating status                                           |
|-------------|------------------------|------------------|------------------------------------------------------------|
| RUN (green) | Operating              | Lit              | Operation normal.                                          |
|             |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.        |
| ERC (red)   | Error detected by Unit | Lit              | Initial settings are incorrect.                            |
|             |                        | Not lit          | Operating normally.                                        |
| ERH (red)   | Errors in the CPU Unit | Lit              | Error has occurred during data exchange with the CPU Unit. |
|             |                        | Not lit          | Operating normally.                                        |

## 7-3-3 Unit Number Switches

The CPU Unit and Analog Output Unit exchange data via the Special I/O Unit Areas in the CIO Area and DM Area. The words that are allocated to each Analog Output Unit in the Special I/O Unit Areas in the CIO Area and DM Area are determined by the setting of the unit number switches on the front panel of the Unit.

Unit number switches




| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | 0           | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | 1           | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | 2           | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | 3           | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | 4           | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | 5           | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | 6           | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | 7           | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | 8           | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | 9           | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | 10          | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | n           | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | 95          | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

## 7-4 Wiring

**⚠ Caution** Always connect surge suppressors to inductive loads in the system (e.g., magnetic contactors, relays, and solenoids). Always separate devices that generate surge from the Analog I/O Units. Faulty Unit operation may cause unexpected system operation.

If inductive loads are connected to output signals from Relay Contact Output Units, connect a surge suppressor in an AC circuit and a diode in a DC circuit close to the inductive load to absorb the back electromotive force.



Connect a surge suppressor in an AC circuit and a diode in a DC circuit.

### 7-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.


|              |    |    |              |
|--------------|----|----|--------------|
| Output 2 (+) | B1 | A1 | Output 1 (+) |
| Output 2 (-) | B2 | A2 | Output 1 (-) |
| N.C.         | B3 | A3 | N.C.         |
| Output 4 (+) | B4 | A4 | Output 3 (+) |
| Output 4 (-) | B5 | A5 | Output 3 (-) |
| N.C.         | B6 | A6 | N.C.         |
| N.C.         | B7 | A7 | N.C.         |
| N.C.         | B8 | A8 | N.C.         |
| N.C.         | B9 | A9 | N.C.         |

- Note**
1. The number of analog outputs that can be used is set in the DM Area.
  2. The output signal ranges for individual outputs are set in the DM Area. The output signal range can be set separately for each output.
  3. Do not make any connections to the N.C. terminals.


### 7-4-2 Internal Circuitry

The following diagrams show the internal circuitry of the analog output section.


#### Output circuits




## Internal Configuration



## 7-4-3 Output Wiring Example



**Note** Crimp terminals must be used for terminal connections, and the screws must be tightened securely. M3 terminal screws are used. The applicable tightening torque is 0.5 N·m.



**Note** To increase noise resistance for analog output wiring, ground the shield on the output signal cable at the output device.

### 7-4-4 Output Wiring Considerations

When wiring outputs, apply the following points to avoid noise interference and optimize Analog Output Unit performance.

- Use two-core shielded twisted-pair cables for output connections.
- Route output cables separately from power cables (e.g., AC and three-phase lines), and do not place them in the same duct with power cables.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby), install a noise filter at the power supply input area.



## 7-5 Exchanging Data with the CPU Unit

### 7-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the CJ1W-DA042V Analog Output Unit via the Special I/O Unit Area in the CIO Area (for data used to operate the Unit) and the Special I/O Unit Area in the DM Area (for data used for initial settings).

#### ■ I/O Refresh Data

Analog output set values, which are used as data for Unit operation, are allocated in the Special I/O Unit Area in the CIO Area of the CPU Unit according to the unit number. These values are updated during I/O refreshing.

#### ■ Initial Settings Data



The Unit's initial settings data, such as the analog output signal ranges and the output status when conversion stops, is allocated in the Special I/O Unit Area in the DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.



## Unit Number Setting

The words in the Special I/O Unit Areas in the CIO Area and DM Area that are allocated to each Analog Output Unit are determined by the setting of the unit number switches on the front panel of the Unit.

Unit number switches



| Switch setting | Unit number | Words allocated in Special I/O Unit Area in CIO Area | Words allocated in Special I/O Unit Area in DM Area |
|----------------|-------------|------------------------------------------------------|-----------------------------------------------------|
| 0              | 0           | CIO 2000 to CIO 2009                                 | D20000 to D20099                                    |
| 1              | 1           | CIO 2010 to CIO 2019                                 | D20100 to D20199                                    |
| 2              | 2           | CIO 2020 to CIO 2029                                 | D20200 to D20299                                    |
| 3              | 3           | CIO 2030 to CIO 2039                                 | D20300 to D20399                                    |
| 4              | 4           | CIO 2040 to CIO 2049                                 | D20400 to D20499                                    |
| 5              | 5           | CIO 2050 to CIO 2059                                 | D20500 to D20599                                    |
| 6              | 6           | CIO 2060 to CIO 2069                                 | D20600 to D20699                                    |
| 7              | 7           | CIO 2070 to CIO 2079                                 | D20700 to D20799                                    |
| 8              | 8           | CIO 2080 to CIO 2089                                 | D20800 to D20899                                    |
| 9              | 9           | CIO 2090 to CIO 2099                                 | D20900 to D20999                                    |
| 10             | 10          | CIO 2100 to CIO 2109                                 | D21000 to D21099                                    |
| to             | to          | to                                                   | to                                                  |
| n              | n           | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9       | D20000 + (n × 100) to D20000 + (n × 100) + 99       |
| to             | to          | to                                                   | to                                                  |
| 95             | 95          | CIO 2950 to CIO 2959                                 | D29500 to D29599                                    |

**Note** If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

## Special I/O Unit Restart Bits

To restart the Analog Output Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

### ■ Special I/O Unit Restart Bits


| Bit     | Function                |                                   |
|---------|-------------------------|-----------------------------------|
| A502.00 | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON. |
| A502.01 | Unit No. 1 Restart Bit  |                                   |
| to      | to                      |                                   |
| A502.15 | Unit No. 15 Restart Bit |                                   |
| A503.00 | Unit No. 16 Restart Bit |                                   |
| to      | to                      |                                   |
| A507.15 | Unit No. 95 Restart Bit |                                   |

**Note** Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.

## 7-5-2 Allocations for Initial Settings Data

### DM Area

The initial settings of the Analog Output Unit are set according to the data allocated in the Special I/O Unit Area in the DM Area. Settings, such as the number of outputs used and the analog output signal ranges, must be set in this area.



- Note**
1. The words in the Special I/O Unit Area in the DM Area that are allocated to the Analog Output Unit are set using the unit number switches on the front panel of the Unit. (Refer to page 284.)
  2. If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

### Allocations in DM Area

The following table shows the allocation of DM Area words and bits.

| DM Area word<br>(See note.) | Bits                                         |    |    |    |    |    |    |    |    |                                                                                      |    |    |                                |    |    |    |
|-----------------------------|----------------------------------------------|----|----|----|----|----|----|----|----|--------------------------------------------------------------------------------------|----|----|--------------------------------|----|----|----|
|                             | 15                                           | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06                                                                                   | 05 | 04 | 03                             | 02 | 01 | 00 |
| D (m)                       | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    |    |                                                                                      |    |    | Number of analog out-puts used |    |    |    |
| D (m+1)                     | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    |    | Conversion mode<br>00 hex: Cyclic Conversion Mode,<br>A5 hex: Direct Conversion Mode |    |    |                                |    |    |    |
| D (m+2)                     | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    |    | Output 1 output signal range setting                                                 |    |    |                                |    |    |    |
| D (m+3)                     | Output 1 output status when conversion stops |    |    |    |    |    |    |    |    |                                                                                      |    |    |                                |    |    |    |
| D (m+4)                     | Output 1 scaling lower limit                 |    |    |    |    |    |    |    |    |                                                                                      |    |    |                                |    |    |    |
| D (m+5)                     | Output 1 scaling upper limit                 |    |    |    |    |    |    |    |    |                                                                                      |    |    |                                |    |    |    |

| DM Area word<br>(See note.) | Bits                                         |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
|-----------------------------|----------------------------------------------|----|----|----|----|----|----|----|--------------------------------------|----|----|----|----|----|----|----|
|                             | 15                                           | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07                                   | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D (m+6)                     | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    | Output 2 output signal range setting |    |    |    |    |    |    |    |
| D (m+7)                     | Output 2 output status when conversion stops |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+8)                     | Output 2 scaling lower limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+9)                     | Output 2 scaling upper limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+10)                    | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    | Output 3 output signal range setting |    |    |    |    |    |    |    |
| D (m+11)                    | Output 3 output status when conversion stops |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+12)                    | Output 3 scaling lower limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+13)                    | Output 3 scaling upper limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+14)                    | Not used. (Settings are ignored.)            |    |    |    |    |    |    |    | Output 4 output signal range setting |    |    |    |    |    |    |    |
| D (m+15)                    | Output 4 output status when conversion stops |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+16)                    | Output 4 scaling lower limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |
| D (m+17)                    | Output 4 scaling upper limit                 |    |    |    |    |    |    |    |                                      |    |    |    |    |    |    |    |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$


#### ■ Set Values and Stored Values

| Setting                                     | Contents                                                                                                                                                                                                              | Page |
|---------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Number of analog outputs used (See note 1.) | 0: No outputs used.<br>1: One output used (output 1 used).<br>2: Two outputs used (outputs 1 and 2 used).<br>3: Three outputs used (outputs 1, 2, and 3 used).<br>4: Four outputs used (outputs 1, 2, 3, and 4 used). | 289  |
| Conversion mode setting                     | 00 hex: Cyclic Conversion Mode<br>A5 hex: Direct Conversion Mode (See note 2.)                                                                                                                                        | 291  |
| Output signal range                         | 1: 0 to 10 V<br>3: -10 to 10 V<br>6: 1 to 5 V                                                                                                                                                                         | 289  |
| Output status when conversion stops         | 0: CLR Outputs 0 or minimum value of output range (See note 3.).<br>1: HOLD Holds output value prior to stop.<br>2: MAX Outputs maximum value of range                                                                | 292  |
| Scaling settings                            | Any value other than 0 within range of $\pm 32,000$ (8300 hex to 7D00 hex) as long as the upper limit is not equal to the lower limit.                                                                                | 293  |

- Note**
- Output numbers that are not to be used (set to 0) will be output at 0 V.
  - A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion. Direct conversion is not supported by CJ1 CPU Units.
  - The values output for the signal ranges will be 0 V for the range of  $\pm 10$  V, and the minimum value for the other ranges. (Refer to page 292.)

### 7-5-3 I/O Refresh Data Allocations

I/O refresh data for the Analog Output Unit is exchanged according to the allocations in the Special I/O Unit Area.



- Note**
1. The Special I/O Unit Area words that are occupied by the Analog Output Unit are set using the unit number switches on the front panel of the Unit. (Refer to page 279 for details on the method used to set the unit number switches.)
  2. If two or more Special I/O Units are assigned the same unit number, a Unit Number Duplication Error will occur (A401.13 will turn ON) and the PLC will not operate.

#### Allocations in CIO Area

The allocations of words and bits in the CIO Area for Cyclic Conversion Mode are shown in the following table. In Direct Conversion Mode, the Conversion Enable Bits and Output Setting Error Flags are not used.

| I/O                                               | Word      | Bits               |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|---------------------------------------------------|-----------|--------------------|----|----|----|-----------------|----|----|----|-----------------|----|----|----|------------------------|----|----|----|
|                                                   |           | 15                 | 14 | 13 | 12 | 11              | 10 | 09 | 08 | 07              | 06 | 05 | 04 | 03                     | 02 | 01 | 00 |
| Outputs<br>(CPU Unit to<br>Analog Output<br>Unit) | n         | Not used.          |    |    |    |                 |    |    |    |                 |    |    |    | Conversion Enable Bits |    |    |    |
|                                                   |           |                    |    |    |    |                 |    |    |    | Out-<br>put 4   |    |    |    | Out-<br>put 3          |    |    |    |
|                                                   | n+1       | Output 1 set value |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   |           | 16 <sup>3</sup>    |    |    |    | 16 <sup>2</sup> |    |    |    | 16 <sup>1</sup> |    |    |    | 16 <sup>0</sup>        |    |    |    |
|                                                   | n+2       | Output 2 set value |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   | n+3       | Output 3 set value |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   | n+4       | Output 4 set value |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   | n+5       | Not used.          |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   | n+6       | Not used.          |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
|                                                   | n+7       | Not used.          |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |
| n+8                                               | Not used. |                    |    |    |    |                 |    |    |    |                 |    |    |    |                        |    |    |    |

| I/O                                     | Word | Bits        |    |    |    |    |    |    |    |           |    |    |    |                           |           |           |           |
|-----------------------------------------|------|-------------|----|----|----|----|----|----|----|-----------|----|----|----|---------------------------|-----------|-----------|-----------|
|                                         |      | 15          | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07        | 06 | 05 | 04 | 03                        | 02        | 01        | 00        |
| Inputs (Analog Output Unit to CPU Unit) | n+9  | Alarm Flags |    |    |    |    |    |    |    | Not used. |    |    |    | Output Setting Error Bits |           |           |           |
|                                         |      |             |    |    |    |    |    |    |    |           |    |    |    | Out-put 4                 | Out-put 3 | Out-put 2 | Out-put 1 |

- For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

#### ■ Set Values and Stored Values

| Setting                  | Contents                                                                             | Yes: Settable or usable<br>No: Not settable or usable |                        | Page |
|--------------------------|--------------------------------------------------------------------------------------|-------------------------------------------------------|------------------------|------|
|                          |                                                                                      | Cyclic Conversion Mode                                | Direct Conversion Mode |      |
| Conversion Enable Bit    | 0: Conversion outputs stopped.<br>1: Conversion outputs started.                     | Yes                                                   | No                     | 290  |
| Set value                | 16-bit binary data                                                                   | Yes                                                   | Yes<br>(See note.)     | 289  |
| Output Setting Error Bit | 0: No error<br>1: Output setting error                                               | Yes                                                   | No                     | 295  |
| Alarm Flags              | Bits 00 to 03: Output setting error                                                  | Yes                                                   | No                     | 298  |
|                          | Bits 04 to 07: Not used.                                                             | Not used.                                             |                        |      |
|                          | Bit 08: Scaling data setting error                                                   | Yes                                                   | Yes                    |      |
|                          | Bit 09: Output signal range setting error or error in number of outputs used setting | Yes                                                   | Yes                    |      |
|                          | Bit 10: Output hold setting error                                                    | Yes                                                   | Yes                    |      |
|                          | Bit 11: Not used                                                                     | Not used.                                             |                        |      |
|                          | Bit 12: Error in setting of conversion mode                                          | Yes                                                   | Yes                    |      |
|                          | Bit 13: Direct Conversion Mode                                                       | Yes                                                   | Yes                    |      |
|                          | Bits 14 to 15: Not used                                                              | Not used.                                             |                        |      |


**Note** D/A conversion is performed for the set value when the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed.

## 7-6 Analog Output Functions and Operating Procedures

### 7-6-1 Output Settings and Conversion Values

#### Number of Analog Outputs Used

The Analog Output Unit performs conversion processing only for the specified number of analog outputs. To specify the number of analog outputs, use a Programming Device to set word m in the DM Area as shown in the following diagram.



$$m = 20000 + (\text{unit number} \times 100)$$


- 0: No outputs used.
- 1: One output used (output 1 used).
- 2: Two outputs used (outputs 1 and 2 used).
- 3: Three outputs used (outputs 1, 2, and 3 used).
- 4: Four outputs used (outputs 1, 2, 3, and 4 used).

- In Cyclic Conversion Mode, the conversion period for analog outputs can be made shorter by setting fewer analog outputs. 20  $\mu$ s for 1 point, 25  $\mu$ s for 2 points, 30  $\mu$ s for 3 points, 35  $\mu$ s for 4 points
- Output numbers that are not to be used (set to 0) will be output at 0 V.

#### Output Signal Range

Each of outputs 1 to 4 can be set to one of the following output signal ranges: 1 to 5 V, 0 to 10 V, or -10 to 10 V.

To specify the output signal range for each output, use a Programming Device to set words m+2, m+6, m+10, and m+14 in the DM Area as shown in the following diagram.



- 1: 0 to 10 V
- 3: -10 to 10 V
- 6: 1 to 5 V

**Note** When data memory settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or set the Special I/O Unit Restart Bit to ON. The contents of the data memory settings will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

#### Writing Set Values

Analog output set values are written to CIO words n+1 to n+4.


| Word | Contents           |
|------|--------------------|
| n+1  | Output 1 set value |
| n+2  | Output 2 set value |
| n+3  | Output 3 set value |
| n+4  | Output 4 set value |

- For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

Use MOV(021) or XFER(070) to write values in the user program.


### Example 1

In this example, the set value from only one output is written. (The unit number is 0.)



### Example 2


In this example, multiple set values are written. (The unit number is #0.)



**Note** If the set value has been written outside the specified range, an output setting error will occur and the value set by the output hold function will be output.

## Starting and Stopping Conversion

To begin analog output conversion in Cyclic Conversion Mode, turn ON the corresponding Conversion Enable Bit (word n, bits 00 to 03) from the user's program.




$$n = \text{CIO } 2000 + (\text{unit number} \times 10)$$

- Note**
1. To perform analog output conversion in Direct Conversion Mode, execute the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction in the user's program. (Refer to page 291.)
  2. The analog output when conversion is stopped depends on the output signal range setting and output hold setting. (Refer to pages 289 and 292.)
  3. Conversion will not begin under the following conditions even if the Conversion Enable Bit is turned ON. (Refer to page 292.)
    1. When there is an output setting error.
    2. When a fatal error occurs in the PLC.
  4. When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, the Conversion Enable Bits will all turn OFF. They will also turn OFF when the power supply to the PLC is turned ON. The output status at this time depends on the output hold function.



**Example:** In this example, conversion is begun for analog output number 1. (The unit number is 0.)




## 7-6-2 Conversion Mode Setting

Bits 00 to 07 in DM word m+1 can be used to set the conversion mode. The conversion mode that is set determines the timing of refreshing analog output values. This setting applies to analog outputs 1 to 4. There are not individual settings for each output.

The following table describes the conversion modes that can be set.

| Conversion mode        | Operation                                                                                                                                                                                                                                                                                                                                                                                      | Features                                                                                                                                                                                                                                                                                                            | Remarks                                                                                          |
|------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------|
| Cyclic Conversion Mode | Output set values are refreshed during the I/O refresh period. Each conversion period, the refreshed set values are converted to analog values and output. It takes at least one cycle for the data set in the PLC to be transferred to the Analog Output Unit.                                                                                                                                | Operation is the same as that of the CJ1W-DA021/-DA041/-DA08V/-DA08C Analog Output Units.                                                                                                                                                                                                                           | This is the default setting.                                                                     |
| Direct Conversion Mode | The output set values are refreshed and D/A conversion is performed immediately when the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed in the CPU Unit. The set values are not refreshed unless the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed. If the CPU Unit is in PROGRAM mode, the set values are automatically output using Cyclic Conversion Mode. | AODC can be used together with the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction for the CJ1W-AD042 Analog Input Unit to create a consistent input-processing-output time. If these instructions are used in a scheduled interrupt task, a constant and consistent input-processing-output time can be created. | A CJ2H-CPU□□(-EIP) CPU Unit with unit version 1.1 or later is required to use direct conversion. |

To specify the conversion mode, use a Programming Device to set the bits in DM word (m+1) as shown in the following diagram.



$$m = 20000 + (\text{unit number} \times 100)$$


00 hex: Cyclic Conversion Mode  
A5 hex: Direct Conversion Mode

- Note**
- When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.


2.

**Example**

In this example, the set value for analog output 1 is output in Direct Conversion Mode. (The unit number is 0.)

**Example**

In this example, the set value for analog outputs 1 to 4 are output in Direct Conversion Mode. (The unit number is 0.)



The ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is used in Direct Conversion Mode.

3. Refer to the *CS/CJ/NSJ-series Instruction Reference Manual* (Cat. No. W474) for information on the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction.
4. In Direct Conversion Mode, the set value specified with the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction will be output in RUN or MONITOR mode even if the Output Conversion Enable Bit is OFF.
5. Refer to page 481 for the instruction execution times for the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction.

### 7-6-3 Output Hold Function

The Analog Output Unit stops conversion under the following conditions and outputs the value set for the output hold function.

**1,2,3...**

1. When the Conversion Enable Bit is OFF in Cyclic Conversion Mode (Refer to page 289.)
2. When there is an output setting error. (Refer to page 295.)
3. When a fatal error occurs in the PLC.
4. When there is an I/O bus error.
5. When all loads are turned OFF from the CPU Unit  
In Direct Conversion Mode, the values set for the output hold function will be output after the loads are enabled again and until the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed.
6. When there is a WDT (watchdog timer) error in the CPU Unit.
7. When the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is executed in Direct Conversion Mode and the written set value is out of range.

CLR, HOLD, or MAX can be selected for the output status when conversion stops.

| Output signal range | CLR                       | HOLD                                            | MAX                      |
|---------------------|---------------------------|-------------------------------------------------|--------------------------|
| 1 to 5 V            | 0.8 V (–5% (full scale))  | Voltage that was output just prior to stopping. | 5.2 V (5% (full scale))  |
| 0 to 10 V           | –0.5 V (–5% (full scale)) | Voltage that was output just prior to stopping. | 10.5 V (5% (full scale)) |
| –10 to 10 V         | 0.0 V                     | Voltage that was output just prior to stopping. | 11.0 V (5% (full scale)) |

To set the output hold function, use a Programming Device to set DM Area as shown in the following diagram.

| DM Area word (See note.) | Function                                      | Set value                                                                                                                                                |
|--------------------------|-----------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+3)                  | Output 1: Output status when conversion stops | 0: CLR<br>Outputs 0 or minimum value of range (–5%).<br>1: HOLD<br>Holds output value prior to stop.<br>2: MAX<br>Outputs maximum value of range (105%). |
| D (m+7)                  | Output 2: Output status when conversion stops |                                                                                                                                                          |
| D (m+11)                 | Output 3: Output status when conversion stops |                                                                                                                                                          |
| D (m+15)                 | Output 4: Output status when conversion stops |                                                                                                                                                          |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**Note** When DM Area settings have been carried out using a Programming Device, be sure to either cycle the power supply to the PLC, or turn ON the Special I/O Unit Restart Bit. The contents of the initial settings in the DM Area will be transferred to the Special I/O Unit when the power is turned ON or the Special I/O Unit Restart Bit is turned ON.

## 7-6-4 Output Scaling

When upper and lower limits have been preset in 16-bit binary data in the CPU Unit's DM Area within a range of –32,000 to 32,000 decimal (from 8300 to 7D00 hex), analog output set values (in user-specified units) with the upper and lower limits taken as full scale are converted from digital to analog. (See note.)

This scaling function eliminates the previous necessity of providing programs for numeric conversion to specified units.

**Note** To set the upper or lower limit to a negative number, use two's complement. (Set 8300 to FFFF hex for –32,000 to –1.)

- Note**
1. The upper limit is normally set to be greater than the lower limit, but it is also possible to set lower limit to be greater than the upper limit for reverse scaling.
  2. Actual D/A conversion is executed at up to –5% to +105% of full scale. If values exceeding this range are set, an output setting value error will occur and the output hold function will operate.
  3. When setting upper and lower limits in the DM Area in the specified units, be sure to make the settings in 16-bit binary data (with negative values set as two's complement).

4. If the scaling upper limit equals the lower limit, or if the scaling upper limit or lower limit is outside the range of  $\pm 32,000$ , a scaling data setting error occurs and scaling will not be performed. Scaling will not be performed but operation will be normal when both the upper and lower limits are set to 0000 (the default values).

### Setting Upper and Lower Limits for Output Scaling

Set the upper and lower limits for scaling for outputs 1 to 4 in the following DM Area words.

| DM Area word | Bits                         |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|--------------|------------------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|              | 15                           | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| DM (m+4)     | Output 1 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+5)     | Output 1 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+8)     | Output 2 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+9)     | Output 2 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+12)    | Output 3 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+13)    | Output 3 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+16)    | Output 4 scaling lower limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| DM (m+17)    | Output 4 scaling upper limit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

$$m = 20000 + (\text{unit number} \times 100)$$


**Note** For decimal numbers  $-32,000$  to  $32,000$ , set 16-bit binary data (8300 to 7D00 hex).

### Example Setting 1

For this example, the following conditions are set in the DM Area.

| Conditions          | The values shown in parentheses are 16-bit binary data. |
|---------------------|---------------------------------------------------------|
| Output signal range | 0 to 10 V                                               |
| Scaling lower limit | 0 (0000 hex)                                            |
| Scaling upper limit | 10,000 (2710 hex)                                       |

The following diagram shows the correspondence between output signals and converted scaling values.




| The values shown in parentheses are 16-bit binary data. | Output signal |
|---------------------------------------------------------|---------------|
| 0 (0000 hex)                                            | 0 V           |
| 10,000 (2710 hex)                                       | 10 V          |
| -500 (FE0C hex)                                         | -0.5 V        |
| 10,500 (2904 hex)                                       | 10.5 V        |

**Example Setting 2 (Reverse Scaling)**

For this example, the following conditions are set in the DM Area.

| Conditions          | The values shown in parentheses are 16-bit binary data. |
|---------------------|---------------------------------------------------------|
| Output signal range | 0 to 10 V                                               |
| Scaling lower limit | 10,000 (2710 hex)                                       |
| Scaling upper limit | 0 (0000 hex)                                            |


The following diagram shows the correspondence between output signals and converted scaling values.



| The values shown in parentheses are 16-bit binary data. | Output signal |
|---------------------------------------------------------|---------------|
| 10,000 (2710 hex)                                       | 0 V           |
| 0 (0000 hex)                                            | 10 V          |
| 10,500 (2904 hex)                                       | -0.5 V        |
| -500 (FE0C hex)                                         | 10.5 V        |

**7-6-5 Output Setting Errors**

If the analog output set value is greater than the specified range in Cyclic Conversion Mode, the corresponding flag in CIO word n+9, bits 00 to 03 will be turned ON to indicate a setting error.



$$n = \text{CIO } 2000 + (\text{unit number} \times 10)$$

**Note** The voltage for an output number at which a setting error has occurred will be output according to the output hold function.


## 7-7 Handling Errors and Alarms

### 7-7-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog Output Unit, the ERC or ERH indicator on the front panel of the Unit will light.


Front panel of Unit



| Indicator   | Meaning                | Indicator status | Operating status                                           |
|-------------|------------------------|------------------|------------------------------------------------------------|
| RUN (green) | Operating              | Lit              | Operation normal.                                          |
|             |                        | Not lit          | Unit has stopped exchanging data with the CPU Unit.        |
| ERC (red)   | Error detected by Unit | Lit              | Alarm has occurred or initial settings are incorrect.      |
|             |                        | Not lit          | Operating normally.                                        |
| ERH (red)   | Error in the CPU Unit  | Lit              | Error has occurred during data exchange with the CPU Unit. |
|             |                        | Not lit          | Operating normally.                                        |


**Troubleshooting Procedure**

Use the following procedure for troubleshooting Analog Output Unit errors.




## 7-7-2 Alarms Occurring at the Analog Output Unit

The ERC indicator will light when the Analog Output Unit detects an alarm. The Alarm Flags in bits 08 to 15 of CIO word n+9 will turn ON or the Output Set Value Error Flags in bits 00 to 03 will turn ON.



### ERH and RUN Indicators Lit




The ERC and RUN indicators will be lit if an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| n+9           | Alarm flag             | Error contents                              | Output status                             | Countermeasure         |
|---------------|------------------------|---------------------------------------------|-------------------------------------------|------------------------|
| Bits 00 to 03 | Output Set Value Error | The output setting range has been exceeded. | Output value set by output hold function. | Correct the set value. |

$$n = \text{CIO } 2000 + (\text{unit number} \times 10)$$

### ERC Indicator: Lit, RUN Indicator: Not Lit



The ERC indicator will be lit when the initial settings for the Analog Output Unit are not set correctly. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF when the error is cleared and the power to the PLC is cycled, or the Special I/O Unit Restart Bit is turned ON.

| n+9    | Alarm flag                                                                   | Error contents                                                                                                                                               | Countermeasure                                                                                 |
|--------|------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|
| Bit 08 | Scaling data setting error                                                   | There is a mistake in the upper or lower limit settings for scaling. The setting range has been exceeded. The upper limit equals the lower limit (not 0000). | Correct the settings.                                                                          |
| Bit 09 | Output signal range setting error or error in number of outputs used setting | The setting of the number of outputs to use or an output signal range is wrong.                                                                              | Set the number of analog outputs used to 0 to 4 and set the input signal ranges to 1, 3, or 6. |




| n+9    | Alarm flag                          | Error contents                                                             | Countermeasure         |
|--------|-------------------------------------|----------------------------------------------------------------------------|------------------------|
| Bit 10 | Output hold setting error           | The setting of the output status for when conversion is stopped is wrong.  | Specify 00, 01, or 02. |
| Bit 12 | Error in setting of conversion mode | The setting for Cyclic Conversion Mode or Direct Conversion Mode is wrong. | Set 00 hex or A5 hex.  |

$$n = \text{CIO 2000} + (\text{unit number} \times 10)$$

### 7-7-3 Errors in the CPU Unit

The ERH indicator will light if an error occurs in the CPU Unit or I/O bus and I/O refreshing with the Special I/O Units is not performed correctly, preventing the Analog Output Unit from operating.


#### ERH and RUN Indicators: Lit



The ERH and RUN indicators will light if an I/O bus error occurs or if a WDT (watchdog timer) error occurs in the CPU Unit, resulting in incorrect I/O refresh with the Analog Output Unit. Cycle the power supply to the PLC or restart the Analog Output Unit.

| Error                     | Error contents                                             | Output status                               |
|---------------------------|------------------------------------------------------------|---------------------------------------------|
| I/O bus error             | Error has occurred during data exchange with the CPU Unit. | Output value set by output hold function.   |
| CPU Unit monitoring error | No response from CPU Unit for a specified period of time.  | Maintains the status from before the error. |
| CPU Unit WDT error        | Error has occurred in CPU Unit.                            | Output value set by output hold function.   |

#### ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number for the Analog Output Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Output status                 |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|-------------------------------|
| Unit Number Duplication Error  | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | The output value will be 0 V. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O tables are different from the ones actually mounted.                        |                               |

## 7-7-4 Restarting Special I/O Units

To restart the Analog Output Unit after changing the contents of the DM Area or correcting an error, cycle the power to the PLC or turn ON the Special I/O Unit Restart Bit.

### ■ Special I/O Unit Restart Bits

| Bit     | Function                |                                   |
|---------|-------------------------|-----------------------------------|
| A502.00 | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON. |
| A502.01 | Unit No. 1 Restart Bit  |                                   |
| to      | to                      |                                   |
| A502.15 | Unit No. 15 Restart Bit |                                   |
| A503.00 | Unit No. 16 Restart Bit |                                   |
| to      | to                      |                                   |
| A507.15 | Unit No. 95 Restart Bit |                                   |

- Note**
1. Replace the Unit if the error is not cleared even though the power supply is cycled or the Restart Bit is turned ON.
  2. The output becomes 0 V during restart.

## 7-7-5 Troubleshooting

The following tables list the probable causes of troubles that may occur, and the countermeasures for dealing with them.

### Analog Output Does Not Change

| Probable cause                                                                                          | Countermeasure                                                                      | Page |
|---------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|------|
| Number of analog outputs used is not set correctly.                                                     | Set the number of analog outputs used to enable all outputs that are being used.    | 289  |
| The ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction is not being executed in Direct Conversion Mode. | Execute the ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction in the user program. | 291  |
| The output hold function is in operation.                                                               | Turn ON the Conversion Enable Bit.                                                  | 292  |
| The value set for the output set value is out of range.                                                 | Set the data within the range.                                                      | 272  |

### Value Does Not Change as Intended

| Probable cause                                                                                                                   | Countermeasure                           | Page |
|----------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------|
| The output signal range setting is wrong.                                                                                        | Correct the output signal range setting. | 289  |
| The specifications of the input device do not match those of the Analog Output Unit (e.g., input signal range, input impedance). | Change the input device.                 | 270  |

### Outputs Are Inconsistent

| Probable cause                                           | Countermeasure                                                                                             | Page |
|----------------------------------------------------------|------------------------------------------------------------------------------------------------------------|------|
| The output signals are being affected by external noise. | Try connecting the cable shield at the Analog Output Unit, or disconnecting it if it is already connected. | 281  |

# SECTION 8

## CS-series Analog I/O Unit (CS1W-MAD44)

This section explains how to use the CS1W-MAD44 Analog I/O Unit.

|        |                                                        |     |
|--------|--------------------------------------------------------|-----|
| 8-1    | Specifications .....                                   | 302 |
| 8-1-1  | Specifications .....                                   | 302 |
| 8-1-2  | I/O Function Block Diagram .....                       | 305 |
| 8-1-3  | Input Specifications .....                             | 305 |
| 8-1-4  | Output Specifications .....                            | 307 |
| 8-2    | Operating Procedure .....                              | 310 |
| 8-2-1  | Procedure Examples .....                               | 311 |
| 8-3    | Components and Switch Settings .....                   | 317 |
| 8-3-1  | Indicators .....                                       | 318 |
| 8-3-2  | Unit Number Switches .....                             | 319 |
| 8-3-3  | Operation Mode Switch .....                            | 319 |
| 8-3-4  | Voltage/Current Switch .....                           | 320 |
| 8-4    | Wiring .....                                           | 320 |
| 8-4-1  | Terminal Arrangement .....                             | 320 |
| 8-4-2  | Internal Circuitry .....                               | 321 |
| 8-4-3  | Voltage Input Disconnection .....                      | 322 |
| 8-4-4  | I/O Wiring Example .....                               | 323 |
| 8-4-5  | I/O Wiring Considerations .....                        | 324 |
| 8-5    | Exchanging Data with the CPU Unit .....                | 324 |
| 8-5-1  | Outline of Data Exchange .....                         | 324 |
| 8-5-2  | Unit Number Settings .....                             | 325 |
| 8-5-3  | Special I/O Unit Restart Bits .....                    | 325 |
| 8-5-4  | Fixed Data Allocations .....                           | 326 |
| 8-5-5  | I/O Refresh Data Allocations .....                     | 329 |
| 8-6    | Analog Input Functions and Operating Procedures .....  | 332 |
| 8-6-1  | Input Settings and Conversion Values .....             | 332 |
| 8-6-2  | Mean Value Processing .....                            | 334 |
| 8-6-3  | Peak Value Hold Function .....                         | 337 |
| 8-6-4  | Input Disconnection Detection Function .....           | 338 |
| 8-7    | Analog Output Functions and Operating Procedures ..... | 339 |
| 8-7-1  | Output Settings and Conversions .....                  | 339 |
| 8-7-2  | Output Hold Function .....                             | 341 |
| 8-7-3  | Output Setting Errors .....                            | 342 |
| 8-8    | Ratio Conversion Function .....                        | 342 |
| 8-9    | Adjusting Offset and Gain .....                        | 345 |
| 8-9-1  | Adjustment Mode Operational Flow .....                 | 346 |
| 8-9-2  | Input Offset and Gain Adjustment Procedures .....      | 347 |
| 8-9-3  | Output Offset and Gain Adjustment Procedures .....     | 353 |
| 8-10   | Handling Errors and Alarms .....                       | 361 |
| 8-10-1 | Indicators and Error Flowchart .....                   | 361 |
| 8-10-2 | Alarms Occurring at the Analog I/O Unit .....          | 363 |
| 8-10-3 | Errors in the CPU Unit .....                           | 365 |
| 8-10-4 | Restarting Special I/O Units .....                     | 366 |
| 8-10-5 | Troubleshooting .....                                  | 366 |

## 8-1 Specifications

### 8-1-1 Specifications


| Item                             | CS1W-MAD44                                                                                                                      |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
|----------------------------------|---------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------|----------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Unit type                        | CS-series Special I/O Unit                                                                                                      |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Isolation                        | Between I/O and PLC signals: Photocoupler<br>(No isolation between I/O signals.)                                                |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| External terminals               | 21-point detachable terminal block (M3 screws)                                                                                  |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Current consumption              | 200 mA max. at 5 VDC, 200 mA max. at 26 VDC                                                                                     |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Dimensions (mm)<br>(See note 1.) | 35 × 130 × 126 (W × H × D)                                                                                                      |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Weight                           | 450 g max.                                                                                                                      |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| General specifications           | Conforms to general specifications for SYSMAC CS-series Series.                                                                 |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Mounting position                | CS-series CPU Rack or CS-series Expansion Rack<br>(Cannot be mounted to a C200H Expansion I/O Rack or a SYSMAC BUS Slave Rack.) |                                                                                                |                                  |                                                                                                                                                                                                                                                            |
| Maximum number of Units          | Units per Rack (CPU Rack or Expansion Rack)<br>(See note 2.)                                                                    | Power Supply Unit                                                                              | Maximum number of Units per Rack |                                                                                                                                                                                                                                                            |
|                                  |                                                                                                                                 | C200HW-PA204<br>C200HW-PA204S<br>C200HW-PA204R<br>C200HW-PD204                                 | 3 Units max.                     |                                                                                                                                                                                                                                                            |
|                                  |                                                                                                                                 | C200HW-PA209R                                                                                  | 6 Units max.                     |                                                                                                                                                                                                                                                            |
|                                  | Units per basic system                                                                                                          | When C200HW-PA209R Power Supply Units only are used:<br>6 Units max. × 8 Racks = 48 Units max. |                                  |                                                                                                                                                                                                                                                            |
| Data exchange with CPU Units     | Special I/O Unit Area<br>CIO 200000 to CIO 295915<br>(Words CIO 2000 to CIO 2959)                                               | Exchanges 10 words of data per Unit.                                                           | CPU Unit to Analog I/O Unit      | Analog output<br>Peak value hold<br>Conversion Enable Bit                                                                                                                                                                                                  |
|                                  |                                                                                                                                 |                                                                                                | Analog I/O Unit to CPU Unit      | Analog input<br>Input disconnection detection<br>Alarm flags                                                                                                                                                                                               |
|                                  | Internal Special I/O Unit DM Area<br>(D20000 to D29599)                                                                         | Transmits 100 words of data per Unit at power-up or when the Unit is restarted.                | CPU Unit to Analog I/O Unit      | Input signal conversion enable/disable, input signal range setting<br>Output signal conversion enable/disable, output signal range setting<br>Ratio conversion function setting, constants<br>Output status for output hold<br>Mean value function setting |

| Item   |                | CS1W-MAD44                                      |                                                                                                                                                                                                                                                                                                                                                                                                   |                                                  |
|--------|----------------|-------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|
| Input  | Specifications |                                                 |                                                                                                                                                                                                                                                                                                                                                                                                   | <b>Voltage input</b>                             |
|        |                |                                                 |                                                                                                                                                                                                                                                                                                                                                                                                   | <b>Current input</b>                             |
|        |                | Number of analog inputs                         |                                                                                                                                                                                                                                                                                                                                                                                                   | 4                                                |
|        |                | Input signal range (See note 3.)                |                                                                                                                                                                                                                                                                                                                                                                                                   | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>-10 to 10 V |
|        |                | Maximum rated input (for 1 point) (See note 5.) |                                                                                                                                                                                                                                                                                                                                                                                                   | ±15 V                                            |
|        |                | Input impedance                                 |                                                                                                                                                                                                                                                                                                                                                                                                   | 1 MΩ min.                                        |
|        |                | Resolution                                      |                                                                                                                                                                                                                                                                                                                                                                                                   | 4,000 (full scale)                               |
|        |                | Converted output data                           |                                                                                                                                                                                                                                                                                                                                                                                                   | 16-bit binary data                               |
|        |                | Accuracy<br>(See note 6.)                       | 23±2°C                                                                                                                                                                                                                                                                                                                                                                                            | ±0.2% of full scale                              |
|        |                |                                                 | 0°C to 55°C                                                                                                                                                                                                                                                                                                                                                                                       | ±0.4% of full scale                              |
|        |                | A/D conversion time (See note 7.)               |                                                                                                                                                                                                                                                                                                                                                                                                   | 1.0 ms/point max.                                |
|        | Functions      | Mean value processing                           | Stores the last “n” data conversions in the buffer, and stores the the mean value of the conversion values.<br>Number of mean value buffers: n = 2, 4, 8, 16, 32, 64                                                                                                                                                                                                                              |                                                  |
|        |                | Peak value holding                              | Stores the maximum conversion value while the Peak Value Hold Bit is ON.                                                                                                                                                                                                                                                                                                                          |                                                  |
|        |                | Input disconnection detection (See note 9.)     | Detects the disconnection and turns ON the Disconnection Detection Flag.                                                                                                                                                                                                                                                                                                                          |                                                  |
| Output | Specifications |                                                 |                                                                                                                                                                                                                                                                                                                                                                                                   | <b>Voltage output</b>                            |
|        |                | Number of analog outputs                        |                                                                                                                                                                                                                                                                                                                                                                                                   | 4                                                |
|        |                | Output signal range<br>(See note 3.)            |                                                                                                                                                                                                                                                                                                                                                                                                   | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>-10 to 10 V |
|        |                | Output impedance (for 1 point)                  |                                                                                                                                                                                                                                                                                                                                                                                                   | 0.5 Ω max.                                       |
|        |                | Max. output current                             |                                                                                                                                                                                                                                                                                                                                                                                                   | 12 mA                                            |
|        |                | Resolution                                      |                                                                                                                                                                                                                                                                                                                                                                                                   | 4,000 (full scale)                               |
|        |                | Set data                                        |                                                                                                                                                                                                                                                                                                                                                                                                   | 16-bit binary data                               |
|        |                | Accuracy<br>(See note 6.)                       | 23±2°C                                                                                                                                                                                                                                                                                                                                                                                            | ±0.3% of full scale                              |
|        |                |                                                 | 0°C to 55°C                                                                                                                                                                                                                                                                                                                                                                                       | ±0.5% of full scale                              |
|        |                | D/A conversion time (See note 7.)               |                                                                                                                                                                                                                                                                                                                                                                                                   | 1.0 ms/point max.                                |
|        | Functions      | Output hold function                            | Outputs the specified output status (CLR, HOLD, or MAX) under any of the following circumstances.<br>When the Conversion Enable Bit is OFF. (See note 8.)<br>In adjustment mode, when a value other than the output number is output during adjustment.<br>When there is an output setting error or a fatal error occurs at the PLC.<br>When the CPU Unit is on standby.<br>When the Load is OFF. |                                                  |
| Other  | Functions      | Ratio conversion function                       | Stores the results of positive and negative gradient analog inputs calculated for ratio and bias as analog output values.<br>Positive gradient: Analog output = A × Analog input + B<br>(A = 0 to 99.99, B = 8,000 to 7FFF hex)<br>Negative gradient: Analog output = F - A × Analog input + B<br>(A = 0 to 99.99, B = 8,000 to 7FFF hex, F = output range max. value)                            |                                                  |

**Note** 1. Refer to *Dimensions* on page 441 for details on the Unit's dimensions.

2. The maximum number of Analog I/O Units that can be mounted to one Rack will vary depending on the current consumption of the other Units mounted to the Rack.
3. Input and output signal ranges can be set for each input and output.
4. Voltage input or current input are chosen by using the voltage/current switch at the back of the terminal block.
5. The Analog I/O Unit must be operated according to the input specifications provided here. Operating the Unit outside these specifications will cause the Unit to malfunction.
6. The accuracy is given for full scale. For example, an accuracy of  $\pm 0.2\%$  means a maximum error of  $\pm 8$  (BCD).  
The default setting is adjusted for voltage input. To use current input, perform the offset and gain adjustments as required.
7. A/D conversion time is the time it takes for an analog signal to be stored in memory as converted data after it has been input. It takes at least one cycle before the converted data is read by the CPU Unit. D/A conversion time is the time required for converting and outputting the PLC data. It takes at least one cycle for the data stored in the PLC to be read by the Analog I/O Unit.
8. When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Output Conversion Enable Bit will turn OFF. The output status specified according to the output hold function will be output.
9. Input disconnection detection is valid only when the 1 to 5-V or 4 to 20-mA range is set. If there is no input signal for when the 1 to 5-V or 4 to 20-mA range is set, the Disconnection Detection Flag will turn ON.


### 8-1-2 I/O Function Block Diagram



### 8-1-3 Input Specifications


If signals that are outside the specified range provided below are input, the conversion values used will be either the maximum or minimum value.

**Range: 1 to 5 V (4 to 20 mA)**




**Range: 0 to 10 V**

Conversion value (16-bit binary data)


**Range: 0 to 5 V**

Conversion value (16-bit binary data)






Range: -10 to 10 V



## 8-1-4 Output Specifications


If the set value is outside the specified range provided below, an output setting error will occur, and the output specified by the output hold function will be output.

Range: 1 to 5 V



**Range: 0 to 10 V**


Analog output signal



Set value (16-bit binary data)


**Range: 0 to 5 V**

Analog output signal



Set value (16-bit binary data)

Range: -10 to 10 V



**Note** The conversion values and set values for a range of -10 to 10 V will be as follows:

| 16-bit binary data | BCD   |
|--------------------|-------|
| F768               | -2200 |
| :                  | :     |
| FFFF               | -1    |
| 0000               | 0     |
| 0001               | 1     |
| :                  | :     |
| 0898               | 2200  |

## 8-2 Operating Procedure

Follow the procedure outlined below when using Analog I/O Units.

### Installation and Settings

- 1,2,3...**
1. Set the operation mode switch on the rear panel of the Unit to normal mode.
  2. Set the voltage/current switch at the back of the terminal block.
  3. Wire the Unit.
  4. Use the unit number switches on the front panel of the Unit to set the unit number.
  5. Turn ON the power to the PLC.
  6. Create the I/O tables.
  7. Make the Special I/O Unit DM Area settings.
    - Set the I/O numbers to be used.
    - Set the input and output signal ranges.
    - Set the number of mean processing samplings.
    - Set the output hold function.
    - Set the ratio conversion usage, the ratio set value, and the bias value.
  8. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the input or output of the connected devices needs to be calibrated, follow the procedures in *Offset Gain Adjustment* below. Otherwise, skip to *Operation* below.


### Offset and Gain Adjustment

- 1,2,3...**
1. Set the operation mode on the rear panel of the Unit to adjustment mode.
  2. Set the voltage/current switch at the back of the terminal block.
  3. Turn ON the power to the PLC.
  4. Adjust the offset and gain.
  5. Turn OFF the power to the PLC.
  6. Change the setting of the operation mode switch on the rear panel of the Unit back to normal mode.

### Operation

- 1,2,3...**
1. Turn ON the power to the PLC.
  2. Ladder program
    - Read conversion values or write set values by means of MOV(021) and XFER(070).
    - Start and stop conversion output.
    - Specify the peak hold function.
    - Obtain disconnection notifications and error codes.


## 8-2-1 Procedure Examples




## Setting the Analog I/O Unit

1,2,3...


1. Set the operation mode switch on the rear panel of the Unit. Refer to 8-3-4 Voltage/Current Switch for further details.




2. Set the voltage/current switch. Refer to 8-3-4 Voltage/Current Switch for further details.



3. Mount and wire the Analog I/O Unit. Refer to *1-2-1 Mounting Procedure*, *8-4 Wiring* or *8-4-4 I/O Wiring Example* for further details.




4. Set the unit number switches. Refer to *8-3-2 Unit Number Switches* for further details.




If the unit number is set to 1, words will be allocated to the Special I/O Unit Area CIO 2010 to CIO 2019 and to the Special I/O Unit Area D20100 to D20199.

5. Turn ON the power to the PLC.



Creating I/O Tables


After turning ON the power to the PLC, be sure to create the I/O tables.



Initial Data Settings


- 1,2,3...
1.

Specify the Special I/O Unit DM Area settings. Refer to *Allocations in DM Area* on page 326 for further details.




- Setting conditions
- Unit No. 1
- Analog input 1: 1 to 5 V  
Analog input 2: 0 to 10 V  
Analog input 3: 4 to 20 mA  
Analog input 4: 4 to 20 mA
- Analog output 1: 1 to 5 V  
Analog output 2: 1 to 5 V  
Analog output 3: -10 to 10 V  
Analog output 4: Not used.


- The following diagram shows the input and output settings used. Refer to 8-6-1 *Input Settings and Conversion Values* or 8-7-1 *Output Settings and Conversions* for more details.




- The following diagram shows the input and output range settings. Refer to 8-6-1 *Input Settings and Conversion Values* or 8-7-1 *Output Settings and Conversions* for more details.



## 2. Restart the CPU Unit.



## Creating Ladder Programs



### 1,2,3...

- The following example describes how to use analog inputs.

The data that is converted from analog to digital and output to CIO words (n + 5) to (n + 8) of the Special I/O Unit Area (CIO 2015 to CIO2018), is stored in the specified addresses D00100 to D00103 as signed binary values 0000 to 0FA0 hex.




- The following table shows the addresses used for analog input.

| Input number | Input signal range | Input conversion value address<br>(n = CIO 2010)<br>(See note a.) | Conversion data holding address<br>(See note b.) |
|--------------|--------------------|-------------------------------------------------------------------|--------------------------------------------------|
| 1            | 1 to 5 V           | (n+5) = CIO 2015                                                  | D00100                                           |
| 2            | 0 to 10 V          | (n+6) = CIO 2016                                                  | D00101                                           |
| 3            | 4 to 20 mA         | (n+7) = CIO 2017                                                  | D00102                                           |
| 4            | 4 to 20 mA         | (n+8) = CIO 2018                                                  | D00103                                           |

**Note a)** The addresses are set according to the unit number of the Special I/O Unit. Refer to *8-3-2 Unit Number Switches* for further details.

**b)** Set as required.



**c)** The input Disconnection Detection Flag is allocated to bits 04 to 07 of word (n+9). Refer to *Allocations for Normal Mode* on page 330 and *8-6-4 Input Disconnection Detection Function* for further details.

2. The following example shows how to use analog outputs.


The setting address D00200 is stored in words (n+1) to (n+3) of the Special I/O Unit Area (CIO 2011 to CIO 2013) as a signed binary value between 0000 to 0FA0 hex.

- The following table shows the addresses used for analog output.


| Output number | Input signal range | Output setting address<br>(n = CIO 2010)<br>(See note a.) | Original conversion address<br>(See note b.) |
|---------------|--------------------|-----------------------------------------------------------|----------------------------------------------|
| 1             | 1 to 5 V           | (n+1) = CIO 2011                                          | D00200                                       |
| 2             | 0 to 10 V          | (n+2) = CIO 2012                                          | D00201                                       |
| 3             | -10 to 10 V        | (n+3) = CIO 2013                                          | D00202                                       |
| 4             | Not used.          | ---                                                       | ---                                          |

**Note a)** The addresses are set according to the unit number of the Special I/O Unit. Refer to *8-3-2 Unit Number Switches* for further details.

**b)** Set as required.




8-3 Components and Switch Settings



The terminal block is attached by a connector. It can be removed by loosening the two black mounting screws located at the top and bottom of the terminal block.

Check to be sure that the black terminal block mounting screw is securely tightened to a torque of 0.5 N·m.



### 8-3-1 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| LED          | Meaning                | Indicator | Operating status                                                                        |
|--------------|------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                                               |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit   | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit   | Operating normally.                                                                     |

### 8-3-2 Unit Number Switches

The CPU Unit and Analog I/O Unit exchange data via the Special I/O Unit Area and the Special I/O Unit DM Area. The Special I/O Unit Area and Special I/O Unit DM Area word addresses that each Analog I/O Unit occupies are set by the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings.




| Switch setting | Unit number | Special I/O Unit Area addresses                   | Special I/O Unit DM Area addresses               |
|----------------|-------------|---------------------------------------------------|--------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                              | D20000 to D20099                                 |
| 1              | Unit #1     | CIO 2010 to CIO 2019                              | D20100 to D20199                                 |
| 2              | Unit #2     | CIO 2020 to CIO 2029                              | D20200 to D20299                                 |
| 3              | Unit #3     | CIO 2030 to CIO 2039                              | D20300 to D20399                                 |
| 4              | Unit #4     | CIO 2040 to CIO 2049                              | D20400 to D20499                                 |
| 5              | Unit #5     | CIO 2050 to CIO 2059                              | D20500 to D20599                                 |
| 6              | Unit #6     | CIO 2060 to CIO 2069                              | D20600 to D20699                                 |
| 7              | Unit #7     | CIO 2070 to CIO 2079                              | D20700 to D20799                                 |
| 8              | Unit #8     | CIO 2080 to CIO 2089                              | D20800 to D20899                                 |
| 9              | Unit #9     | CIO 2090 to CIO 2099                              | D20900 to D20999                                 |
| 10             | Unit #10    | CIO 2100 to CIO 2109                              | D21000 to D21099                                 |
| to             | to          | to                                                | to                                               |
| n              | Unit #n     | CIO 2000 + (n × 10) to<br>CIO 2000 + (n × 10) + 9 | D20000 + (n × 100) to<br>D20000 + (n × 100) + 99 |
| to             | to          | to                                                | to                                               |
| 95             | Unit #95    | CIO 2950 to CIO 2959                              | D29500 to D29599                                 |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 8-3-3 Operation Mode Switch

The operation mode switch on the back panel of the Unit is used to set the operation mode to either normal mode or adjustment mode (for adjusting off-set and gain).




| Pin number |     | Mode            |
|------------|-----|-----------------|
| 1          | 2   |                 |
| OFF        | OFF | Normal mode     |
| ON         | OFF | Adjustment mode |

**Caution** Do not set the pins to any combination other than those shown in the above table. Be sure to set pin 2 to OFF.

**Caution** Be sure to turn OFF the power to the PLC before installing or removing the Unit.

### 8-3-4 Voltage/Current Switch

The analog conversion input can be switched from voltage input to current input by changing the pin settings on the voltage/current switch located on the back of the terminal block.



**Caution** Be sure to turn OFF the power to the PLC before mounting or removing the terminal block.

## 8-4 Wiring

### 8-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.

|              |     |     |              |
|--------------|-----|-----|--------------|
| Output 2 (+) | B1  | A1  | Output 1 (+) |
| Output 2 (–) | B2  | A2  | Output 1 (–) |
| Output 4 (+) | B3  | A3  | Output 3 (+) |
| Output 4 (–) | B4  | A4  | Output 3 (–) |
| N.C.         | B5  | A5  | N.C.         |
| Input 2 (+)  | B6  | A6  | Input 1 (+)  |
| Input 2 (–)  | B7  | A7  | Input 1 (–)  |
| AG           | B8  | A8  | AG           |
| Input 4 (+)  | B9  | A9  | Input 3 (+)  |
| Input 4 (–)  | B10 | A10 | Input 3 (–)  |
|              |     | A11 | N.C.         |

- Note**
1. The analog I/O numbers that can be used are set in the Data Memory (DM).
  2. The I/O signal ranges for individual inputs and outputs are set in the Data Memory (DM). They can be set in units of I/O numbers.
  3. The AG terminal (A8, B8) is connected to the 0-V analog circuit in the Unit. Connecting shielded input lines can improve noise resistance.
  4. The N.C. terminals (A5, A11, B5) are not connected to internal circuitry.

The following diagrams show the internal circuitry of the analog I/O section.

Input (+)

Input (-)

AG (analog 0 V)

250  $\Omega$

1 M $\Omega$

15 k $\Omega$

15 k $\Omega$

15 k $\Omega$

15 k $\Omega$

1 M $\Omega$

Voltage/current input switch

Input circuit and conversion circuit

AG (common to all inputs)

The diagram illustrates the internal architecture of the CS-series PLC, divided into two main sections by a vertical dashed line representing insulation.

**Left Section (Control Logic):**

- Indicators/Switch:** Connected to the **Bus interface** and the **MPU**.
- Bus interface:** Connected to the **MPU** and the **Oscillator**.
- Oscillator:** Provides a clock signal to the **Bus interface** and the **Division** block.
- Division:** A small block that receives input from the **Oscillator** and provides output to the **MPU**.
- MPU (Microprocessor Unit):** The central processing unit, containing **RAM** and **ROM**. It is connected to the **Bus interface**, **Indicators/Switch**, **EEPROM**, and **Photocoupler insulation**.
- EEPROM (Electrically Erasable Programmable Read-Only Memory):** Connected to the **MPU**.

**Right Section (I/O and Power):**


- Photocoupler insulation:** A vertical block that isolates the control logic from the I/O and power sections.
- D/A converter (Digital-to-Analog):** Receives data from the **MPU** and sends it to the **Multiplexer and amplifier**.
- Multiplexer and amplifier:** Receives signals from the **D/A converter** and sends them to the **OUTPUT** terminal.
- A/D converter (Analog-to-Digital):** Receives signals from the **Multiplexer and amplifier** and sends data to the **MPU**.
- Multiplexer and amplifier:** Receives signals from the **INPUT** terminal and sends them to the **A/D converter**.
- OUTPUT:** The final output terminal, labeled "Externally connect terminal".
- INPUT:** The final input terminal, labeled "Externally connect terminal".

**Power Supply Section (Bottom):**

- +26 V:** The main power input to the **Insulation-type DC-to-DC converter**.
- Insulation-type DC-to-DC converter:** Converts the +26 V input into regulated power outputs.
- Regulator:** A block that receives input from the **DC-to-DC converter** and provides regulated +5 V output.
- Outputs:** The system provides three regulated power outputs: **+15 V**, **+5 V** (via the **Regulator**), and **-15 V**.

**CS-series PLC**

### 8-4-3 Voltage Input Disconnection



**Note** If the connected device #2 in the above example outputs 5 V and the power supply is shared by 2 channels as shown in the above diagram, approximately one third of the voltage, or 1.6 V, will be input at input 1.


When voltage inputs are used and a disconnection occurs, separate the power supply at the side of the connected devices or use an insulating device (isolator) for each input to avoid the following problems.

When the power supply at the connected devices is shared and section A or B is disconnected, power will flow in the direction of the broken line and the output voltage of the other connected devices will be reduced to between a third to a half of the voltage. If 1 to 5 V is used and the reduced voltage output, disconnection may not be detectable. If section C is disconnected, the power at the (–) input terminal will be shared and disconnection will not be detectable.


For current inputs, sharing the power supply between the connected devices will not cause any problems.



### 8-4-4 I/O Wiring Example



- Note**
1. When using current inputs, pins IN1 to IN4 of the voltage/current switch must be set to ON. Refer to *8-3-4 Voltage/Current Switch* for further details.
  2. For inputs that are not used, either set to "0: Not used" in the input number settings (refer to *8-6-1 Input Settings and Conversion Values*) or short-circuit the voltage input terminals (V+) and (V-).
  3. Crimp-type terminals must be used for terminal connections, and the screws must be tightened securely. Use M3 screws and tighten them to a torque of 0.5 N·m.
  4. When connecting the shield of the analog input cables to the Unit's AG terminals (A8, B8), as shown in the previous diagram, use a wire that is 30 cm max. in length if possible.



Connecting shielded cable to the Unit's AG terminals (A8, B8) can improve noise resistance.

To minimize output wiring noise, ground the output signal line to the input device.

### 8-4-5 I/O Wiring Considerations

When wiring inputs, apply the following points to avoid noise interference and optimize Analog I/O Unit performance.

- Use two-core shielded twisted-pair cables for external connections.
- Route I/O cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable or a high voltage cable. Do not insert output cables into the same duct.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.

## 8-5 Exchanging Data with the CPU Unit

### 8-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the CS1W-MAD44 Analog I/O Unit via the Special I/O Unit Area (for data used to operate the Unit) and the Special I/O Unit DM Area (for data used for initial settings).

#### I/O Refresh Data

Analog input conversion values, analog output setting values, and other data used to operate the Unit are allocated in the Special I/O Unit Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.


#### Fixed Data

The Unit's fixed data, such as the analog input signal ranges and analog output signal ranges, is allocated in the Special I/O Unit DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.



## 8-5-2 Unit Number Settings

The Special I/O Unit Area and Special I/O Unit DM Area word addresses that each Analog I/O Unit occupies are set by the unit number switches on the front panel of the Unit.



| Switch setting | Unit number | Special I/O Unit Area addresses                | Special I/O Unit DM Area addresses            |
|----------------|-------------|------------------------------------------------|-----------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                           | D20000 to D20099                              |
| 1              | Unit #1     | CIO 2010 to CIO 2019                           | D20100 to D20199                              |
| 2              | Unit #2     | CIO 2020 to CIO 2029                           | D20200 to D20299                              |
| 3              | Unit #3     | CIO 2030 to CIO 2039                           | D20300 to D20399                              |
| 4              | Unit #4     | CIO 2040 to CIO 2049                           | D20400 to D20499                              |
| 5              | Unit #5     | CIO 2050 to CIO 2059                           | D20500 to D20599                              |
| 6              | Unit #6     | CIO 2060 to CIO 2069                           | D20600 to D20699                              |
| 7              | Unit #7     | CIO 2070 to CIO 2079                           | D20700 to D20799                              |
| 8              | Unit #8     | CIO 2080 to CIO 2089                           | D20800 to D20899                              |
| 9              | Unit #9     | CIO 2090 to CIO 2099                           | D20900 to D20999                              |
| 10             | Unit #10    | CIO 2100 to CIO 2109                           | D21000 to D21099                              |
| to             | to          | to                                             | to                                            |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9 | D20000 + (n × 100) to D20000 + (n × 100) + 99 |
| to             | to          | to                                             | to                                            |
| 95             | Unit #95    | CIO 2950 to CIO 2959                           | D29500 to D29599                              |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

## 8-5-3 Special I/O Unit Restart Bits

To restart the Unit operations after changing the contents of the data memory or correcting an error, turn ON the power to the PLC again or turn the Special I/O Unit Restart Bit ON and then OFF again.


| Special I/O Unit Area word address | Function                |                                                      |
|------------------------------------|-------------------------|------------------------------------------------------|
| A50200                             | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON and then OFF again. |
| A50201                             | Unit No. 1 Restart Bit  |                                                      |
| to                                 | to                      |                                                      |
| A50215                             | Unit No. 15 Restart Bit |                                                      |
| A50300                             | Unit No. 16 Restart Bit |                                                      |
| to                                 | to                      |                                                      |
| A50715                             | Unit No. 95 Restart Bit |                                                      |

**Note** If the error is not corrected by restarting the Unit or turning the Special I/O Unit Restart Bit ON and then OFF again, replace the Analog I/O Unit.

## 8-5-4 Fixed Data Allocations

### Allocations in DM Area

The initial settings of the Analog I/O Unit are set according to the data allocated in the Special I/O Unit DM Area. Settings, such as the inputs and outputs used, the analog input signal range, and analog output signal range must be set in this area.



- Note**
1. The Special I/O Unit DM Area words that are occupied by the Analog I/O Unit are set using the unit number switches on the front panel of the Unit. Refer to *8-3-2 Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

**Allocations in DM Area**

The following table shows the allocation of DM words and bits for both normal and adjustment mode.

| DM word  | Bits                                     |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
|----------|------------------------------------------|----|---------|----|---------|----|---------|---|-------------------------------------------------|---------|----------|---------|--------------------|-----------|-----------|-----------|
|          | 15                                       | 14 | 13      | 12 | 11      | 10 | 9       | 8 | 7                                               | 6       | 5        | 4       | 3                  | 2         | 1         | 0         |
| D (m)    | Ratio conversion use setting             |    |         |    |         |    |         |   | Input use setting                               |         |          |         | Output use setting |           |           |           |
|          | Loop 4                                   |    | Loop 3  |    | Loop 2  |    | Loop 1  |   | Input 4                                         | Input 3 | Input 2  | Input 1 | Out-put 4          | Out-put 3 | Out-put 2 | Out-put 1 |
| D (m+1)  | Input signal range setting               |    |         |    |         |    |         |   | Output signal range setting                     |         |          |         |                    |           |           |           |
|          | Input 4                                  |    | Input 3 |    | Input 2 |    | Input 1 |   | Output 4                                        |         | Output 3 |         | Output 2           |           | Output 1  |           |
| D (m+2)  | Not used.                                |    |         |    |         |    |         |   | Output 1: Output status when conversion stopped |         |          |         |                    |           |           |           |
| D (m+3)  | Not used.                                |    |         |    |         |    |         |   | Output 2: Output status when conversion stopped |         |          |         |                    |           |           |           |
| D (m+4)  | Not used.                                |    |         |    |         |    |         |   | Output 3: Output status when conversion stopped |         |          |         |                    |           |           |           |
| D (m+5)  | Not used.                                |    |         |    |         |    |         |   | Output 4: Output status when conversion stopped |         |          |         |                    |           |           |           |
| D (m+6)  | Input 1: Mean value processing setting   |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+7)  | Input 2: Mean value processing setting   |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+8)  | Input 3: Mean value processing setting   |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+9)  | Input 4: Mean value processing setting   |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+10) | Loop 1 (input 1 to output 1), A constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+11) | Loop 1 (input 1 to output 1), B constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+12) | Loop 2 (input 2 to output 2), A constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+13) | Loop 2 (input 2 to output 2), B constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+14) | Loop 3 (input 3 to output 3), A constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+15) | Loop 3 (input 3 to output 3), B constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+16) | Loop 4 (input 4 to output 4), A constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |
| D (m+17) | Loop 4 (input 4 to output 4), B constant |    |         |    |         |    |         |   |                                                 |         |          |         |                    |           |           |           |

**Note** For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

## Set Values and Stored Values


| Item   |                               | Contents                                                                                                                                                                                                                                                                                                                      | Page |
|--------|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Input  | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                      | 332  |
|        | Input signal range            | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V/4 to 20 mA (See note 1.)<br>11: 0 to 5 V                                                                                                                                                                                                                                     | 333  |
|        | Mean value processing setting | 0000: Mean value processing for 2 buffers (See note 3.)<br>0001: No mean value processing<br>0002: Mean value processing for 4 buffers<br>0003: Mean value processing for 8 buffers<br>0004: Mean value processing for 16 buffers<br>0005: Mean value processing for 32 buffers<br>0006: Mean value processing for 64 buffers | 334  |
| Output | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                      | 339  |
|        | Output signal range           | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V<br>11: 0 to 5 V                                                                                                                                                                                                                                                              | 339  |
|        | Output status when stopped    | 00: CLR Outputs 0 or minimum value of each range.<br>(See note 2.)<br>01: HOLD Holds output just before stopping.<br>02: MAX Outputs maximum value of range.                                                                                                                                                                  | 341  |
| Loop   | Ratio conversion use setting  | 00: Not used.<br>01: Uses positive gradient conversion.<br>10: Uses negative gradient conversion.<br>11: Same as for setting "00" above.                                                                                                                                                                                      | 342  |
|        | A constant                    | 4 digits BCD (0 to 9999)                                                                                                                                                                                                                                                                                                      |      |
|        | B constant                    | 16-bit binary data                                                                                                                                                                                                                                                                                                            |      |

- Note**
1. The input signal range of "1 to 5 V" and "4 to 20 mA" is switched using the pins of the voltage/current switch. Refer to *8-3-4 Voltage/Current Switch* for details.
  2. For the range of  $\pm 10$  V, the output is 0 V. For other output signal ranges, the minimum value of each signal range is output. Refer to *8-7-2 Output Hold Function* for details.
  3. The default of mean value processing setting is set to "Mean value processing with 2 buffers." Refer to *8-6-2 Mean Value Processing*.

### 8-5-5 I/O Refresh Data Allocations

#### Special I/O Unit Area Allocation and Contents


I/O refresh data for the Analog I/O Unit is exchanged according to the allocations in the Special I/O Unit Area. Analog input converted values and analog output set values are exchanged with the CPU Unit at I/O refresh.



- Note**
1. The Special I/O Unit Area words that are occupied by the Analog I/O Unit are set using the unit number switches on the front panel of the Unit. Refer to 8-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

**Allocations for Normal Mode**

For normal mode, set the operation mode switch on the rear panel of the Unit as shown in the following diagram.



The allocation of words and bits in the CIO Area is shown in the following table.

| I/O                     | Word  | Bits                                                 |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|-------------------------|-------|------------------------------------------------------|----|----|----|-----------------|----|---|---|-------------------------|---------|---------|---------|----------------------|-----------|-----------|-----------|
|                         |       | 15                                                   | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                       | 6       | 5       | 4       | 3                    | 2         | 1         | 0         |
| Output<br>(CPU to Unit) | n     | Not used.                                            |    |    |    |                 |    |   |   | Peak value hold         |         |         |         | Conversion enable    |           |           |           |
|                         |       |                                                      |    |    |    |                 |    |   |   | Input 4                 | Input 3 | Input 2 | Input 1 | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |
|                         | n + 1 | Output 1 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         |       | 16 <sup>3</sup>                                      |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup>      |           |           |           |
|                         | n + 2 | Output 2 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         | n + 3 | Output 3 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         | n + 4 | Output 4 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
| Input<br>(Unit to CPU)  | n + 5 | Input 1 conversion value / Loop 1 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         |       | 16 <sup>3</sup>                                      |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup>      |           |           |           |
|                         | n + 6 | Input 2 conversion value / Loop 2 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         | n + 7 | Input 3 conversion value / Loop 3 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         | n + 8 | Input 4 conversion value / Loop 4 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                      |           |           |           |
|                         | n + 9 | Alarm Flags                                          |    |    |    |                 |    |   |   | Disconnection detection |         |         |         | Output setting error |           |           |           |
|                         |       |                                                      |    |    |    |                 |    |   |   | Input 4                 | Input 3 | Input 2 | Input 1 | Out-put 4            | Out-put 3 | Out-put 2 | Out-put 1 |

**Set Values and Stored Values**

| I/O    | Item                                   | Contents                                                                                                                                                                                                                                                                                                                      | Page                               |
|--------|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| Input  | Peak value hold function               | 0: Not used.<br>1: Peak value hold used.                                                                                                                                                                                                                                                                                      | 337                                |
|        | Conversion value<br>Calculation result | 16-bit binary data                                                                                                                                                                                                                                                                                                            | 333                                |
|        | Disconnection detection                | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                                                                                       | 338                                |
| Output | Conversion enable                      | 0: Conversion output stopped.<br>1: Conversion output begun.                                                                                                                                                                                                                                                                  | 340                                |
|        | Set value                              | 16-bit binary data                                                                                                                                                                                                                                                                                                            | 340                                |
|        | Output setting error                   | 0: No error<br>1: Output setting error                                                                                                                                                                                                                                                                                        | 342                                |
| Common | Alarm Flags                            | Bits 00 to 03: Output set value error<br>Bits 04 to 07: Input disconnection detection<br>Bit 08: Ratio conversion use setting error<br>Bit 09: Ratio set value error<br>Bit 10: Output hold setting error<br>Bit 11: Mean value processing setting error<br>Bit 15: Operating in adjustment mode<br>(always 0 in normal mode) | 363<br><br><br><br><br><br><br>364 |

**Note** For the CIO word addresses, n = CIO 2000 + unit number × 10.




The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

### Allocation for Adjustment Mode

For adjustment mode, set the operation mode switch on the rear panel of the Unit as shown in the following diagram. When the Unit is set for adjustment mode, the ADJ indicator on the front panel of the Unit will flash.



The allocation of CIO words and bits is shown in the following table.

| I/O                     | Word            | Bits                                                |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|-------------------------|-----------------|-----------------------------------------------------|----|----|----|-----------------|----|---|---|-----------------------------------|------------|------------|------------|-----------------|------|------|---------|
|                         |                 | 15                                                  | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                                 | 6          | 5          | 4          | 3               | 2    | 1    | 0       |
| Output<br>(CPU to Unit) | n               | Not used.                                           |    |    |    |                 |    |   |   | Inputs and outputs to be adjusted |            |            |            |                 |      |      |         |
|                         | 16 <sup>1</sup> |                                                     |    |    |    |                 |    |   |   | 16 <sup>0</sup>                   |            |            |            |                 |      |      |         |
|                         | n + 1           | Not used.                                           |    |    |    |                 |    |   |   | Not used.                         |            | Clr        | Set        | Up              | Down | Gain | Off-set |
|                         | n + 2           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 3           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 4           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 5           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 6           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
| n + 7                   | Not used.       |                                                     |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
| Input<br>(Unit to CPU)  | n + 8           | Conversion value or set value at time of adjustment |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         |                 | 16 <sup>3</sup>                                     |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>                   |            |            |            | 16 <sup>0</sup> |      |      |         |
|                         | n + 9           | Alarm Flags                                         |    |    |    |                 |    |   |   | Disconnection detec-<br>tion      |            |            |            | Not used.       |      |      |         |
|                         |                 |                                                     |    |    |    |                 |    |   |   | Input<br>4                        | Input<br>3 | Input<br>2 | Input<br>1 |                 |      |      |         |

### Set Values and Stored Values

Refer to 8-9-1 Adjustment Mode Operational Flow for further details.

| Item                            | Contents                                                                                                   |
|---------------------------------|------------------------------------------------------------------------------------------------------------|
| Input or output to be adjusted  | Sets input or output to be adjusted.<br>Leftmost digit: 1 (output) or 2 (input)<br>Rightmost digit: 1 to 4 |
| Offset (Offset Bit)             | When ON, adjusts offset error.                                                                             |
| Gain (Gain Bit)                 | When ON, adjusts gain error.                                                                               |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                  |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                  |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                  |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                         |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                   |

| Item                    | Contents                                                                                                                                                                                                                                                |
|-------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Disconnection detection | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                 |
| Alarm Flags             | Bit 12: Input value is outside adjustment limits (in adjustment mode)<br>Bit 13: I/O number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode (always 1 in adjustment mode) |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |


## 8-6 Analog Input Functions and Operating Procedures

### 8-6-1 Input Settings and Conversion Values

#### Setting Inputs and Signal Ranges

##### Input Numbers

The Analog I/O Unit converts only analog inputs specified by input numbers 1 to 4. To specify the analog inputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



The analog input sampling interval can be shortened by setting any unused input numbers to 0.


$$\text{Sampling interval} = (1 \text{ ms}) \times (\text{Number of inputs used})$$

For the DM word addresses,  $m = \text{D20000} + (\text{unit number} \times 100)$

The word for inputs that have been set to "Not used" will always be "0000."

**Input Signal Range**

Any of four types of input signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, and 4 to 20 mA) can be selected for each of the inputs (i.e., input numbers 1 to 4). To specify the input signal range for each input, set from a Programming Device the D(m+1) bits in the DM Area as shown in the following diagram.



- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$
  2. The input signal range of “1 to 5 V” or “4 to 20 mA” is switched using the voltage/current switch.
  3. After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit in order to transfer the contents of the DM settings to the Special I/O Unit.

**Reading Conversion Values**

Analog input conversion values are stored for each input number, in CIO words  $n+5$  to  $n+8$ .


| Word  | Function                 | Stored value       |
|-------|--------------------------|--------------------|
| $n+5$ | Input 1 conversion value | 16-bit binary data |
| $n+6$ | Input 2 conversion value |                    |
| $n+7$ | Input 3 conversion value |                    |
| $n+8$ | Input 4 conversion value |                    |

**Note** For the CIO word addresses,  $n = CIO\ 2000 + (\text{unit number} \times 10)$ .


Use MOV(021) or XFER(070) to read conversion values in the user program.

**Example 1**

In this example, the conversion data from only one input is read. (The unit number is 0.)

**Example 2**


In this example, the conversion data from multiple inputs is read. (The unit number is 0.)



For details regarding conversion value scaling, refer to *Scaling* on page 448.

## 8-6-2 Mean Value Processing

The Analog I/O Unit can compute the mean value of the conversion values of analog inputs that have been previously sampled. Mean value processing involves an operational mean value in the history buffers, so it has no effect on the data refresh cycle. (The number of history buffers that can be set to use mean value processing is 2, 4, 8, 16, 32, or 64.)



When “n” number of history buffers are being used, the first conversion data will be stored for all “n” number of history buffers immediately after data conversion has begun or after a disconnection is restored.

When mean value processing is used together with the peak value hold function, the mean value will be held.

To specify whether or not mean value processing is to be used, and to specify the number of history buffers for mean data processing, use a Programming Device to make the settings in D(m+6) to D(m+9) as shown in the following table.


| DM word | Function                      | Set value                                   |
|---------|-------------------------------|---------------------------------------------|
| D (m+6) | Input 1 mean value processing | 0000: Mean value processing with 2 buffers  |
| D (m+7) | Input 2 mean value processing | 0001: No mean value processing              |
| D (m+8) | Input 3 mean value processing | 0002: Mean value processing with 4 buffers  |
| D (m+9) | Input 4 mean value processing | 0003: Mean value processing with 8 buffers  |
|         |                               | 0004: Mean value processing with 16 buffers |
|         |                               | 0005: Mean value processing with 32 buffers |
|         |                               | 0006: Mean value processing with 64 buffers |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

**Note** After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.


The history buffer moving average is calculated as shown below. (In this example, there are four buffers.)

- 1,2,3...** 1. With the first cycle, Data 1 is stored in all the history buffers.




$$\text{Mean value} = (\text{Data 1} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

2. With the second cycle, Data 2 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 2} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

3. With the third cycle, Data 3 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 3} + \text{Data 2} + \text{Data 1} + \text{Data 1}) \div 4$$

4. With the fourth cycle, the Data 4 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 4} + \text{Data 3} + \text{Data 2} + \text{Data 1}) \div 4$$

5. With the fifth cycle, Data 5 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 5} + \text{Data 4} + \text{Data 3} + \text{Data 2}) \div 4$$

When a disconnection is restored, the mean value processing function begins again from step 1.

- Note** 1. The default setting for mean value processing in the Analog I/O Unit is mean value processing with 2 buffers. When the mean value processing

function is used, the delay in refreshing converted data for input signal changes will be as shown in the following diagram.

- Specify “no mean value processing” to follow conversion of a rapid change in input signals.



For  $V = 20\text{ V}$  ( $-10$  to  $10\text{ V}$ )

**Using One Word**

$$t = n + (2 \text{ to } 3)$$

**Using m Words ( $1 \leq m \leq 8$ )**

No averaging ( $n = 1$ ) or two averaging buffers ( $n = 2$ ):

$$t = n \times (m + 2)$$

n averaging buffers ( $4 \leq n \leq 64$ ):

$$t = (n - 2) \times m + 10.5$$

### Response Time

Unit: ms

| m | n     |       |      |      |      |    |   |
|---|-------|-------|------|------|------|----|---|
|   | 64    | 32    | 16   | 8    | 4    | 2  | 1 |
| 4 | 258.5 | 130.5 | 66.5 | 34.5 | 18.5 | 12 | 6 |
| 3 | 196.5 | 100.5 | 52.5 | 28.5 | 16.5 | 10 | 5 |
| 2 | 134.5 | 70.5  | 38.5 | 22.5 | 14.5 | 8  | 4 |
| 1 | 67    | 35    | 19   | 11   | 7    | 5  | 3 |

### Symbols

m: Number of input words used in DM Area

n: Average number of buffers set for the input number for which to find the response time


### Calculation Example

The following example calculations are for a resolution of 8,000 with an application using inputs 1 and 4, 64 averaging buffers set for input 1, and no averaging set for input 4.


- Response time for input 1:  $t = \{(64 - 2) \times 2 + 10.5\} = 134.5\text{ (ms)}$
- Response time for input 1:  $t = 1 \times (2 + 2) = 4\text{ (ms)}$

### 8-6-3 Peak Value Hold Function

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). This function can be used with analog input. The following diagram shows how digital conversion values are affected when the peak value hold function is used.



The peak value hold function can be set individually for each input number by turning on the respective bits (04 to 07) in CIO word n.



The peak value hold function will be in effect for the above input numbers while their respective bits are ON. The conversion values will be reset when the bits are turned OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

In the following example, the peak value hold function is in effect for input number 1, and the unit number is 0.



When mean value processing is used together with the peak value hold function, the mean value will be held.

As long as the peak value hold function is in effect, the peak value hold will be held even in the event of a disconnection.


When the load to the CPU Unit is disconnected, the Peak Value Hold Bits (bits 04 to 07 of the word n) are cleared and the peak value hold function is disabled.

### 8-6-4 Input Disconnection Detection Function

When an input signal range of 1 to 5 V (4 to 20 mA) is used, input circuit disconnections can be detected. The detection conditions for each of the input signal ranges are shown in the following table.

| Range      | Current/voltage |
|------------|-----------------|
| 1 to 5 V   | 0.3 V max.      |
| 4 to 20 mA | 1.2 mA max.     |

The current/voltage level will fluctuate according to the offset/gain adjustment. The input disconnection detection signals for each input number are stored in bits 04 to 07 of CIO word  $n+9$ . Specify these bits as execution conditions to use disconnection detection in the user's program.



The respective bit turns ON when a disconnection is detected for a given input. When the disconnection is restored, the bit turns OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The conversion value during a disconnection will be 0000.

In the following example, the conversion value is read only if there is no disconnection at analog input number 1. (The unit number is 0.)






## 8-7 Analog Output Functions and Operating Procedures

### 8-7-1 Output Settings and Conversions

#### Setting Outputs and Signal Ranges

##### Output Numbers

The Analog I/O Unit converts analog outputs specified by output numbers 1 to 4 only. To specify the analog outputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.




The analog output conversion cycle can be shortened by setting any unused output numbers to 0.

$$\text{Conversion cycle} = (1 \text{ ms}) \times (\text{Number of outputs used})$$

- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  2. Output numbers not used (set to 0) will be output at 0 V.

##### Output Signal Range

Any of four types of output signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, and 0 to 5 V) can be selected for each of the outputs (i.e., output numbers 1 to 4). To specify the output signal range for each output, use a Programming Device to set the D(m+1) bits in the DM Area shown in the following diagram.



- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  2. After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.

**Writing Set Values**

Analog output set values are written to CIO words (n+1) to (n+4).


| Word | Function           | Stored value       |
|------|--------------------|--------------------|
| n+1  | Output 1 set value | 16-bit binary data |
| n+2  | Output 2 set value |                    |
| n+3  | Output 3 set value |                    |
| n+4  | Output 4 set value |                    |

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


Use MOV(021) or XFER(070) to write values in the user program.

**Example 1**

In this example, the set value from only one input is read. (The unit number is 0.)

**Example 2**


In this example, multiple set values are written. (The unit number is #0.)



**Note** If the set value has been written outside the specified range, an output setting error will occur, and the value set by the output hold function will be output.

**Starting and Stopping Conversion**

To begin analog output conversion, turn ON the corresponding Conversion Enable Bit (word n, bits 00 to 03) from the user's program.



Analog conversion is executed while these bits are ON. When the bits are turned OFF, the conversion is stopped and the output data is held.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The analog output when conversion is stopped will differ depending on the output signal range setting and output hold setting. Refer to *Setting Outputs and Signal Ranges* on page 339 and *8-7-2 Output Hold Function*.

Conversion will not begin under the following conditions even if the Conversion Enable Bit is turned ON. Refer to *8-7-2 Output Hold Function*.


**1,2,3...**

1. In adjustment mode, when something other than the output number is output during adjustment.
2. When there is an output setting error.

3. When a fatal error occurs at the PLC.
4. When there is an input disconnection during a ratio conversion.

When the operation mode for the CPU Unit is changed from RUN or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Conversion Enable Bits will all turn OFF. The output status at this time depends on the output hold function.

In this example, conversion is begun for analog output number 1. (The unit number is 0.)



## 8-7-2 Output Hold Function

The Analog I/O Unit stops conversion under the following circumstances and outputs the value set by the output hold function.

- 1,2,3...**
1. When the Conversion Enable Bit is OFF. Refer to *Starting and Stopping Conversion* on page 340.
  2. In adjustment mode, when something other than the output number is output during adjustment. Refer to *8-9-2 Input Offset and Gain Adjustment Procedures*.
  3. When there is an output setting error. Refer to *8-7-3 Output Setting Errors*.
  4. When a fatal error occurs at the PLC.
  5. When there is an input disconnection during ratio conversion.
  6. When there is an I/O bus error.
  7. When the CPU Unit is in LOAD OFF status.
  8. When there is a WDT (watchdog timer) error in the CPU Unit.

CLR, HOLD, or MAX can be selected for the output status when conversion is stopped.

| Output signal range | CLR                              | HOLD                                        | MAX                             |
|---------------------|----------------------------------|---------------------------------------------|---------------------------------|
| 0 to 10 V           | -0.5 V (Min. -5% of full scale)  | Voltage that was output just prior to stop. | 10.5 V (Max. +5% of full scale) |
| -10 to 10 V         | 0.0 V                            | Voltage that was output just prior to stop. | 11.0 V (Max. +5% of full scale) |
| 1 to 5 V            | 0.8 V (Min. -5% of full scale)   | Voltage that was output just prior to stop. | 5.2 V (Max. +5% of full scale)  |
| 0 to 5 V            | -0.25 V (Min. -5% of full scale) | Voltage that was output just prior to stop. | 5.25 V (Max. +5% of full scale) |

The above values may fluctuate if offset/gain adjustment has been applied.

To specify the output hold function, use a Programming Device to set the DM Area words D (m+2) to D (m+5) as shown in the following table.


| DM word | Function                             | Set value                                                                                                                                                                                                   |
|---------|--------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+2) | Output 1: Output status when stopped | xx00: CLR<br>Output 0 or minimum value of range (–5%).<br>xx01: HOLD<br>Hold output value prior to stop.<br>xx02: MAX<br>Output maximum value of range (105%).<br>Set any value in the leftmost bytes (xx). |
| D (m+3) | Output 2: Output status when stopped |                                                                                                                                                                                                             |
| D (m+4) | Output 3: Output status when stopped |                                                                                                                                                                                                             |
| D (m+5) | Output 4: Output status when stopped |                                                                                                                                                                                                             |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**Note** After specifying the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.

### 8-7-3 Output Setting Errors

If the analog output set value is greater than the specified range, a setting error signal will be stored in CIO word n+9 (bits 00 to 03).



When a setting error is detected for a particular output, the corresponding bit turns ON. When the error is cleared, the bit turns OFF.

For the CIO word addresses,  $n = CIO\ 2000 + (\text{unit number} \times 10)$ .

The voltage for an output number at which a setting error has occurred will be output according to the output hold function.

## 8-8 Ratio Conversion Function

The Analog I/O Unit has a ratio conversion function that enables it to perform analog-to-analog conversions by itself, without utilizing the PLC. It can use either Loop 1 (input number 1 → output number 1), Loop 2 (input number 2 → output number 2), Loop 3 (input number 3 → output number 3), or Loop 4 (input number 4 → output number 4).

Input 1 → Ratio bias calculation → Output 1

Input 2 → Ratio bias calculation → Output 2


Input 3 → Ratio bias calculation → Output 3

Input 4 → Ratio bias calculation → Output 4

The relationship between the analog input and the analog output is expressed by the following conversion equations.

### Positive Gradient Conversion

$$(\text{Analog output}) = A \times (\text{Analog input}) + B$$



A: Ratio set value 0 to 99.99 (BCD)

B: Bias 8000 to 7FFF (16-bit binary data)

The following example is for an I/O range of  $-10$  to  $10$  V.

Constant A: 0050 (0.5)


Constant B: 0190 (2.0 V)

Analog input:  $-10$  to  $10$  V

Analog output  
 $= 0.5 \times (-10 \text{ to } 10 \text{ V}) + 2.0 \text{ V}$   
 $= -3.0 \text{ to } 7.0 \text{ V}$

### Negative Gradient Conversion

$$(\text{Analog output}) = F - A \times (\text{Analog input}) + B$$



F: Output range maximum value

A: Ratio set value 0 to 99.99 (BCD)

B: Bias 8000 to 7FFF (16-bit binary data)

The following example is for an I/O range of  $0$  to  $10$  V.

Constant A: 1000 (10.0)

Constant B: 0068 (0.5 V)


F: 10 V (output range maximum value)

Analog input:  $0$  to  $1$  V

Analog output  
 $= 10 \text{ V} - 10 \times (0 \text{ to } 1 \text{ V}) + 0.5 \text{ V}$   
 $= 10.5 \text{ to } 0.5 \text{ V}$

### Specifying Ratio Conversion Function

To specify the use of Loop 1 to Loop 4 and their I/O relationships, set bits 08 to 15 of DM Area word D (m) as shown in the following diagram.



The response time of ratio conversion (input-to-output conversion) is 0.7 ms.  
 For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

### Specifying Ratio Set Value and Bias

The ratio set value (A) and the bias (B) are set in the DM words from D (m+10) to D (m+17).

| DM word  | Function                                   | Set value                                    |
|----------|--------------------------------------------|----------------------------------------------|
| D (m+10) | Loop 1 (input 1 → output 1),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+11) | Loop 1 (input 1 → output 1),<br>B constant | 16-bit binary data                           |
| D (m+12) | Loop 2 (input 2 → output 2),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+13) | Loop 2 (input 2 → output 2),<br>B constant | 16-bit binary data                           |
| D (m+14) | Loop 3 (input 3 → output 3),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+15) | Loop 3 (input 3 → output 3),<br>B constant | 16-bit binary data                           |
| D (m+16) | Loop 4 (input 4 → output 4),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+17) | Loop 4 (input 4 → output 4),<br>B constant | 16-bit binary data                           |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

#### Note

- After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit. For details regarding the Special I/O Unit Restart Bit, refer to 8-10-4 *Restarting Special I/O Units*.
- The calculation results will be output in digital values to word n+5 (Loop 1), word n+6 (Loop 2), word n+7 (Loop 3), and word n+8 (Loop 4).
- If an input cable is disconnected, the calculation value will become 0000, and the analog output value will be output according to the output hold function.
- If the output value exceeds the specified signal range due to the ratio conversion of the digital input value, the calculation result and analog output will be given as the lower-limit or upper-limit value.

## 8-9 Adjusting Offset and Gain

These functions can be used to calibrate inputs or outputs according to the devices that are connected.

### Input Calibration Function

This function takes an output device's offset voltage (or current) and gain voltage (or current) as the analog input conversion data 0000 and 0FA0 (or 07D0 when the range is  $\pm 10$  V). For example, when used in a range of 1 to 5 V, a range of 0.8 to 4.8 V may be output even if the external device specifications are for 1 to 5 V. In such cases, when the external device outputs an offset voltage of 0.8 V, the converted data at the Analog Input Unit will be FF38. When a gain voltage of 4.8 V is output, the converted data will be 0EDA. With the offset and gain adjustment functions, when 0.8 V and 4.8 V are input, then the values are converted to 0000 and 0FA0 respectively (instead of FF38 and 0EDA).

| Output device offset and gain voltage | Converted data before adjustment | Converted data after adjustment |
|---------------------------------------|----------------------------------|---------------------------------|
| 0.8 V                                 | FF38                             | 0000                            |
| 4.8 V                                 | 0EDA                             | 0FA0                            |

### Input Calibration Function


This function adjusts output voltages according to input device offset values and gain values, and takes the presently set values of the Unit to be 0000 and 00FA0 (or 07D0 when the range is  $\pm 10$  V) respectively. For example, assume that the specifications for an external input device (such as a display device) are 100.0 to 500.0. If voltage is output by the Analog Output Unit at a set value of 0000, and the actual display at the external input device shows not 100.0 but 100.5, the output voltage can be adjusted (lowered in this case) so that the display will show 100.0, and the set value (FFFB in this case) when the display shows exactly 100.0 can be set as 0000.

Similarly, for the gain value, if the Analog Output Unit outputs voltage at a set value of 0FA0, and the actual display at the external input device shows not 500.0 but 500.5, the output voltage can be adjusted (lowered in this case) so that the display will show 500.0, and the set value (0F9B in this case) when the display shows exactly 500.0 can be set as 0FA0.

| Display at external input device | Set value before adjustment (word n+8) | Set value after adjustment |
|----------------------------------|----------------------------------------|----------------------------|
| 100.0                            | FFFB                                   | 0000                       |
| 500.0                            | 0F9B                                   | 0FA0                       |

### 8-9-1 Adjustment Mode Operational Flow

The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.



**Caution** Be sure to turn OFF the power to the PLC before changing the setting of the operation mode switch.



**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog I/O Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog I/O Unit will stop operating, and the input and output values that existed immediately before this stoppage will be retained.


**⚠ Caution** Always perform adjustments in conjunction with offset and gain adjustments.

**Note** Input adjustments can be performed more accurately in conjunction with mean value processing.

## 8-9-2 Input Offset and Gain Adjustment Procedures


### Specifying Input Number to be Adjusted

To specify the input number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)




### Bits Used for Adjusting Offset and Gain

The CIO word (n+1) bits shown in the following diagram are used for adjusting offset and gain.



**Offset Adjustment**

The procedure for adjusting the analog input offset is explained below. As shown in the following diagram, the offset is adjusted by sampling inputs so that the conversion value becomes 0000.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

A  
0

MON



200100 ^ OFF

SET

200100 ^ ON

The analog input's digital conversion values while the Offset Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/current switch is ON.

3. Input the voltage or current so that the conversion value becomes 0000. The following table shows the offset adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value |
|--------------------|-----------------|-----------------------------|
| 0 to 10 V          | −0.5 to 0.5 V   | FF38 to 00C8                |
| −10 to 10 V        | −1.0 to 1.0 V   |                             |
| 1 to 5 V           | 0.8 to 1.2 V    |                             |
| 0 to 5 V           | −0.25 to 0.25 V |                             |
| 4 to 20 mA         | 3.2 to 4.8 mA   |                             |

4. After inputting the voltage or current so that the conversion value for the analog input terminal is 0000, turn ON bit 04 (the Set Bit) of CIO word n+1, and then turn it OFF again.

SHIFT CONT C 2 A 0 A 0 B 1 A 0 E 4 MON

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

SHIFT CONT C 2 A 0 A 0 B 1 A 0 A 0 MON

200100 ^ ON

RESET

200100 ^ OFF


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
- The EEPROM can be overwritten 50,000 times.
  - While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

## Gain Adjustment


The procedure for adjusting the analog input gain is explained below. As shown in the following diagram, the gain is adjusted by sampling inputs so that the conversion value is maximized.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)


1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)



The analog input's digital conversion values while the Gain Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/current switch is ON.

3. Input the voltage or current so that the conversion value is maximized (0FA0 or 07D0). The following table shows the gain adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value |
|--------------------|-----------------|-----------------------------|
| 0 to 10 V          | 9.5 to 10.5 V   | 0ED8 to 1068                |
| –10 to 10 V        | 9.0 to 11.0 V   | 0708 to 0898                |
| 1 to 5 V           | 4.8 to 5.2 V    | 0ED8 to 1068                |
| 0 to 5 V           | 4.75 to 5.25 V  | 0ED8 to 1068                |
| 4 to 20 mA         | 19.2 to 20.8 mA | 0ED8 to 1068                |

4. With the voltage or current having been input so that the conversion value for the Analog I/O Unit is maximized (0FA0 or 07D0), turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

E  
4

MON

200104      ^    OFF

SET

200104      ^    ON

RESET

200104      ^    OFF

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

SHIFT

CONT  
#

C  
2

A  
0

A  
0

B  
1

A  
0

B  
1

MON

200101      ^    ON

RESET

200101      ^    OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
1. The EEPROM can be overwritten 50,000 times.
  2. While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

**Clearing Offset and Gain Adjusted Values**

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the input value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105      ^    OFF

200105      ^    ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104      ^    OFF

200104      ^    ON

200104      ^    OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105      ^    ON

200105      ^    OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.


**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### 8-9-3 Output Offset and Gain Adjustment Procedures


#### Specifying Output Number to be Adjusted

To specify the output number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)




#### Bits Used for Adjusting Offset and Gain

The CIO word n+1 bits shown in the following diagram are used for adjusting offset and gain.



#### Offset Adjustment

The procedure for adjusting the analog output offset is explained below. As shown in the following diagram, the set value is adjusted so that the analog output reaches the standard value (0V/1V).



The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0


A 0

MON

200100
^ OFF

200100
^ ON

2. Check whether the output devices are connected.



3. Monitor CIO word n+8 and check the set value while the Offset Bit is ON.

CLR

000000 CT00

SHIFT

CH  
\*DM

C 2

A 0

A 0

8

MON


2008
0000

4. Change the set value so that the output voltage are as shown in the following table. The data can be set within the indicated ranges.


| Output signal range | Possible output voltage/<br>current adjustment | Output range |
|---------------------|------------------------------------------------|--------------|
| 0 to 10 V           | −0.5 to 0.5 V                                  | FF38 to 00C8 |
| −10 to 10 V         | −1.0 to 1.0 V                                  |              |
| 1 to 5 V            | 0.8 to 1.2 V                                   |              |
| 0 to 5 V            | −0.25 to 0.25 V                                |              |



Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.




The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.



5. Check the 0-V/1-V output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200100 ^ ON

SET

200100 ^ OFF


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### Gain Adjustment

The procedure for adjusting the analog output gain is explained below. As shown in the following diagram, the set value is adjusted so that the analog output is maximized (to 10 V/5 V).



The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

- 1,2,3...
1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT#

C2

A0

A0

B1

A0

B1

MON

200101


^ OFF

SET

200101

^ ON

2. Check whether the output devices are connected.



3. Monitor CIO word n+8 and check the set value while the Gain Bit is ON.

CLR

000000 CT00

SHIFT

CH\*DM

C2

A0

A0

8

MON


2008

0000


4. Change the set value so that the output voltage is as shown in the following table. The data can be set within the indicated ranges.

| Output signal range | Possible output voltage/<br>current adjustment | Output range |
|---------------------|------------------------------------------------|--------------|
| 0 to 10 V           | 9.5 to 10.5 V                                  | 0ED8 to 1068 |
| −10 to 10 V         | 9.0 to 11.0 V                                  | 0708 to 0898 |
| 1 to 5 V            | 4.8 to 5.2 V                                   | 0ED8 to 1068 |
| 0 to 5 V            | 4.75 to 5.25 V                                 | 0ED8 to 1068 |


Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.




The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



5. Check the 10V/5V output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200101 ^ ON

RESET

200101 ^ OFF

**! Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**! Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### Clearing Offset and Gain Adjusted Values

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

- 1,2,3...** 1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the set value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

SET

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

|     |
|-----|
| SET |
|-----|

200104 ^ ON

|       |
|-------|
| RESET |
|-------|

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ ON

|       |
|-------|
| RESET |
|-------|

200105 ^ OFF

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Note** The EEPROM can be overwritten 50,000 times.


## 8-10 Handling Errors and Alarms

### 8-10-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog I/O Unit, the ERC or ERH indicators on the front panel of the Unit will light.


Front panel of Unit



| LED          | Meaning                    | Indicator | Operating status                                                                        |
|--------------|----------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating                  | Lit       | Operating in normal mode.                                                               |
|              |                            | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Unit has detected an error | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                            | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting                  | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                            | Not lit   | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit      | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                            | Not lit   | Operating normally.                                                                     |

**Troubleshooting Procedure**


Use the following procedure for troubleshooting Analog I/O Unit errors.






## 8-10-2 Alarms Occurring at the Analog I/O Unit

When an alarm occurs at the Analog I/O Unit, the ERC indicator lights and the Alarm Flags are stored in bits 08 to 15 of CIO word n+9.



### ERC and RUN Indicators: Lit




The ERC and RUN indicators will be lit when an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| Word n + 9    | Alarm flag                                | Error contents                                                 | I/O status                                              | Countermeasure                                                                                                                  |
|---------------|-------------------------------------------|----------------------------------------------------------------|---------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| Bits 00 to 03 | Output Set Value Error                    | The output setting range has been exceeded.                    | Output value set by output hold function.               | Correct the set value.                                                                                                          |
| Bits 04 to 07 | Disconnection Detection                   | A disconnection was detected. (See note.)                      | Conversion data becomes 0000.                           | Check the rightmost byte of CIO word n+9. The inputs for bits that are ON may be disconnected. Restore any disconnected inputs. |
| Bit 14        | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the output status immediately prior to the error. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog I/O Unit.            |

**Note** Disconnection detection operates for input numbers used with a range of 1 to 5 V (4 to 20 mA).


For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

**ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing**

This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.

| Word n + 9     | Alarm flag                                                 | Error contents                                                                                                                                                               | I/O status                                                                  | Countermeasure                                                                                                                                                                                       |
|----------------|------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 12         | (Adjustment mode)<br>Input Value Adjustment Range Exceeded | In adjustment mode, offset or gain cannot be adjusted because input value is out of the permissible range for adjustment.                                                    | Conversion data corresponding to the input signal is monitored in word n+8. | If making the adjustment by means of a connected input device, first adjust the input device before adjusting the Analog I/O Unit.                                                                   |
| Bit 13         | (Adjustment mode)<br>I/O Number Setting Error              | In adjustment mode, adjustment cannot be performed because the specified input or output number is not set for use or because the wrong input or output number is specified. | Holds the values immediately prior to the error. No data is changed.        | Check whether the word n input or output number to be adjusted is set from 11 to 14, or 21 to 24. Check whether the input or output number to be adjusted is set for use by means of the DM setting. |
| Bit 15 only ON | (Adjustment Mode)<br>PLC Error                             | The PLC is in either MONITOR or RUN mode while the Analog I/O Unit is operating in adjustment mode.                                                                          | Holds the values immediately prior to the error. No data is changed.        | Detach the Unit. Switch the rear panel DIP switch pin to OFF. Restart the Unit in normal mode.                                                                                                       |

**Note** When a PLC error occurs in the adjustment mode, Unit operations will stop operating. (The input and output values immediately prior to the error will be held.)

**ERC Indicator: Lit, RUN Indicator: Not Lit**

The ERC indicator will be lit when the initial settings for the Analog I/O Unit are not set correctly. The alarm flags for the following errors will turn ON in CIO word n+9. These alarm flags will turn OFF when the error is cleared and


the Unit is restarted, or the Special I/O Unit Restart Bit is turned ON and then OFF again.

| Word n + 9 | Alarm flag                          | Error contents                                                                          | I/O status                                       | Countermeasure                       |
|------------|-------------------------------------|-----------------------------------------------------------------------------------------|--------------------------------------------------|--------------------------------------|
| Bit 08     | Ratio Conversion Use Setting Error  | The I/O number for the ratio conversion function has been set to be not used.           | Conversion does not start and data becomes 0000. | Set the I/O number for use.          |
| Bit 09     | Ratio Set Value Error               | A number outside of the 0 to 9999 BCD range has been specified for the ratio set value. |                                                  | Specify a number from 0 to 9999 BCD. |
| Bit 10     | Output Hold Setting Error           | The wrong output status for when conversion is stopped has been specified.              |                                                  | Specify a number from 0000 to 0002.  |
| Bit 11     | Mean Value Processing Setting Error | The wrong number of samplings has been specified for mean processing.                   |                                                  | Specify a number from 0000 to 0006.  |

### 8-10-3 Errors in the CPU Unit

When errors occur in the CPU Unit or I/O bus, and I/O refresh with the Special I/O Unit is not performed correctly resulting in the Analog I/O Unit malfunctioning, the ERH indicator will be lit.

#### ERH and RUN Indicators: Lit



The ERH and RUN indicators will be lit if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog I/O Unit.


Turn ON the power supply again or restart the system.

For further details, refer to *CS-series CS1G/H-CPU□□-EV1, CS1G/H-CPU□□H Programmable Controllers Operation Manual (W339)*.

| Error                                | Error contents                                             | Input condition                                    | Output condition                                   |
|--------------------------------------|------------------------------------------------------------|----------------------------------------------------|----------------------------------------------------|
| I/O bus error                        | Error has occurred during data exchange with the CPU Unit. | Conversion data becomes 0000.                      | Depends on the output hold function.               |
| CPU Unit monitoring error (see note) | No response from CPU Unit during fixed period.             | Maintains the condition existing before the error. | Maintains the condition existing before the error. |
| CPU Unit WDT error                   | Error has been generated in CPU Unit.                      | Changes to undefined state.                        | Depends on the output hold function.               |

**Note** No error will be detected by the CPU Unit or displayed on the Programming Console, because the CPU Unit is continuing operation.

ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number for the Analog I/O Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Input condition                                  | Output condition              |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|-------------------------------|
| Duplicate Unit Number          | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | Conversion does not start and data becomes 0000. | The output value will be 0 V. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                                                  |                               |

### 8-10-4 Restarting Special I/O Units

There are two ways to restart Special I/O Unit operation after having changed DM contents or having cleared the cause of an error. The first way is to turn the power to the PLC OFF and ON, and the second way is to turn ON the Special I/O Unit Restart Bit ON.

#### Special I/O Unit Restart Bits

| Bits   | Functions            |                                                                                |
|--------|----------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit  | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit  |                                                                                |
| to     | to                   |                                                                                |
| A50215 | Unit #15 Restart Bit |                                                                                |
| A50300 | Unit #16 Restart Bit |                                                                                |
| to     | to                   |                                                                                |
| A50715 | Unit #95 Restart Bit |                                                                                |

If the error is not cleared even after turning the Special I/O Unit Restart Bit ON and then OFF again, then replace the Unit.

There previous input data will be held and the output will be 0 V while restarting the Unit.

### 8-10-5 Troubleshooting

The following tables explain the probable causes of troubles that may occur, and the countermeasures for dealing with them.

#### Conversion Data Does Not Change

| Probable cause                                                                           | Countermeasure                                                            | Page |
|------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|------|
| The input is not set for being used.                                                     | Set the input to be used.                                                 | 332  |
| The peak value hold function is in operation.                                            | Turn OFF the peak value hold function if it is not required.              | 337  |
| The input device is not working, the input wiring is wrong, or there is a disconnection. | Using a tester, check to see if the input voltage or current is changing. | ---  |
|                                                                                          | Use Unit's alarm flags to check for a disconnection.                      | 338  |

**Value Does Not Change as Intended**

| Probable cause                                                                                                              | Countermeasure                                                                                    | Page     |
|-----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|----------|
| The input device's signal range does not match the input signal range for the relevant input number at the Analog I/O Unit. | Check the specifications of the input device, and match the settings for the input signal ranges. | 305      |
| The offset and gain are not adjusted.                                                                                       | Adjust the offset and gain.                                                                       | 345      |
| When using the 4 mA to 20 mA range, the voltage/current switch is not turned ON.                                            | Turn ON the voltage/current switch.                                                               | 311, 318 |
| The ratio conversion function is set to be used, so the calculation results are being monitored.                            | Correct the conversion settings.                                                                  | 363      |

**Conversion Values are Inconsistent**

| Probable cause                                          | Countermeasure                                                                                                        | Page |
|---------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|------|
| The input signals are being affected by external noise. | Change the shielded cable connection to the Unit's COM terminal.                                                      | 323  |
|                                                         | Insert a 0.01- $\mu$ F to 0.1- $\mu$ F ceramic capacitor or film capacitor between the input's (+) and (-) terminals. | ---  |
|                                                         | Try increasing the number of mean value processing buffers.                                                           | 334  |

**Analog Output Does Not Change**

| Probable Cause                                                | Countermeasure                            | Page     |
|---------------------------------------------------------------|-------------------------------------------|----------|
| The output is not set for being used.                         | Set the output to be used.                | 339      |
| The output hold function is in operation.                     | Turn ON the Output Conversion Enable Bit. | 341      |
| The conversion value is set outside of the permissible range. | Set the data within the range.            | 307, 339 |

**Output Does Not Change as Intended**

| Probable Cause                                                                                                                     | Countermeasure                           | Page |
|------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------|
| The output signal range setting is wrong.                                                                                          | Correct the output signal range setting. | 339  |
| The I/O specifications of the output device do not match those of the Analog I/O Unit (e.g., input signal range, input impedance). | Change the output device.                | 303  |
| The offset or gain is not adjusted.                                                                                                | Adjust the offset or gain.               | 345  |
| The ratio conversion function is set to be used.                                                                                   | Correct the conversion settings.         | 342  |

**Outputs are Inconsistent**

| Probable Cause                                           | Countermeasure                                                                         | Page |
|----------------------------------------------------------|----------------------------------------------------------------------------------------|------|
| The output signals are being affected by external noise. | Try changing the shielded cable connection (e.g., the grounding at the output device). | ---  |



# SECTION 9

## CJ-series Analog I/O Unit (CJ1W-MAD42)

This section explains how to use the CJ1W-MAD42 Analog I/O Unit.

|        |                                                        |     |
|--------|--------------------------------------------------------|-----|
| 9-1    | Specifications .....                                   | 370 |
| 9-1-1  | Specifications .....                                   | 370 |
| 9-1-2  | I/O Function Block Diagram .....                       | 372 |
| 9-1-3  | Input Specifications .....                             | 373 |
| 9-1-4  | Output Specifications .....                            | 375 |
| 9-2    | Operating Procedure .....                              | 377 |
| 9-2-1  | Procedure Examples .....                               | 378 |
| 9-3    | Components and Switch Settings .....                   | 384 |
| 9-3-1  | Indicators .....                                       | 385 |
| 9-3-2  | Unit Number Switches .....                             | 385 |
| 9-3-3  | Voltage/Current Switch .....                           | 386 |
| 9-4    | Wiring .....                                           | 387 |
| 9-4-1  | Terminal Arrangement .....                             | 387 |
| 9-4-2  | Internal Circuitry .....                               | 387 |
| 9-4-3  | Voltage Input Disconnection .....                      | 389 |
| 9-4-4  | I/O Wiring Example .....                               | 390 |
| 9-4-5  | I/O Wiring Considerations .....                        | 391 |
| 9-5    | Exchanging Data with the CPU Unit .....                | 391 |
| 9-5-1  | Outline of Data Exchange .....                         | 391 |
| 9-5-2  | Unit Number Settings .....                             | 392 |
| 9-5-3  | Operation Mode Setting .....                           | 392 |
| 9-5-4  | Special I/O Unit Restart Bits .....                    | 393 |
| 9-5-5  | Fixed Data Allocations .....                           | 394 |
| 9-5-6  | I/O Refresh Data Allocations .....                     | 397 |
| 9-6    | Analog Input Functions and Operating Procedures .....  | 400 |
| 9-6-1  | Input Settings and Conversion Values .....             | 400 |
| 9-6-2  | Conversion Time and Resolution Setting .....           | 402 |
| 9-6-3  | Mean Value Processing .....                            | 402 |
| 9-6-4  | Peak Value Hold Function .....                         | 405 |
| 9-6-5  | Input Scaling Function .....                           | 406 |
| 9-6-6  | Input Disconnection Detection Function .....           | 408 |
| 9-7    | Analog Output Functions and Operating Procedures ..... | 409 |
| 9-7-1  | Output Settings and Conversions .....                  | 409 |
| 9-7-2  | Conversion Time and Resolution Setting .....           | 411 |
| 9-7-3  | Output Hold Function .....                             | 412 |
| 9-7-4  | Output Scaling Function .....                          | 413 |
| 9-7-5  | Output Setting Errors .....                            | 415 |
| 9-8    | Ratio Conversion Function .....                        | 415 |
| 9-9    | Adjusting Offset and Gain .....                        | 418 |
| 9-9-1  | Adjustment Mode Operational Flow .....                 | 419 |
| 9-9-2  | Input Offset and Gain Adjustment Procedures .....      | 420 |
| 9-9-3  | Output Offset and Gain Adjustment Procedures .....     | 426 |
| 9-10   | Handling Errors and Alarms .....                       | 434 |
| 9-10-1 | Indicators and Error Flowchart .....                   | 434 |
| 9-10-2 | Alarms Occurring at the Analog I/O Unit .....          | 436 |
| 9-10-3 | Errors in the CPU Unit .....                           | 438 |
| 9-10-4 | Restarting Special I/O Units .....                     | 439 |
| 9-10-5 | Troubleshooting .....                                  | 439 |

## 9-1 Specifications

### 9-1-1 Specifications

| Item                                     | CJ1W-MAD42                                                                                                                                                                  |                                          |                                                        |
|------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|--------------------------------------------------------|
| Unit type                                | CJ-series Special I/O Unit                                                                                                                                                  |                                          |                                                        |
| Isolation                                | Between I/O and PLC signals: Photocoupler<br>(No isolation between I/O signals.)                                                                                            |                                          |                                                        |
| External terminals                       | 18-point detachable terminal block (M3 screws)                                                                                                                              |                                          |                                                        |
| Current consumption                      | 580 mA max. at 5 V DC                                                                                                                                                       |                                          |                                                        |
| Dimensions (mm)<br>(See note 1.)         | 31 × 90 × 65 (W × H × D)                                                                                                                                                    |                                          |                                                        |
| Weight                                   | 150 g max.                                                                                                                                                                  |                                          |                                                        |
| General specifications                   | Conforms to general specifications for SYSMAC CJ-series Series.                                                                                                             |                                          |                                                        |
| Mounting position                        | CJ-series CPU Rack or CJ-series Expansion Rack<br>(Cannot be mounted to a C200H Expansion I/O Rack or a SYSMAC BUS Slave Rack.)                                             |                                          |                                                        |
| Maximum number of Units<br>(See note 2.) | Per CPU Rack or Expansion Rack (See note 2.)                                                                                                                                | Power Supply Unit                        | No. of mountable Units                                 |
|                                          |                                                                                                                                                                             | CJ1W-PA205R<br>CJ1W-PA205C<br>CJ1W-PD025 | CPU Rack: 7 Units/Rack<br>Expansion Rack: 8 Units/Rack |
|                                          |                                                                                                                                                                             | CJ1W-PA202                               | CPU Rack: 4 Units/Rack<br>Expansion Rack: 4 Units/Rack |
|                                          |                                                                                                                                                                             | CJ1W-PD022                               | CPU Rack: 2 Units/Rack<br>Expansion Rack: 3 Units/Rack |
| Data exchange with CPU Units             | Special I/O Unit Area CIO 200000 to CIO295915 (Words CIO 2000 to CIO 2959):<br>Exchanges 10 words of data per Unit.<br>Internal Special I/O Unit DM Area (D20000 to D29599) |                                          |                                                        |

- Note**
1. Refer to *Appendix A Dimensions* on page 441 for details on the Unit's dimensions.
  2. This is the maximum number of Units that can be mounted to a CJ2H-CPU6□ CPU Unit (no EtherNet/IP). The maximum number of Analog Output Units that can be mounted to one Rack varies depending on the current consumption of the other Units mounted to the Rack.

### Input Specifications and Functions

| Item                                            |             | Voltage input                                                                                                                                                    | Current input               |
|-------------------------------------------------|-------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| Number of analog inputs                         |             | 4                                                                                                                                                                |                             |
| Input signal range (See note 3.)                |             | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>−10 to 10 V                                                                                                                 | 4 to 20 mA<br>(See note 4.) |
| Maximum rated input (for 1 point) (See note 5.) |             | ±15 V                                                                                                                                                            | ±30 mA                      |
| External input impedance                        |             | 1 MΩ min.                                                                                                                                                        | 250 Ω (rated value)         |
| Resolution                                      |             | 4,000/8,000 (full scale) (See note 8.)                                                                                                                           |                             |
| Converted output data                           |             | 16-bit binary data                                                                                                                                               |                             |
| Accuracy<br>(See note 6.)                       | 25°C        | ±0.2% of full scale                                                                                                                                              |                             |
|                                                 | 0°C to 55°C | ±0.4% of full scale                                                                                                                                              |                             |
| A/D conversion time (See note 7.)               |             | 1.0 ms/500 μs max. per point                                                                                                                                     |                             |
| Mean value processing                           |             | Stores the last “n” data conversions in the buffer, and stores the mean value of the conversion values.<br>Number of mean value buffers: n = 2, 4, 8, 16, 32, 64 |                             |
| Peak value holding                              |             | Stores the maximum conversion value while the Peak Value Hold Bit is ON.                                                                                         |                             |



| Item                          | Voltage input                                                                                                                                                                                                                    | Current input |
|-------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| Scaling                       | Enabled only for conversion time of 1 ms and resolution of 4,000. Setting any values within a range of $\pm 32,000$ as the upper and lower limits allows the A/D conversion result to be output with these values as full scale. |               |
| Input disconnection detection | Detects the disconnection and turns ON the Disconnection Detection Flag.                                                                                                                                                         |               |


- Input and output signal ranges can be set for each input and output.
- Voltage input or current input are chosen by using the voltage/current switch at the back of the terminal block.
- The Analog I/O Unit must be operated according to the input specifications provided here. Operating the Unit outside these specifications will cause the Unit to malfunction.
- The accuracy is given for full scale. For example, an accuracy of  $\pm 0.2\%$  means a maximum error of  $\pm 8$  (BCD).
- A/D conversion time is the time it takes for an analog signal to be stored in memory as converted data after it has been input. It takes at least one cycle before the converted data is read by the CPU Unit.
- By means of the D(m+18) setting, the resolution can be changed to 8,000, and the conversion time can be changed to 500  $\mu\text{s}$ .

## Output Specifications

| Item                                          |             | Voltage output                                                                                                                                                                                                                                                                                                                                                                                         | Current output            |
|-----------------------------------------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------|
| Number of analog outputs                      |             | 2                                                                                                                                                                                                                                                                                                                                                                                                      |                           |
| Output signal range (See note 1.)             |             | 1 to 5 V<br>0 to 5 V<br>0 to 10 V<br>-10 to 10 V                                                                                                                                                                                                                                                                                                                                                       | 4 to 20 mA                |
| External output impedance                     |             | 0.5 $\Omega$ max.                                                                                                                                                                                                                                                                                                                                                                                      | ---                       |
| Maximum external output current (for 1 point) |             | 2.4 mA                                                                                                                                                                                                                                                                                                                                                                                                 | ---                       |
| Maximum allowed load resistance               |             | ---                                                                                                                                                                                                                                                                                                                                                                                                    | 600 $\Omega$              |
| Resolution                                    |             | 4,000/8,000 (full scale) (See note 5.)                                                                                                                                                                                                                                                                                                                                                                 |                           |
| Set data                                      |             | 16-bit binary data                                                                                                                                                                                                                                                                                                                                                                                     |                           |
| Accuracy (See note 2.)                        | 25°C        | $\pm 0.3\%$ of full scale                                                                                                                                                                                                                                                                                                                                                                              | $\pm 0.3\%$ of full scale |
|                                               | 0°C to 55°C | $\pm 0.5\%$ of full scale                                                                                                                                                                                                                                                                                                                                                                              | $\pm 0.6\%$ of full scale |
| D/A conversion time (See note 3.)             |             | 1.0 ms/500 $\mu\text{s}$ max. per point                                                                                                                                                                                                                                                                                                                                                                |                           |
| Output hold function                          |             | Outputs the specified output status (CLR, HOLD, or MAX) under any of the following circumstances.<br>When the Conversion Enable Bit is OFF. (See note 4.)<br>In adjustment mode, when a value other than the output number is output during adjustment.<br>When there is an output setting error or a fatal error occurs at the PLC.<br>When the Load is OFF.                                          |                           |
| Scaling                                       |             | Enabled only for conversion time or 1 ms and resolution of 4,000. Setting any values within a range of $\pm 32,000$ as the upper and lower limits allows D/A conversion to be executed and analog signals to be output with these values as full scale.                                                                                                                                                |                           |
| Ratio conversion function                     |             | Stores the results of positive and negative gradient analog inputs calculated for ratio and bias as analog output values.<br>Positive gradient: Analog output = $A \times \text{Analog input} + B$<br>(A = 0 to 99.99, B = 8,000 to 7FFF hex)<br>Negative gradient: Analog output = $F - A \times \text{Analog input} + B$<br>(A: 0 to 99.99, B = 8,000 to 7FFF hex,<br>F: Output range maximum value) |                           |

1. Input and output signal ranges can be set for each input and output.
2. The accuracy is given for full scale. For example, an accuracy of  $\pm 0.2\%$  means a maximum error of  $\pm 8$  (BCD) at a resolution of 4,000.
3. D/A conversion time is the time required for converting and outputting the PLC data. It takes at least one cycle for the data stored in the PLC to be read by the Analog I/O Unit.
4. When the operation mode for the CPU Unit is changed from RUN mode or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Output Conversion Enable Bit will turn OFF. The output status specified according to the output hold function will be output.
5. By means of the D(m+18) setting, the resolution can be changed to 8,000, and the conversion time can be changed to 500  $\mu\text{s}$ .


### 9-1-2 I/O Function Block Diagram




### 9-1-3 Input Specifications



If signals that are outside the specified range provided below are input, the conversion values used will be at either the maximum or minimum value.

#### Range: 1 to 5 V (4 to 20 mA)



#### Range: 0 to 10 V




**Range: 0 to 5 V****Range: -10 to 10 V**

### 9-1-4 Output Specifications

If the set value is outside the specified range provided below, the output setting will be fixed at the maximum or the minimum value.

#### Range: 1 to 5 V

Analog output signal




Set value (16-bit binary data)

( ): Values in parentheses are for a resolution of 8,000.

#### Range: 0 to 10 V

Analog output signal




Set value (16-bit binary data)

( ): Values in parentheses are for a resolution of 8,000.

**Range: 0 to 5 V**


Analog output signal



Set value (16-bit binary data)  
 ( ): Values in parentheses are for a resolution of 8,000.

**Range: -10 to 10 V**

Analog output signal



Set value (16-bit binary data)  
 ( ): Values in parentheses are for a resolution of 8,000.

**Note** The conversion values and set values for a range of -10 to 10 V will be as follows:

| 16-bit binary data | BCD (Resolution: 4,000) |
|--------------------|-------------------------|
| F768               | -2200                   |
| :                  | :                       |
| FFFF               | -1                      |
| 0000               | 0                       |
| 0001               | 1                       |
| :                  | :                       |
| 0898               | 2200                    |

## 9-2 Operating Procedure

Follow the procedure outlined below when using Analog I/O Units.

### Installation and Settings

- 1,2,3...**
1. Set the voltage/current switch at the back of the terminal block.
  2. Wire the Unit.
  3. Use the unit number switches on the front panel of the Unit to set the unit number.
  4. Turn ON the power to the PLC.
  5. Create the I/O tables.
  6. Make the Special I/O Unit DM Area settings.
    - Set the I/O numbers to be used.
    - Set the input and output signal ranges.
    - Set the number of mean processing samplings.
    - Set the output hold function
    - Set the scaling function.
    - Set the ratio conversion usage, the ratio set value, and the bias value.
    - Set the conversion time and resolution.
  7. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.

When the input or output of the connected devices needs to be calibrated, follow the procedures in *Offset Gain Adjustment* below. Otherwise, skip to *Operation* below.

### Offset and Gain Adjustment


- 1,2,3...**
1. Set the voltage/current switch at the back of the terminal block.
  2. Turn ON the power to the PLC.
  3. Set to adjustment mode in the Special I/O Unit DM Area.
  4. Turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit.
  5. Adjust the offset and gain.
  6. Set to normal mode in the Special I/O Unit DM Area.
  7. Restart the Analog I/O Unit by turning ON the Special I/O Unit Restart Bit or turn the power supply to the PLC OFF and ON.

### Operation

#### Ladder program

- Read conversion values or write set values by means of MOV(021) and XFER(070).
- Start and stop conversion output.
- Specify the peak hold function.
- Obtain disconnection notifications and error codes.


## 9-2-1 Procedure Examples




### Setting the Analog I/O Unit

1,2,3...

1. Set the voltage/current switch. Refer to 9-3-3 *Voltage/Current Switch* for further details.




2. Mount and wire the Analog I/O Unit. Refer to 1-2-1 *Mounting Procedure*, 9-4 *Wiring* or 9-4-4 *I/O Wiring Example* for further details.






3.
- Set the unit number switches. Refer to 9-3-2 Unit Number Switches for further details.



4.
- Turn ON the power to the PLC.

Creating I/O Tables


After turning ON the power to the PLC, be sure to create the I/O tables.



Programming Console

Initial Data Settings

- 1,2,3...
1. Specify the Special I/O Unit DM Area settings. Refer to Allocations in DM Area on page 394 for further details.



Setting conditions


Unit No. 1

Analog input 1: 1 to 5 V  
Analog input 2: 0 to 10 V  
Analog input 3: 4 to 20 mA  
Analog input 4: 4 to 20 mA


Analog output 1: 0 to 10 V  
Analog output 2: 4 to 20 mA

Programming Console


- The following diagram shows the input and output settings used. Refer to 9-6-1 *Input Settings and Conversion Values* or 9-7-1 *Output Settings and Conversions* for more details.




- The following diagram shows the input and output range settings. Refer to 9-6-1 *Input Settings and Conversion Values* or 9-7-1 *Output Settings and Conversions* for more details.



- Set the conversion time and resolution.




- Set the voltage/current range.




2. Restart the CPU Unit.

Power turned ON again  
(or Special I/O Unit Restart  
Bit is turned ON).



Creating Ladder Programs



Programming Console    Personal computer

1,2,3...


1. The following example describes how to use analog inputs.
- The data that is converted from analog to digital and output to CIO words (n + 5) to (n+8) of the Special I/O Unit Area (CIO 2015 to CIO2018), is stored in the specified addresses D00100 to D00103 as signed binary values 0000 to 0FA0 hex.

- The following table shows the addresses used for analog input.

| Input number | Input signal range | Input conversion value address<br>(n = CIO 2010)<br>(See note a.) | Conversion data holding address<br>(See note b.) |
|--------------|--------------------|-------------------------------------------------------------------|--------------------------------------------------|
| 1            | 1 to 5 V           | (n+5) = CIO 2015                                                  | D00100                                           |
| 2            | 0 to 10 V          | (n+6) = CIO 2016                                                  | D00101                                           |
| 3            | 4 to 20 mA         | (n+7) = CIO 2017                                                  | D00102                                           |
| 4            | 4 to 20 mA         | (n+8) = CIO 2018                                                  | D00103                                           |

**Note a)** The addresses are set according to the unit number of the Special I/O Unit. Refer to 9-3-2 Unit Number Switches for further details.

## b) Set as required.



c) The input Disconnection Detection Flag is allocated to bits 04 to 07 of word (n+9). Refer to *Allocations for Normal Mode* on page 398 and *9-6-6 Input Disconnection Detection Function* for further details.

2. The following example shows how to use analog outputs.


The setting address D00200 is stored in words (n+1) to (n+2) of the Special I/O Unit Area (CIO 2011 to CIO 2012) as a signed binary value between 0000 to 0FA0 hex.

- The following table shows the addresses used for analog output.


| Output number | Input signal range | Output setting address<br>(n = CIO 2010)<br>(See note a.) | Original conversion address<br>(See note b.) |
|---------------|--------------------|-----------------------------------------------------------|----------------------------------------------|
| 1             | 0 to 10 V          | (n+1) = CIO 2011                                          | D00200                                       |
| 2             | 4 to 20 mA         | (n+2) = CIO 2012                                          | D00201                                       |

**Note a)** The addresses are set according to the unit number of the Special I/O Unit. Refer to *9-3-2 Unit Number Switches* for further details.

b) Set as required.




## 9-3 Components and Switch Settings



The terminal block is attached using a connector mechanism. It can be removed by lowering the lever at the bottom of the terminal block.

The lever must normally be in the raised position. Confirm this before operation.



### 9-3-1 Indicators


The indicators show the operating status of the Unit. The following table shows the meanings of the indicators.

| LED          | Meaning                | Indicator | Operating status                                                                        |
|--------------|------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating              | Lit       | Operating in normal mode.                                                               |
|              |                        | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Error detected by Unit | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                        | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting              | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                        | Not lit   | Other than the above.                                                                   |
| ERH (red)    | Error in the CPU Unit  | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                        | Not lit   | Operating normally.                                                                     |

### 9-3-2 Unit Number Switches

The CPU Unit and Analog I/O Unit exchange data via the Special I/O Unit Area and the Special I/O Unit DM Area. The Special I/O Unit Area and Special I/O Unit DM Area word addresses that each Analog I/O Unit occupies are set by the unit number switches on the front panel of the Unit.

Always turn OFF the power before setting the unit number. Use a flat-blade screwdriver, being careful not to damage the slot in the screw. Be sure not to leave the switch midway between settings.




| Switch setting | Unit number | Special I/O Unit Area addresses                   | Special I/O Unit DM Area addresses               |
|----------------|-------------|---------------------------------------------------|--------------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                              | D20000 to D20099                                 |
| 1              | Unit #1     | CIO 2010 to CIO 2019                              | D20100 to D20199                                 |
| 2              | Unit #2     | CIO 2020 to CIO 2029                              | D20200 to D20299                                 |
| 3              | Unit #3     | CIO 2030 to CIO 2039                              | D20300 to D20399                                 |
| 4              | Unit #4     | CIO 2040 to CIO 2049                              | D20400 to D20499                                 |
| 5              | Unit #5     | CIO 2050 to CIO 2059                              | D20500 to D20599                                 |
| 6              | Unit #6     | CIO 2060 to CIO 2069                              | D20600 to D20699                                 |
| 7              | Unit #7     | CIO 2070 to CIO 2079                              | D20700 to D20799                                 |
| 8              | Unit #8     | CIO 2080 to CIO 2089                              | D20800 to D20899                                 |
| 9              | Unit #9     | CIO 2090 to CIO 2099                              | D20900 to D20999                                 |
| 10             | Unit #10    | CIO 2100 to CIO 2109                              | D21000 to D21099                                 |
| to             | to          | to                                                | to                                               |
| n              | Unit #n     | CIO 2000 + (n × 10) to<br>CIO 2000 + (n × 10) + 9 | D20000 + (n × 100) to<br>D20000 + (n × 100) + 99 |
| to             | to          | to                                                | to                                               |
| 95             | Unit #95    | CIO 2950 to CIO 2959                              | D29500 to D29599                                 |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

### 9-3-3 Voltage/Current Switch

The analog conversion input can be switched from voltage input to current input by changing the pin settings on the voltage/current switch located on the back of the terminal block.



**Caution** Be sure to turn OFF the power to the PLC before mounting or removing the terminal block.



## 9-4 Wiring

### 9-4-1 Terminal Arrangement

The signal names corresponding to the connecting terminals are as shown in the following diagram.


|                      |    |    |                      |
|----------------------|----|----|----------------------|
| Voltage output 2 (+) | B1 | A1 | Voltage output 1 (+) |
| Output 2 (–)         | B2 | A2 | Output 1 (–)         |
| Current output 2 (+) | B3 | A3 | Current output 1 (+) |
| N.C.                 | B4 | A4 | N.C.                 |
| Input 2 (+)          | B5 | A5 | Input 1 (+)          |
| Input 2 (–)          | B6 | A6 | Input 1 (–)          |
| AG                   | B7 | A7 | AG                   |
| Input 4 (+)          | B8 | A8 | Input 3 (+)          |
| Input 4 (–)          | B9 | A9 | Input 3 (–)          |

- Note**
1. The analog I/O numbers that can be used are set in the Data Memory (DM).
  2. The I/O signal ranges for individual inputs and outputs are set in the Data Memory (DM). They can be set in units of I/O numbers.
  3. The AG terminal (A7, B7) is connected to the 0-V analog circuit in the Unit. Connecting shielded input lines can improve noise resistance.
  4. The N.C. terminals (A4, B4) are not connected to internal circuitry.


### 9-4-2 Internal Circuitry

The following diagrams show the internal circuitry of the analog I/O section.


#### Input Circuitry




#### Output Circuitry




## Current Output Circuitry



## Internal Configuration



### 9-4-3 Voltage Input Disconnection




**Note** If the connected device #2 in the above example outputs 5 V and the power supply is shared by 2 channels as shown in the above diagram, approximately one third of the voltage, or 1.6 V, will be input at input 1.

When voltage inputs are used and a disconnection occurs, separate the power supply at the side of the connected devices or use an insulating device (isolator) for each input to avoid the following problems.


When the power supply at the connected devices is shared and section A or B is disconnected, power will flow in the direction of the broken line and the output voltage of the other connected devices will be reduced to between a third to a half of the voltage. If 1 to 5 V is used and the reduced voltage output, disconnection may not be detectable. If section C is disconnected, the power at the (–) input terminal will be shared and disconnection will not be detectable.

For current inputs, sharing the power supply between the connected devices will not cause any problems.

### 9-4-4 I/O Wiring Example



- Note**
1. When using current inputs, pins IN1 of the voltage/current switch must be set to ON. Refer to 9-3-3 *Voltage/Current Switch* for further details. Also set the voltage and current ranges in D (m+35) in the DM Area.
  2. For inputs that are not used, either set to "0: Not used" in the input number settings (refer to 9-6-1 *Input Settings and Conversion Values*) or short-circuit the voltage input terminals (V+) and (V-).
  3. Crimp-type terminals must be used for terminal connections, and the screws must be tightened securely. Use M3 screws and tighten them to a torque of 0.5 N·m.
  4. When connecting the shield of the analog input cables to the Unit's AG terminals (A7, B7), as shown in the previous diagram, use a wire that is 30 cm max. in length if possible.



**Note** Connecting shielded cable to the Unit's AG terminals (A7, B7) can improve noise resistance.

To minimize output wiring noise, ground the output signal line to the input device.

### 9-4-5 I/O Wiring Considerations

When wiring inputs, apply the following points to avoid noise interference and optimize Analog I/O Unit performance.

- Use two-core shielded twisted-pair cables for external connections.
- Route I/O cables separately from the AC cable, and do not run the Unit's cables near a main circuit cable or a high voltage cable. Do not insert output cables into the same duct.
- If there is noise interference from power lines (if, for example, the power supply is shared with electrical welding devices or electrical discharge machines, or if there is a high-frequency generation source nearby) install a noise filter at the power supply input area.

## 9-5 Exchanging Data with the CPU Unit

### 9-5-1 Outline of Data Exchange


Data is exchanged between the CPU Unit and the CJ1W-MAD42 Analog I/O Unit via the Special I/O Unit Area (for data used to operate the Unit) and the Special I/O Unit DM Area (for data used for initial settings).

#### I/O Refresh Data

Analog input conversion values, analog output set values, and other data used to operate the Unit are allocated in the Special I/O Unit Area of the CPU Unit according to the unit number, and are exchanged during I/O refreshing.


#### Fixed Data

The Unit's fixed data, such as the analog input signal ranges and analog output signal ranges, is allocated in the Special I/O Unit DM Area of the CPU Unit according to the unit number, and is exchanged when the power is turned ON or the Unit is restarted.



## 9-5-2 Unit Number Settings

The Special I/O Unit Area and Special I/O Unit DM Area word addresses that each Analog I/O Unit occupies are set by the unit number switches on the front panel of the Unit.



| Switch setting | Unit number | Special I/O Unit Area addresses                | Special I/O Unit DM Area addresses            |
|----------------|-------------|------------------------------------------------|-----------------------------------------------|
| 0              | Unit #0     | CIO 2000 to CIO 2009                           | D20000 to D20099                              |
| 1              | Unit #1     | CIO 2010 to CIO 2019                           | D20100 to D20199                              |
| 2              | Unit #2     | CIO 2020 to CIO 2029                           | D20200 to D20299                              |
| 3              | Unit #3     | CIO 2030 to CIO 2039                           | D20300 to D20399                              |
| 4              | Unit #4     | CIO 2040 to CIO 2049                           | D20400 to D20499                              |
| 5              | Unit #5     | CIO 2050 to CIO 2059                           | D20500 to D20599                              |
| 6              | Unit #6     | CIO 2060 to CIO 2069                           | D20600 to D20699                              |
| 7              | Unit #7     | CIO 2070 to CIO 2079                           | D20700 to D20799                              |
| 8              | Unit #8     | CIO 2080 to CIO 2089                           | D20800 to D20899                              |
| 9              | Unit #9     | CIO 2090 to CIO 2099                           | D20900 to D20999                              |
| 10             | Unit #10    | CIO 2100 to CIO 2109                           | D21000 to D21099                              |
| to             | to          | to                                             | to                                            |
| n              | Unit #n     | CIO 2000 + (n × 10) to CIO 2000 + (n × 10) + 9 | D20000 + (n × 100) to D20000 + (n × 100) + 99 |
| to             | to          | to                                             | to                                            |
| 95             | Unit #95    | CIO 2950 to CIO 2959                           | D29500 to D29599                              |

**Note** If two or more Special I/O Units are assigned the same unit number, a “UNIT No. DPL ERR” error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

## 9-5-3 Operation Mode Setting

The operation mode can be switched between normal mode and adjustment mode (for offset gain adjustment) by changing the setting in bits 00 to 07 of D(m+18).

### Settings in D(m+18)

| DM word | Bits                               |    |    |    |    |    |   |   |                                                                  |   |   |   |   |   |   |   |
|---------|------------------------------------|----|----|----|----|----|---|---|------------------------------------------------------------------|---|---|---|---|---|---|---|
|         | 15                                 | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7                                                                | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| D(m+18) | Conversion time/resolution setting |    |    |    |    |    |   |   | Operation mode setting<br>00: Normal mode<br>C1: Adjustment mode |   |   |   |   |   |   |   |

$$m = D20000 + (\text{unit number} \times 100)$$

### 9-5-4 Special I/O Unit Restart Bits

To restart the Unit operations after changing the contents of the data memory or correcting an error, turn ON the power to the PLC again or turn the Special I/O Unit Restart Bit ON and then OFF again.


| Special I/O Unit<br>Area word<br>address | Function                |                                                      |
|------------------------------------------|-------------------------|------------------------------------------------------|
| A50200                                   | Unit No. 0 Restart Bit  | Restarts the Unit when turned ON and then OFF again. |
| A50201                                   | Unit No. 1 Restart Bit  |                                                      |
| to                                       | to                      |                                                      |
| A50215                                   | Unit No. 15 Restart Bit |                                                      |
| A50300                                   | Unit No. 16 Restart Bit |                                                      |
| to                                       | to                      |                                                      |
| A50715                                   | Unit No. 95 Restart Bit |                                                      |

**Note** If the error is not corrected by restarting the Unit or turning the Special I/O Unit Restart Bit ON and then OFF again, replace the Analog I/O Unit.

### 9-5-5 Fixed Data Allocations

#### Allocations in DM Area

The initial settings of the Analog I/O Unit are set according to the data allocated in the Special I/O Unit DM Area. Settings, such as the inputs and outputs used, the analog input signal range, and analog output signal range must be set in this area.



- Note**
1. The Special I/O Unit DM Area words that are occupied by the Analog I/O Unit are set using the unit number switches on the front panel of the Unit. Refer to *9-3-2 Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.



**Allocations in DM Area**

The following table shows the allocation of DM words and bits for both normal and adjustment mode.

| DM word  | Bits                                                                                             |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
|----------|--------------------------------------------------------------------------------------------------|----|-----------|----|---------|----|---------|---|-------------------------------------------------|---------|-----------|---------|--------------------|-----------|-----------|-----------|
|          | 15                                                                                               | 14 | 13        | 12 | 11      | 10 | 9       | 8 | 7                                               | 6       | 5         | 4       | 3                  | 2         | 1         | 0         |
| D (m)    | Ratio conversion use setting                                                                     |    |           |    |         |    |         |   | Input use setting                               |         |           |         | Output use setting |           |           |           |
|          | Not used.                                                                                        |    | Not used. |    | Loop 2  |    | Loop 1  |   | Input 4                                         | Input 3 | Input 2   | Input 1 | Not used.          | Not used. | Out-put 2 | Out-put 1 |
| D (m+1)  | Input signal range setting                                                                       |    |           |    |         |    |         |   | Output signal range setting                     |         |           |         |                    |           |           |           |
|          | Input 4                                                                                          |    | Input 3   |    | Input 2 |    | Input 1 |   | Not used.                                       |         | Not used. |         | Output 2           |           | Output 1  |           |
| D (m+2)  | Not used.                                                                                        |    |           |    |         |    |         |   | Output 1: Output status when conversion stopped |         |           |         |                    |           |           |           |
| D (m+3)  | Not used.                                                                                        |    |           |    |         |    |         |   | Output 2: Output status when conversion stopped |         |           |         |                    |           |           |           |
| D (m+4)  | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+5)  | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+6)  | Input 1: Mean value processing setting                                                           |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+7)  | Input 2: Mean value processing setting                                                           |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+8)  | Input 3: Mean value processing setting                                                           |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+9)  | Input 4: Mean value processing setting                                                           |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+10) | Loop 1 (input 1 to output 1), A constant                                                         |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+11) | Loop 1 (input 1 to output 1), B constant                                                         |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+12) | Loop 2 (input 2 to output 2), A constant                                                         |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+13) | Loop 2 (input 2 to output 2), B constant                                                         |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+14) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+15) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+16) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+17) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+18) | Conversion time and resolution setting                                                           |    |           |    |         |    |         |   | Operation mode setting                          |         |           |         |                    |           |           |           |
| D (m+19) | Output 1 scaling lower limit (Enabled only for conversion time of 1 ms and resolution of 4,000.) |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+20) | Output 1 scaling upper limit (Enabled only for conversion time of 1 ms and resolution of 4,000.) |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+21) | Output 2 scaling lower limit (Enabled only for conversion time of 1 ms and resolution of 4,000.) |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+22) | Output 2 scaling upper limit (Enabled only for conversion time of 1 ms and resolution of 4,000.) |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+23) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+24) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+25) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+26) | Not used.                                                                                        |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+27) | Input 1 scaling lower limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+28) | Input 1 scaling upper limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+29) | Input 2 scaling lower limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+30) | Input 2 scaling upper limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+31) | Input 3 scaling lower limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+32) | Input 3 scaling upper limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+33) | Input 4 scaling lower limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+34) | Input 4 scaling upper limit                                                                      |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
| D (m+35) | Voltage/current range setting (Enabled only when set for 1 to 5 V, 4 to 20 mA)                   |    |           |    |         |    |         |   |                                                 |         |           |         |                    |           |           |           |
|          | Not used.                                                                                        |    |           |    |         |    |         |   | Input 4                                         | Input 3 | Input 2   | Input 1 | Not used.          |           | Out-put 2 | Out-put 1 |

## Set Values and Stored Values


| Item                                                        |                               | Contents                                                                                                                                                                                                                                                                                                                            | Page |
|-------------------------------------------------------------|-------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------|
| Input                                                       | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                            | 400  |
|                                                             | Input signal range            | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V, 4 to 20 mA (See note 1.)<br>11: 0 to 5 V                                                                                                                                                                                                                                          | 400  |
|                                                             | Voltage/current range setting | 0: Voltage range (1 to 5 V)<br>1: Current range (4 to 20 mA)                                                                                                                                                                                                                                                                        |      |
|                                                             | Mean value processing setting | 0000: Mean value processing with 2 buffers (See note 3.)<br>0001: No mean value processing<br>0002: Mean value processing with 4 buffers<br>0003: Mean value processing with 8 buffers<br>0004: Mean value processing with 16 buffers<br>0005: Mean value processing with 32 buffers<br>0006: Mean value processing with 64 buffers | 402  |
|                                                             | Scaling setting               | Set any value in binary data from -32,000 (8,300) to +32,000 (7D00), except when upper limit = lower limit (not 0000).                                                                                                                                                                                                              |      |
| Output                                                      | Use setting                   | 0: Not used.<br>1: Used.                                                                                                                                                                                                                                                                                                            | 409  |
|                                                             | Output signal range           | 00: -10 to 10 V<br>01: 0 to 10 V<br>10: 1 to 5 V<br>11: 0 to 5 V                                                                                                                                                                                                                                                                    | 410  |
|                                                             | Voltage/current range setting | 0: Voltage range (1 to 5 V)<br>1: Current range (4 to 20 mA)                                                                                                                                                                                                                                                                        |      |
|                                                             | Output status when stopped    | 00: CLR Outputs 0 or minimum value of each range.<br>(See note 2.)<br>01: HOLD Holds output just before stopping.<br>02: MAX Outputs maximum value of range.                                                                                                                                                                        | 412  |
|                                                             | Scaling setting               | Set any value in binary data from -32,000 (8,300) to +32,000 (7D00), except when upper limit = lower limit (not 0000).                                                                                                                                                                                                              |      |
| Loop                                                        | Ratio conversion use setting  | 00: Not used.<br>01: Uses positive gradient conversion.<br>10: Uses negative gradient conversion.<br>11: Same as for setting "00" above.                                                                                                                                                                                            | 415  |
|                                                             | A constant                    | 4 digits BCD (0 to 9999)                                                                                                                                                                                                                                                                                                            |      |
|                                                             | B constant                    | 16-bit binary data                                                                                                                                                                                                                                                                                                                  |      |
| Conversion time/resolution setting (for inputs and outputs) |                               | 00: Conversion time of 1 ms and resolution of 4,000<br>C1: Conversion time of 500 $\mu$ s and resolution of 8,000                                                                                                                                                                                                                   | 402  |

- Note**
1. The input signal range of "1 to 5 V" and "4 to 20 mA" is switched using the pins of the voltage/current switch. Refer to 9-3-3 *Voltage/Current Switch* for details.
  2. For the range of  $\pm 10$  V, the output is 0 V. For other output signal ranges, the minimum value of each signal range is output. Refer to 9-7-3 *Output Hold Function* for details.
  3. The default setting for mean value processing is to use two buffers.

## 9-5-6 I/O Refresh Data Allocations

### Special I/O Unit Area Allocation and Contents

I/O refresh data for the Analog I/O Unit is exchanged according to the allocations in the Special I/O Unit Area. Analog input converted values and analog output set values are exchanged with the CPU Unit at I/O refresh.



- Note**
1. The Special I/O Unit Area words that are occupied by the Analog I/O Unit are set using the unit number switches on the front panel of the Unit. Refer to 9-3-2 *Unit Number Switches* for details on the method used to set the unit number switches.
  2. If two or more Special I/O Units are assigned the same unit number, a "UNIT No. DPL ERR" error (in the Programming Console) will be generated (A40113 will turn ON) and the PLC will not operate.

**Allocations for Normal Mode**

For normal mode, set bits 00 to 07 in D(m+18) to 00 hex.

The allocation of words and bits in the CIO Area is shown in the following table.

| I/O                     | Word  | Bits                                                 |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|-------------------------|-------|------------------------------------------------------|----|----|----|-----------------|----|---|---|-------------------------|---------|---------|---------|-----------------|---|----------------------|-----------|
|                         |       | 15                                                   | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                       | 6       | 5       | 4       | 3               | 2 | 1                    | 0         |
| Output<br>(CPU to Unit) | n     | Not used.                                            |    |    |    |                 |    |   |   | Peak value hold         |         |         |         | Not used.       |   | Conversion enable    |           |
|                         |       |                                                      |    |    |    |                 |    |   |   | Input 4                 | Input 3 | Input 2 | Input 1 |                 |   | Out-put 2            | Out-put 1 |
|                         | n + 1 | Output 1 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         |       | 16 <sup>3</sup>                                      |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup> |   |                      |           |
|                         | n + 2 | Output 2 set value                                   |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         | n + 3 | Not used.                                            |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         | n + 4 | Not used.                                            |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
| Input<br>(Unit to CPU)  | n + 5 | Input 1 conversion value / Loop 1 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         |       | 16 <sup>3</sup>                                      |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>         |         |         |         | 16 <sup>0</sup> |   |                      |           |
|                         | n + 6 | Input 2 conversion value / Loop 2 calculation result |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         | n + 7 | Input 3 conversion value                             |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         | n + 8 | Input 4 conversion value                             |    |    |    |                 |    |   |   |                         |         |         |         |                 |   |                      |           |
|                         | n + 9 | Alarm Flags                                          |    |    |    |                 |    |   |   | Disconnection detection |         |         |         |                 |   | Output setting error |           |
|                         |       |                                                      |    |    |    |                 |    |   |   | Input 4                 | Input 3 | Input 2 | Input 1 |                 |   | Out-put 2            | Out-put 1 |

**Set Values and Stored Values**

| I/O    | Item                                   | Contents                                                                                                                                                                                                                                                                                                                                                                                                                      | Page                               |
|--------|----------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| Input  | Peak value hold function               | 0: Not used.<br>1: Peak value hold used.                                                                                                                                                                                                                                                                                                                                                                                      | 405                                |
|        | Conversion value<br>Calculation result | 16-bit binary data                                                                                                                                                                                                                                                                                                                                                                                                            | 401                                |
|        | Disconnection detection                | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                                                                                                                                                                                       | 408                                |
| Output | Conversion enable                      | 0: Conversion output stopped.<br>1: Conversion output begun.                                                                                                                                                                                                                                                                                                                                                                  | 411                                |
|        | Set value                              | 16-bit binary data                                                                                                                                                                                                                                                                                                                                                                                                            | 410                                |
|        | Output setting error                   | 0: No error<br>1: Output setting error                                                                                                                                                                                                                                                                                                                                                                                        | 414                                |
| Common | Alarm Flags                            | Bits 00 to 03: Output set value error<br>Bits 04 to 07: Input disconnection detection<br>Bit 08: Ratio conversion use setting error;<br>scaling data error<br>Bit 09: Ratio set value error<br>Bit 10: Output hold setting error<br>Bit 11: Mean value processing setting error<br>Bit 12: Conversion time/resolution; operation<br>mode setting error<br>Bit 15: Operating in adjustment mode.<br>(Always 0 in normal mode.) | 436<br><br><br><br><br><br><br>437 |

**Note** For the CIO word addresses, n = CIO 2000 + unit number × 10.

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |

### Allocation for Adjustment Mode

For adjustment mode, set bits 00 to 07 in D (m+18) to 01 hex.

The allocation of CIO words and bits is shown in the following table.

| I/O                     | Word            | Bits                                                |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|-------------------------|-----------------|-----------------------------------------------------|----|----|----|-----------------|----|---|---|-----------------------------------|------------|------------|------------|-----------------|------|------|---------|
|                         |                 | 15                                                  | 14 | 13 | 12 | 11              | 10 | 9 | 8 | 7                                 | 6          | 5          | 4          | 3               | 2    | 1    | 0       |
| Output<br>(CPU to Unit) | n               | Not used.                                           |    |    |    |                 |    |   |   | Inputs and outputs to be adjusted |            |            |            |                 |      |      |         |
|                         | 16 <sup>1</sup> |                                                     |    |    |    |                 |    |   |   | 16 <sup>0</sup>                   |            |            |            |                 |      |      |         |
|                         | n + 1           | Not used.                                           |    |    |    |                 |    |   |   | Not used.                         |            | Clr        | Set        | Up              | Down | Gain | Off-set |
|                         | n + 2           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 3           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 4           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 5           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         | n + 6           | Not used.                                           |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
| n + 7                   | Not used.       |                                                     |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
| Input<br>(Unit to CPU)  | n + 8           | Conversion value or set value at time of adjustment |    |    |    |                 |    |   |   |                                   |            |            |            |                 |      |      |         |
|                         |                 | 16 <sup>3</sup>                                     |    |    |    | 16 <sup>2</sup> |    |   |   | 16 <sup>1</sup>                   |            |            |            | 16 <sup>0</sup> |      |      |         |
|                         | n + 9           | Alarm Flags                                         |    |    |    |                 |    |   |   | Disconnection detec-<br>tion      |            |            |            | Not used.       |      |      |         |
|                         |                 |                                                     |    |    |    |                 |    |   |   | Input<br>4                        | Input<br>3 | Input<br>2 | Input<br>1 |                 |      |      |         |

### Set Values and Stored Values

Refer to 9-9-1 Adjustment Mode Operational Flow for further details.

| Item                            | Contents                                                                                                                                                                                                                                                   |
|---------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Input or output to be adjusted  | Sets input or output to be adjusted.<br>Leftmost digit: 1 (output) or 2 (input)<br>Rightmost digit: 1 to 2 (output)/ 1 to 4 (input)                                                                                                                        |
| Offset (Offset Bit)             | When ON, adjusts offset error.                                                                                                                                                                                                                             |
| Gain (Gain Bit)                 | When ON, adjusts gain error.                                                                                                                                                                                                                               |
| Down (Down Bit)                 | Decrements the adjustment value while ON.                                                                                                                                                                                                                  |
| Up (Up Bit)                     | Increments the adjustment value while ON.                                                                                                                                                                                                                  |
| Set (Set Bit)                   | Sets adjusted value and writes to EEPROM.                                                                                                                                                                                                                  |
| Clr (Clear Bit)                 | Clears adjusted value. (Returns to default status)                                                                                                                                                                                                         |
| Conversion value for adjustment | The conversion value for adjustment is stored as 16 bits of binary data.                                                                                                                                                                                   |
| Disconnection detection         | 0: No disconnection<br>1: Disconnection                                                                                                                                                                                                                    |
| Alarm Flags                     | Bit 12: Input value is outside adjustment limits (in adjustment mode)<br>Bit 13: I/O number setting error (in adjustment mode)<br>Bit 14: EEPROM write error (in adjustment mode)<br>Bit 15: Operating in adjustment mode. (Always ON in adjustment mode.) |

**Note** For the CIO word addresses, n = CIO 2000 + (unit number × 10).

The input disconnection detection function can be used when the input signal range is set for 1 to 5 V (4 to 20 mA).

| Input signal range | Voltage/current |
|--------------------|-----------------|
| 1 to 5 V           | 0.3 V max.      |
| 4 to 20 mA         | 1.2 mA max.     |


## 9-6 Analog Input Functions and Operating Procedures

### 9-6-1 Input Settings and Conversion Values

#### Setting Inputs and Signal Ranges

##### Input Numbers

The Analog I/O Unit converts only analog inputs specified by input numbers 1 to 4. To specify the analog inputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



The analog input sampling interval can be shortened by setting any unused input numbers to 0.

$$\text{Sampling interval} = (1 \text{ ms}) (\text{See note.}) \times (\text{Number of inputs used})$$


For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

The word for inputs that have been set to "Not used" will always be "0000."

**Note** This value will be 500  $\mu\text{s}$  when the setting is for 500  $\mu\text{s}$  and a resolution of 8,000.

##### Input Signal Range

Any of four types of input signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V, and 4 to 20 mA) can be selected for each of the inputs (i.e., input numbers 1 to 4). To specify the input signal range for each input, set from a Programming Device the D(m+1) bits in the DM Area as shown in the following diagram.




- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$
  2. The input signal range of "1 to 5 V" or "4 to 20 mA" is switched using the voltage/current switch.

- After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit in order to transfer the contents of the DM settings to the Special I/O Unit.

### Voltage/Current Range Setting

When “1 to 5 V, 4 to 20 mA” is selected for the input signal range, either the “1 to 5 V” or “4 to 20 mA” range can then be selected by means of the D (m+35) setting. Adjusting the factory-set voltage and current can improve the accuracy of current output specifications.



### Reading Conversion Values

Analog input conversion values are stored for each input number, in CIO words n+5 to n+8.


| Word | Function                 | Stored value       |
|------|--------------------------|--------------------|
| n+5  | Input 1 conversion value | 16-bit binary data |
| n+6  | Input 2 conversion value |                    |
| n+7  | Input 3 conversion value |                    |
| n+8  | Input 4 conversion value |                    |

**Note** For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

Use MOV(021) or XFER(070) to read conversion values in the user program.


#### Example 1

In this example, the conversion data from only one input is read. (The unit number is 0.)



#### Example 2

In this example, the conversion data from multiple inputs is read. (The unit number is 0.)




For details regarding conversion value scaling, refer to *Scaling* on page 448.

## 9-6-2 Conversion Time and Resolution Setting

Bits 08 to 15 in DM word m+18 can be used to set the conversion time and resolution for the CJ1W-MAD42 to increase speed and accuracy.


This setting applies to analog inputs 1 to 4, i.e., there are not individual settings for each input.



**Note** After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit in order to transfer the contents of the DM settings to the Special I/O Unit.

## 9-6-3 Mean Value Processing

The Analog I/O Unit can compute the mean value of the conversion values of analog inputs that have been previously sampled. Mean value processing involves an operational mean value in the history buffers, so it has no effect on the data refresh cycle. (The number of history buffers that can be set to use mean value processing is 2, 4, 8, 16, 32, or 64.)



When “n” number of history buffers are being used, the first conversion data will be stored for all “n” number of history buffers immediately after data conversion has begun or after a disconnection is restored.

When mean value processing is used together with the peak value hold function, the mean value will be held.

To specify whether or not mean value processing is to be used, and to specify the number of history buffers for mean data processing, use a Programming



Device to make the settings in D(m+6) to D(m+9) as shown in the following table.


| DM word | Function                      | Set value                                   |
|---------|-------------------------------|---------------------------------------------|
| D (m+6) | Input 1 mean value processing | 0000: Mean value processing with 2 buffers  |
| D (m+7) | Input 2 mean value processing | 0001: No mean value processing              |
| D (m+8) | Input 3 mean value processing | 0002: Mean value processing with 4 buffers  |
| D (m+9) | Input 4 mean value processing | 0003: Mean value processing with 8 buffers  |
|         |                               | 0004: Mean value processing with 16 buffers |
|         |                               | 0005: Mean value processing with 32 buffers |
|         |                               | 0006: Mean value processing with 64 buffers |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$

**Note** After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.


The history buffer moving average is calculated as shown below. (In this example, there are four buffers.)

- 1,2,3...** 1. With the first cycle, Data 1 is stored in all the history buffers.




$$\text{Mean value} = (\text{Data 1} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

2. With the second cycle, Data 2 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 2} + \text{Data 1} + \text{Data 1} + \text{Data 1}) \div 4$$

3. With the third cycle, Data 3 is stored in the first history buffer.




$$\text{Mean value} = (\text{Data 3} + \text{Data 2} + \text{Data 1} + \text{Data 1}) \div 4$$

4. With the fourth cycle, the Data 4 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 4} + \text{Data 3} + \text{Data 2} + \text{Data 1}) \div 4$$


5. With the fifth cycle, Data 5 is stored in the first history buffer.



$$\text{Mean value} = (\text{Data 5} + \text{Data 4} + \text{Data 3} + \text{Data 2}) \div 4$$

When a disconnection is restored, the mean value processing function begins again from step 1.

- Note**
1. The default setting for mean value processing in the Analog I/O Unit is mean value processing with 2 buffers.
  2. When the mean value processing function is used, the delay in refreshing converted data for input signal changes will be as shown in the following diagram.
  3. Specify “no mean value processing” to follow conversion of a rapid change in input signals.



**For V = 20 V (–10 to 10 V)**

**When Resolution is 1 ms/4,000**

- For One Word  
 $t = n + (2 \text{ to } 3)$
- For m Words ( $1 < m \leq 4$ )  
No averaging ( $n = 1$ ) or two averaging buffers ( $n = 2$ )  
 $t = n \times (m + 2)$   
For n averaging buffers ( $4 \leq n \leq 64$ )  
 $t = (n - 2) \times m + 10.5$

**When Resolution is 500 μs/8,000**

- For One Word  
 $t = [n + (2 \text{ to } 3)] \times 1/4$
- For m Words ( $1 < m \leq 4$ )  
No averaging ( $n = 1$ ) or two averaging buffers ( $n = 2$ )  
 $t = n \times (m + 2) \times 1/2$   
For n averaging buffers ( $4 \leq n \leq 64$ )  
 $t = [(n - 2) \times m + 10.5] \times 1/2$

**Response Time for a  
Resolution of 1 ms/4,000**

Unit: ms

| m | n     |       |      |      |      |    |   |
|---|-------|-------|------|------|------|----|---|
|   | 64    | 32    | 16   | 8    | 4    | 2  | 1 |
| 4 | 258.5 | 130.5 | 66.5 | 34.5 | 18.5 | 12 | 6 |
| 3 | 196.5 | 100.5 | 52.5 | 28.5 | 16.5 | 10 | 5 |

| m | n     |      |      |      |      |   |   |
|---|-------|------|------|------|------|---|---|
|   | 64    | 32   | 16   | 8    | 4    | 2 | 1 |
| 2 | 134.5 | 70.5 | 38.5 | 22.5 | 14.5 | 8 | 4 |
| 1 | 67    | 35   | 19   | 11   | 7    | 5 | 3 |

#### Response Time for a Resolution of 500 $\mu$ s/8,000

Unit: ms

| m | n      |       |       |       |      |     |     |
|---|--------|-------|-------|-------|------|-----|-----|
|   | 64     | 32    | 16    | 8     | 4    | 2   | 1   |
| 4 | 129.25 | 65.25 | 33.25 | 17.25 | 9.25 | 6   | 3   |
| 3 | 98.25  | 50.25 | 26.25 | 14.25 | 8.25 | 5   | 2.5 |
| 2 | 67.25  | 35.25 | 19.25 | 11.25 | 7.25 | 4   | 2   |
| 1 | 33.5   | 17.5  | 9.5   | 5.5   | 3.5  | 2.5 | 1.5 |

The above response times are not affected by the number of analog I/O points that are used.

#### Symbols

m: Number of input words used in DM Area

n: Average number of buffers set for the input number for which to find the response time


#### Calculation Example

The following example calculations are for a resolution of 8,000 with an application using inputs 1 and 8, 64 averaging buffers set for input 1, and no averaging set for input 8.


- Response time for input 1:  $t = \{(64 - 2) \times 2 + 10.5\} \times 1/2 = 67.25$  (ms)
- Response time for input 1:  $t = 1 \times (2 + 2) \times 1/2 = 2$  (ms)

### 9-6-4 Peak Value Hold Function

The peak value hold function holds the maximum digital conversion value for every input (including mean value processing). This function can be used with analog input. The following diagram shows how digital conversion values are affected when the peak value hold function is used.



The peak value hold function can be set individually for each input number by turning on the respective bits (04 to 07) in CIO word n.



The peak value hold function will be in effect for the above input numbers while their respective bits are ON. The conversion values will be reset when the bits are turned OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

In the following example, the peak value hold function is in effect for input number 1, and the unit number is 0.



**Note** When mean value processing is used together with the peak value hold function, the mean value will be held.

As long as the peak value hold function is in effect, the peak value hold will be held even in the event of a disconnection.

When the load to the CPU Unit is disconnected, the Peak Value Hold Bits (bits 04 to 07 of the word n) are cleared and the peak value hold function is disabled.

### 9-6-5 Input Scaling Function

When upper and lower limits (within a decimal range of -32,000 to 32,000) have been preset in 16-bit binary data (from 8300 to 7D00) in the CPU Unit's DM Area, analog input values can then be automatically converted into a user-specified unit following A/D conversion, with the upper and lower limits taken as full scale based on that resolution value. (See note 1.) This scaling function eliminates the previous need to provide programs for numeric conversion into specified units. It is only enabled, however, for a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 500  $\mu$ s and a resolution of 8,000).

- Note**
1. To set the upper or lower limit to a negative number, use two's complement. (Set 8300 to FFF for -32,000 to -1.)
  2. Addresses  $m = \text{D}20000 + \text{unit number} \times 100$  are allocated in the DM Area.
  3. Besides upper limit > lower limit, it is also possible to set lower limit < upper limit. (Reverse scaling is supported.)
  4. Actual A/D conversion is executed at up to -5% to +105% of full scale.
  5. When setting upper and lower limits in the DM Area in the specified units, be sure to make the settings in 16-bit binary data (with negative values set

as two's complement). For decimal numbers  $-32,000$  to  $+32,000$ , set 16-bit binary data (8300 to 7D00).

6. The scaling function is enabled for only a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 500  $\mu$ s and a resolution of 8,000).
7. The scaling function cannot be used when the ratio conversion function is used.
8. If the scaling upper limit equals the lower limit, or if the scaling upper limit or lower limit is outside the range of  $\pm 32,000$ , a scaling data setting error is generated and scaling cannot be executed. Operation starts normally when both the upper and lower limits are set to 0000 (the default values).

### Setting Upper and Lower Limits for Input Scaling

Set the scaling upper and lower limits for inputs 1 to 4 in words  $m+27$  to  $m+34$  of the DM Area, as shown below.

**Note** For decimal numbers  $-32,000$  to  $+32,000$ , set 16-bit binary data (8300 to 7D00).


| DM word  | Bits                        |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
|----------|-----------------------------|----|----|----|----|----|---|---|---|---|---|---|---|---|---|---|
|          | 15                          | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| D (m+27) | Input 1 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+28) | Input 1 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+29) | Input 2 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+30) | Input 2 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+31) | Input 3 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+32) | Input 3 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+33) | Input 4 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+34) | Input 4 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |

### Example Setting 1

Set the following conditions in D (m+27) to D (m+34). (The values shown in parentheses are binary data.)

| Setting condition   | Set value     |
|---------------------|---------------|
| Input signal range  | 0 to 10 V     |
| Scaling lower limit | 0000 (0000)   |
| Scaling upper limit | 10,000 (2710) |

### When Input Signal Range is 0 V to 10 V



The following table shows the correspondence between input signals and converted scaling values. (The values shown in parentheses are binary data.)

| Input signal | Conversion result |
|--------------|-------------------|
| 0 V          | 0000 (0000)       |
| 10 V         | 10,000 (2710)     |


| Input signal | Conversion result |
|--------------|-------------------|
| -0.5 V       | -500 (FE0C)       |
| 10.5 V       | 10,500 (2904)     |

### Example Setting 2 (Reverse Scaling)

Set the following conditions in D (m+27) to D (m+34). (The values shown in parentheses are binary data.)

| Setting condition   | Set value    |
|---------------------|--------------|
| Input signal range  | 0 to 10 V    |
| Scaling lower limit | 10000 (2710) |
| Scaling upper limit | 0000 (0000)  |

#### When Input Signal Range is 0 V to 10 V (Reverse Scaling)



The following table shows the correspondence between input signals and converted scaling values. (The values shown in parentheses are binary data.)

| Input signal | Conversion result |
|--------------|-------------------|
| 0 V          | 10,000 (2710)     |
| 10 V         | 0000 (0000)       |
| -0.5 V       | 10,500 (2904)     |
| 10.5 V       | -500 (FE0C)       |


## 9-6-6 Input Disconnection Detection Function

When an input signal range of 1 to 5 V (4 to 20 mA) is used, input circuit disconnections can be detected. The detection conditions for each of the input signal ranges are shown in the following table.

| Range      | Current/voltage |
|------------|-----------------|
| 1 to 5 V   | 0.3 V max.      |
| 4 to 20 mA | 1.2 mA max.     |

The current/voltage level will fluctuate according to the offset/gain adjustment.

The input disconnection detection signals for each input number are stored in bits 04 to 07 of CIO word n+9. Specify these bits as execution conditions to use disconnection detection in the user's program.



The respective bit turns ON when a disconnection is detected for a given input. When the disconnection is restored, the bit turns OFF.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The conversion value during a disconnection will be 0000.

In the following example, the conversion value is read only if there is no disconnection at analog input number 1. (The unit number is 0.)




## 9-7 Analog Output Functions and Operating Procedures

### 9-7-1 Output Settings and Conversions

#### Setting Outputs and Signal Ranges

##### Output Numbers

The Analog I/O Unit converts analog outputs specified by output numbers 1 to 2 only. To specify the analog outputs to be used, turn ON from a Programming Device the D(m) bits in the DM Area shown in the following diagram.



The analog output conversion cycle can be shortened by setting any unused output numbers to 0.


$$\text{Conversion cycle} = (1 \text{ ms}) (\text{See note 3.}) \times (\text{Number of outputs used})$$

- Note**
1. For the DM word addresses,  $m = \text{D20000} + (\text{unit number} \times 100)$ .
  2. Output numbers not used (set to 0) will be output at 0 V.

3. This value will be 500  $\mu$ s when the setting is for 500  $\mu$ s and a resolution of 8,000.

### Output Signal Range


Any of four types of output signal range (–10 to 10 V, 0 to 10 V, 1 to 5 V/4 to 20 mA, and 0 to 5 V) can be selected for each of the outputs (i.e., output numbers 1 to 4). To specify the output signal range for each output, use a Programming Device to set the D (m+1) bits in the DM Area shown in the following diagram.



- Note**
1. For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .
  2. After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.

### Voltage/Current Range Setting

When “1 to 5 V, 4 to 20 mA” is selected for the output signal range, either the “1 to 5 V” or “4 to 20 mA” range can then be selected by means of the D (m+35) setting. Adjusting the factory-set voltage and current can improve the accuracy of current output specifications.



### Writing Set Values

Analog output set values are written to CIO words (n+1) and (n+2).

| Word | Function           | Stored value       |
|------|--------------------|--------------------|
| n+1  | Output 1 set value | 16-bit binary data |
| n+2  | Output 2 set value |                    |


For the CIO word addresses,  $n = CIO\ 2000 + (\text{unit number} \times 10)$ .

Use MOV(021) or XFER(070) to write values in the user program.




**Example 1**

In this example, the set value from only one input is read. (The unit number is 0.)

**Example 2**

In this example, multiple set values are written. (The unit number is #0.)




**Note** If the set value has been written outside the specified range, an output setting error will occur.

## 9-7-2 Conversion Time and Resolution Setting

Bits 08 to 15 in DM word  $m+18$  can be used to set the conversion time and resolution for the CJ1W-MAD42 to increase speed and accuracy.


This setting applies to analog inputs 1 to 4, i.e., there are not individual settings for each input.



**Note** After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit in order to transfer the contents of the DM settings to the Special I/O Unit.

### Starting and Stopping Conversion

To begin analog output conversion, turn ON the corresponding Conversion Enable Bit (word  $n$ , bits 00 and 01) from the user's program.



Analog conversion is executed while these bits are ON. When the bits are turned OFF, the conversion is stopped and the output data is held.

For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .


The analog output when conversion is stopped will differ depending on the output signal range setting and output hold setting. Refer to *Setting Outputs and Signal Ranges* on page 409 and *9-7-3 Output Hold Function*.

Conversion will not begin under the following conditions even if the Conversion Enable Bit is turned ON. Refer to *9-7-3 Output Hold Function*.

- 1,2,3...**
1. In adjustment mode, when something other than the output number is output during adjustment.
  2. When an output setting value occurs.
  3. When a fatal error occurs at the PLC.
  4. When there is an input disconnection during a ratio conversion.

When the operation mode for the CPU Unit is changed from RUN or MONITOR mode to PROGRAM mode, or when the power is turned ON, the Conversion Enable Bits will all turn OFF. The output status at this time depends on the output hold function.

In this example, conversion is begun for analog output number 1. (The unit number is 0.)



### 9-7-3 Output Hold Function

The Analog I/O Unit stops conversion under the following circumstances and outputs the value set by the output hold function.

- 1,2,3...**
1. When the Conversion Enable Bit is OFF. Refer to *Conversion Time and Resolution Setting* on page 411.
  2. In adjustment mode, when something other than the output number is output during adjustment. Refer to *9-9-2 Input Offset and Gain Adjustment Procedures*.
  3. When an output setting value occurs.
  4. When a fatal error occurs at the PLC.
  5. When there is an input disconnection during ratio conversion.
  6. When there is an I/O bus error.
  7. When the CPU Unit is in LOAD OFF status.
  8. When there is a WDT (watchdog timer) error in the CPU Unit.

CLR, HOLD, or MAX can be selected for the output status when conversion is stopped.

| Output signal range | CLR                              | HOLD                                        | MAX                             |
|---------------------|----------------------------------|---------------------------------------------|---------------------------------|
| 0 to 10 V           | -0.5 V (Min. -5% of full scale)  | Voltage that was output just prior to stop. | 10.5 V (Max. +5% of full scale) |
| -10 to 10 V         | 0.0 V                            | Voltage that was output just prior to stop. | 11.0 V (Max. +5% of full scale) |
| 1 to 5 V            | 0.8 V (Min. -5% of full scale)   | Voltage that was output just prior to stop. | 5.2 V (Max. +5% of full scale)  |
| 0 to 5 V            | -0.25 V (Min. -5% of full scale) | Voltage that was output just prior to stop. | 5.25 V (Max. +5% of full scale) |

| Output signal range | CLR                               | HOLD                                        | MAX                              |
|---------------------|-----------------------------------|---------------------------------------------|----------------------------------|
| 4 to 20 mA          | 3.2 mA (Min. -0.5% of full scale) | Voltage that was output just prior to stop. | 20.8 mA (Max. +5% of full scale) |

The above values may fluctuate if offset/gain adjustment has been applied.

To specify the output hold function, use a Programming Device to set the DM Area words D (m+2) to D (m+5) as shown in the following table.

| DM word | Function                             | Set value                                                                                                                                                                                                   |
|---------|--------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| D (m+2) | Output 1: Output status when stopped | xx00: CLR<br>Output 0 or minimum value of range (-5%).<br>xx01: HOLD<br>Hold output value prior to stop.<br>xx02: MAX<br>Output maximum value of range (105%).<br>Set any value in the leftmost bytes (xx). |
| D (m+3) | Output 2: Output status when stopped |                                                                                                                                                                                                             |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

**Note** After specifying the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit.

## 9-7-4 Output Scaling Function

When upper and lower limits (within a decimal range of -32,000 to 32,000) have been preset in 16-bit binary data (from 8300 to 7D00) in the CPU Unit's DM Area, within a range of -32,000 to 32,000 decimal, analog output set values are automatically converted to the resolution value with the upper and lower limits taken as full scale, and are then converted from digital to analog. (See note 1.) This scaling function eliminates the previous necessity of providing programs for numeric conversion from specified units. It is only enabled, however, for a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 500  $\mu$ s and a resolution of 8,000).

- Note**
- To set the upper or lower limit to a negative number, use two's complement. (Set 8300 to FFF for -32,000 to -1.)
  - Addresses  $m = D20000 + \text{unit number} \times 100$  are allocated in the DM Area.
  - Besides upper limit > lower limit, it is also possible to set lower limit < upper limit. (Reverse scaling is supported.)
  - Actual D/A conversion is executed at up to -5% to +105% of full scale.
  - When setting upper and lower limits in the DM Area in the specified units, be sure to make the settings in 16-bit binary data (with negative values set as two's complement).
  - The scaling function is enabled for only a conversion time of 1 ms and a resolution of 4,000 (and not for a conversion time of 500  $\mu$ s and a resolution of 8,000).
  - The scaling function cannot be used when the ratio conversion function is used.

8. If the scaling upper limit equals the lower limit, or if the scaling upper limit or lower limit is outside the range of  $\pm 32,000$ , a scaling data setting error is generated and scaling cannot be executed. Operation starts normally when both the upper and lower limits are set to 0000 (the default values).

### Setting Upper and Lower Limits for Output Scaling

Set the scaling upper and lower limits for outputs 1 and 2 in words D (m+19) to D (m+22) of the DM Area, as shown below.

**Note** For decimal numbers  $-32,000$  to  $+32,000$ , set 16-bit binary data (8300 to 7D00).


| DM word  | Bits                         |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
|----------|------------------------------|----|----|----|----|----|---|---|---|---|---|---|---|---|---|---|
|          | 15                           | 14 | 13 | 12 | 11 | 10 | 9 | 8 | 7 | 6 | 5 | 4 | 3 | 2 | 1 | 0 |
| D (m+19) | Output 1 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+20) | Output 1 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+21) | Output 2 scaling lower limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |
| D (m+22) | Output 2 scaling upper limit |    |    |    |    |    |   |   |   |   |   |   |   |   |   |   |

### Example Setting 1

Set the following conditions in D (m+19) to D (m+22). (The values shown in parentheses are binary data.)

| Setting condition   | Set value     |
|---------------------|---------------|
| Output signal range | 0 to 10 V     |
| Scaling lower limit | 0000 (0000)   |
| Scaling upper limit | 10,000 (2710) |

### When Output Signal Range is 0 V to 10 V



The following table shows the correspondence between output signals and converted scaling values. (The values shown in parentheses are 16-bit binary data.)


| Output set value | Output signal |
|------------------|---------------|
| 0000 (0000)      | 0 V           |
| 10,000 (2710)    | 10 V          |
| -500 (FE0C)      | -0.5 V        |
| 10,500 (2904)    | 10.5 V        |

### Example Setting 2 (Reverse Scaling)

Set the following conditions in D (m+27) to D (m+34). (The values shown in parentheses are binary data.)

| Setting condition   | Set value    |
|---------------------|--------------|
| Output signal range | 0 to 10 V    |
| Scaling lower limit | 10000 (2710) |
| Scaling upper limit | 0000 (0000)  |

## When Output Signal Range is 0 V to 10 V




The following table shows the correspondence between output signals and converted scaling values. (The values shown in parentheses are 16-bit binary data.)

| Conversion result | Output signal |
|-------------------|---------------|
| 10,000 (2710)     | 0 V           |
| 0000 (0000)       | 10 V          |
| 10,500 (2904)     | -0.5 V        |
| -500 (FE0C)       | 10.5 V        |

## 9-7-5 Output Setting Errors

If the analog output set value is greater than the specified range, a setting error signal will be stored in CIO word n+9 (bits 00 and 01).



When a setting error is detected for a particular output, the corresponding bit turns ON. When the error is cleared, the bit turns OFF.

- Note**
1. For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .
  2. The voltage for an output number at which a setting error has occurred will be output according to the output hold function.

## 9-8 Ratio Conversion Function

The Analog I/O Unit has a ratio conversion function that enables it to perform analog-to-analog conversions by itself, without utilizing the PLC. It can use either Loop 1 (input number 1 → output number 1), Loop 2 (input number 2 → output number 2).


Input 1 → Ratio bias calculation → Output 1

Input 2 → Ratio bias calculation → Output 2

The relationship between the analog input and the analog output is expressed by the following conversion equations.

**Positive Gradient Conversion**

$$(\text{Analog output}) = A \times (\text{Analog input}) + B$$



A: Ratio set value      0 to 99.99 (BCD)

B: Bias      8000 to 7FFF (16-bit binary data)

The following example is for an I/O range of  $-10$  to  $10$  V.

Constant A:    0050 (0.5)

Constant B:    0190 (2.0 V)


Analog input:    $-10$  to  $10$  V

Analog output    $= 0.5 \times (-10 \text{ to } 10 \text{ V}) + 2.0 \text{ V}$   
 $= -3.0 \text{ to } 7.0 \text{ V}$

**Note** The scaling function cannot be used simultaneously with the ration conversion function.

**Negative Gradient Conversion**

$$(\text{Analog output}) = F - A \times (\text{Analog input}) + B$$



F: Output range maximum value

A: Ratio set value      0 to 99.99 (BCD)

B: Bias      8000 to 7FFF (16-bit binary data)

The following example is for an I/O range of  $0$  to  $10$  V.

Constant A:    1000 (10.0)

Constant B:    0068 (0.5 V)


F:      10 V (output range maximum value)

Analog input:    $0$  to  $1$  V

Analog output    $= 10 \text{ V} - 10 \times (0 \text{ to } 1 \text{ V}) + 0.5 \text{ V}$   
 $= 10.5 \text{ to } 0.5 \text{ V}$

### Specifying Ratio Conversion Function

To specify the use of Loop 1 and Loop 2 and their I/O relationships, set bits 08 to 11 of DM Area word D (m) as shown in the following diagram.



The response time of ratio conversion (input-to-output conversion) is 850  $\mu$ s for a resolution of 4,000 and 420  $\mu$ s for a resolution of 8,000.

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

### Specifying Ratio Set Value and Bias

The ratio set value (A) and the bias (B) are set in the DM words from D(m+10) to D (m+13).

| DM word  | Function                                               | Set value                                    |
|----------|--------------------------------------------------------|----------------------------------------------|
| D (m+10) | Loop 1 (input 1 $\rightarrow$ output 1),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+11) | Loop 1 (input 1 $\rightarrow$ output 1),<br>B constant | 16-bit binary data                           |
| D (m+12) | Loop 2 (input 2 $\rightarrow$ output 2),<br>A constant | BCD 0 to 9999 (0.00 to 99.99;<br>unit: 0.01) |
| D (m+13) | Loop 2 (input 2 $\rightarrow$ output 2),<br>B constant | 16-bit binary data                           |

For the DM word addresses,  $m = D20000 + (\text{unit number} \times 100)$ .

#### Note

- After making the DM settings from a Programming Device, it will be necessary to either turn the power to the PLC OFF and ON, or turn ON the Special I/O Unit Restart Bit to transfer the contents of the DM settings to the Special I/O Unit. For details regarding the Special I/O Unit Restart Bit, refer to 9-10-4 *Restarting Special I/O Units*.
- The calculation results will be output in digital values to word n+5 (Loop 1) and word n+6 (Loop 2).
- If an input cable is disconnected, the calculation value will become 0000, and the analog output value will be output according to the output hold function.
- If the output value exceeds the specified signal range due to the ratio conversion of the digital input value, the calculation result and analog output will be given as the lower or upper-limit value.

## 9-9 Adjusting Offset and Gain

These functions can be used to calibrate inputs or outputs according to the devices that are connected.

### Input Calibration Function

When the resolution is set to 4,000, this function takes an output device's offset voltage (or current) and gain voltage (or current) as the analog input conversion data 0000 and 0FA0 (or 07D0 when the range is  $\pm 10$  V). For example, when used in a range of 1 to 5 V, a range of 0.8 to 4.8 V may be output even if the external device specifications are for 1 to 5 V. In such cases, when the external device outputs an offset voltage of 0.8 V, the converted data at the Analog Input Unit will be FF38, at a resolution of 4,000. When a gain voltage of 4.8 V is output, the converted data will be 0EDA. With the offset and gain adjustment functions, when 0.8 V and 4.8 V are input, then the values are converted to 0000 and 0FA0 respectively (instead of FF38 and 0EDA).

| Output device offset and gain voltage | Converted data before adjustment | Converted data after adjustment |
|---------------------------------------|----------------------------------|---------------------------------|
| 0.8 V                                 | FF38 (FE70)                      | 0000 (0000)                     |
| 4.8 V                                 | 0EDA (0DB4)                      | 0FA0 (1F40)                     |

(Resolution: 8,000)

### Input Calibration Function

This function adjusts output voltages according to input device offset values and gain values, and takes the presently set values of the Unit to be 0000 and 00FA0 (or 07D0 when the range is  $\pm 10$  V) respectively. For example, assume that the specifications for an external input device (such as a display device) are 100.0 to 500.0. If voltage is output by the Analog Output Unit at a set value of 0000, and the actual display at the external input device shows not 100.0 but 100.5, the output voltage can be adjusted (lowered in this case) so that the display will show 100.0, and the set value (FFFB in this case) when the display shows exactly 100.0 can be set as 0000.

Similarly, for the gain value, if the Analog Output Unit outputs voltage at a set value of 0FA0, and the actual display at the external input device shows not 500.0 but 500.5, the output voltage can be adjusted (lowered in this case) so that the display will show 500.0, and the set value (0F9B in this case) when the display shows exactly 500.0 can be set as 0FA0.


| Display at external input device | Set value before adjustment (word n+8) | Set value after adjustment |
|----------------------------------|----------------------------------------|----------------------------|
| 100.0                            | FFFB (FFFD)                            | 0000 (0000)                |
| 500.0                            | 0F9B (1F36)                            | 0FA0 (1F40)                |

(Resolution: 8,000)



### 9-9-1 Adjustment Mode Operational Flow

The adjustment mode enables the input or output of the connected devices to be calibrated. Refer to 2-7 *Adjusting Offset and Gain* and 5-7 *Adjusting Offset and Gain* for details of input and output functions. The following diagram shows the flow of operations when using the adjustment mode for adjusting offset and gain.



**⚠ Caution** Set the PLC to PROGRAM mode when using the Analog I/O Unit in adjustment mode. If the PLC is in MONITOR mode or RUN mode, the Analog I/O Unit will stop operating, and the input and output values that existed immediately before this stoppage will be retained.


**Caution** Always perform adjustments in conjunction with offset and gain adjustments.

**Note** Input adjustments can be performed more accurately in conjunction with mean value processing.

## 9-9-2 Input Offset and Gain Adjustment Procedures


### Specifying Input Number to be Adjusted

To specify the input number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)




### Bits Used for Adjusting Offset and Gain

The CIO word (n+1) bits shown in the following diagram are used for adjusting offset and gain.



**Offset Adjustment**

The procedure for adjusting the analog input offset is explained below. As shown in the following diagram, the offset is adjusted by sampling inputs so that the conversion value becomes 0000.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0

A 0

MON



200100 ^ OFF

SET

200100 ^ ON

The analog input's digital conversion values while the Offset Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/current switch is ON.

3. Input the voltage or current so that the conversion value becomes 0000. The following table shows the offset adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value    |
|--------------------|-----------------|--------------------------------|
| 0 to 10 V          | −0.5 to 0.5 V   | FF38 to 00C8<br>(FE70 to 0190) |
| −10 to 10 V        | −1.0 to 1.0 V   |                                |
| 1 to 5 V           | 0.8 to 1.2 V    |                                |
| 0 to 5 V           | −0.25 to 0.25 V |                                |
| 4 to 20 mA         | 3.2 to 4.8 mA   |                                |

(Values in parentheses are for a resolution of 8,000.)

4. After inputting the voltage or current so that the conversion value for the analog input terminal is 0000, turn ON bit 04 (the Set Bit) of CIO word n+1, and then turn it OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200100 ^ ON

RESET

200100 ^ OFF


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

- Note**
- The EEPROM can be overwritten 50,000 times.
  - While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

## Gain Adjustment


The procedure for adjusting the analog input gain is explained below. As shown in the following diagram, the gain is adjusted by sampling inputs so that the conversion value is maximized.



The following example uses input number 1 adjustment for illustration. (The unit number is 0.)


1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)



The analog input's digital conversion values while the Gain Bit is ON will be monitored in CIO word n+8.

2. Check whether the input devices are connected.



For current input, check that the voltage/ current switch is ON.

3. Input the voltage or current so that the conversion value is maximized (0FA0 or 07D0 for a resolution of 4,000). The following table shows the gain adjustment voltages and currents to be input according to the input signal range.

| Input signal range | Input range     | Word (n+8) monitoring value |
|--------------------|-----------------|-----------------------------|
| 0 to 10 V          | 9.5 to 10.5 V   | 0ED8 to 1068 (1DB0 to 20D0) |
| –10 to 10 V        | 9.0 to 11.0 V   | 0708 to 0898 (0E10 to 1130) |
| 1 to 5 V           | 4.8 to 5.2 V    | 0ED8 to 1068 (1DB0 to 20D0) |
| 0 to 5 V           | 4.75 to 5.25 V  | 0ED8 to 1068 (1DB0 to 20D0) |
| 4 to 20 mA         | 19.2 to 20.8 mA | 0ED8 to 1068 (1DB0 to 20D0) |

(Values in parentheses are for a resolution of 8,000.)

4. With the voltage or current having been input so that the conversion value for the Analog I/O Unit is maximized (0FA0 or 07D0, when the resolution is 4,000), turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

|        |   |     |
|--------|---|-----|
| 200104 | ^ | OFF |
|--------|---|-----|

|        |   |    |
|--------|---|----|
| 200104 | ^ | ON |
|--------|---|----|

|        |   |     |
|--------|---|-----|
| 200104 | ^ | OFF |
|--------|---|-----|

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

5. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

|        |   |    |
|--------|---|----|
| 200101 | ^ | ON |
|--------|---|----|

|        |   |     |
|--------|---|-----|
| 200101 | ^ | OFF |
|--------|---|-----|

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note**

1. The EEPROM can be overwritten 50,000 times.
2. While the Offset Bit or the Gain Bit is ON, the present conversion data will be displayed in word n+8.  
If the Offset Bit or the Gain Bit is OFF, the value immediately prior to turning the bit OFF will be held.

**Clearing Offset and Gain Adjusted Values**

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses input number 1 adjustment for illustration. (The unit number is 0.)

**1,2,3...**

1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the input value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105      ^    OFF

200105      ^    ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104      ^    OFF

200104      ^    ON

200104      ^    OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105      ^    ON

200105      ^    OFF

**⚠ Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.


**⚠ Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### 9-9-3 Output Offset and Gain Adjustment Procedures


#### Specifying Output Number to be Adjusted

To specify the output number to be adjusted, write the value to the rightmost byte of CIO word n as shown in the following diagram.




For the CIO word addresses,  $n = \text{CIO } 2000 + \text{unit number} \times 10$ .

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)




#### Bits Used for Adjusting Offset and Gain

The CIO word n+1 bits shown in the following diagram are used for adjusting offset and gain.



#### Offset Adjustment

The procedure for adjusting the analog output offset is explained below. As shown in the following diagram, the set value is adjusted so that the analog output reaches the standard value (0 V/1 V/4 mA).





The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

- 1,2,3...
1. Turn ON bit 00 (the Offset Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT#

C2

A0

A0

B1

A0

A0


MON

200100 ^ OFF

SET

200100 ^ ON

2. Check whether the output devices are connected.



3. Monitor CIO word n+8 and check the set value while the Offset Bit is ON.

CLR

000000 CT00

SHIFT

CH\*DM

C2

A0

A0

8

MON


2008 0000

4. Change the set value so that the output voltage are as shown in the following table. The data can be set within the indicated ranges.


| Output signal range | Possible output voltage/current adjustment | Output range                   |
|---------------------|--------------------------------------------|--------------------------------|
| 0 to 10 V           | −0.5 to 0.5 V                              | FF38 to 00C8<br>(FE70 to 0190) |
| −10 to 10 V         | −1.0 to 1.0 V                              |                                |
| 1 to 5 V            | 0.8 to 1.2 V                               |                                |
| 0 to 5 V            | −0.25 to 0.25 V                            |                                |
| 4 to 20 mA          | 3.2 to 4.8 mA                              |                                |

(Values in parentheses are for a resolution of 8,000.)

Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.




The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output becomes an appropriate value, at which time, it will turn OFF.



5. Check the 0-V/1-V/4 mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Offset Bit is ON, the offset value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the offset adjustment, turn OFF bit 00 (the Offset Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | A<br>0 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200100 ^ ON

SET

200100 ^ OFF


**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### Gain Adjustment

The procedure for adjusting the analog output gain is explained below. As shown in the following diagram, the set value is adjusted so that the analog output is maximized (to 10 V/5 V/20 mA).



The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

1,2,3...

1. Turn ON bit 01 (the Gain Bit) of CIO word n+1. (Hold the ON status.)

CLR

000000 CT00

SHIFT

CONT  
#

C 2

A 0

A 0

B 1

A 0

B 1



MON

200101 ^ OFF

SET

200101 ^ ON

2. Check whether the output devices are connected.



3. Monitor CIO word n+8 and check the set value while the Gain Bit is ON.

CLR

000000 CT00

SHIFT

CH  
\*DM

C 2

A 0

A 0

8

MON


2008 0000

4. Change the set value so that the output voltage is as shown in the following table. The data can be set within the indicated ranges.


| Output signal range | Possible output voltage/current adjustment | Output range                |
|---------------------|--------------------------------------------|-----------------------------|
| 0 to 10 V           | 9.5 to 10.5 V                              | 0ED8 to 1068 (1DB0 to 20D0) |
| -10 to 10 V         | 9.0 to 11.0 V                              | 0708 to 0898 (0E10 to 1130) |
| 1 to 5 V            | 4.8 to 5.2 V                               | 0ED8 to 1068 (1DB0 to 20D0) |
| 0 to 5 V            | 4.75 to 5.25 V                             | 0ED8 to 1068 (1DB0 to 20D0) |
| 4 to 20 mA          | 19.2 to 20.8 mA                            | 0ED8 to 1068 (1DB0 to 20D0) |

(Values in parentheses are for a resolution of 8,000.)


Change the set value, using the Up Bit (bit 03 of word n+1) and the Down Bit (bit 02 of word n+1).




- The following example increases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



- The following example decreases the output voltage.



The bit will remain ON until the output voltage becomes an appropriate value, at which time, the output will turn OFF.



5. Check the 10 V/5 V/20 mA output, and then turn bit 04 (the Set Bit) of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Gain Bit is ON, the gain value will be saved to the Unit's EEPROM when the Set Bit turns ON.

6. To finish the gain adjustment, turn OFF bit 01 (the Gain Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | B<br>1 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200101 ^ ON

RESET

200101 ^ OFF

**! Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**! Caution** When making adjustments, be sure to perform both the offset adjustment and gain adjustment at the same time.

**Note** The EEPROM can be overwritten 50,000 times.

### Clearing Offset and Gain Adjusted Values

Follow the procedure outlined below to return the offset and gain adjusted values to their default settings.

The following example uses output number 1 adjustment for illustration. (The unit number is 0.)

- 1,2,3...** 1. Turn ON bit 05 (the Clear Bit) of CIO word n+1. (Hold the ON status.) Regardless of the set value, 0000 will be monitored in CIO word n+8.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ OFF

SET

200105 ^ ON

2. Turn bit 04 of CIO word n+1 ON and then OFF again.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | E<br>4 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200104 ^ OFF

SET

200104 ^ ON

RESET

200104 ^ OFF

While the Clear Bit is ON, the adjusted value will be cleared and reset to the default offset and gain values when the Set Bit turns ON.

3. To finish the clearing of adjusted values, turn OFF bit 05 (the Clear Bit) of CIO word n+1.

|       |           |        |        |        |        |        |        |     |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|
| SHIFT | CONT<br># | C<br>2 | A<br>0 | A<br>0 | B<br>1 | A<br>0 | F<br>5 | MON |
|-------|-----------|--------|--------|--------|--------|--------|--------|-----|

200105 ^ ON

RESET

200105 ^ OFF

**Caution** Do not turn OFF the power supply or restart the Unit while the Set Bit is ON (data is being written to the EEPROM). Otherwise, illegal data may be written in the Unit's EEPROM and "EEPROM Errors" may occur when the power supply is turned ON or when the Unit is restarted, causing a malfunction.

**Note** The EEPROM can be overwritten 50,000 times.


## 9-10 Handling Errors and Alarms

### 9-10-1 Indicators and Error Flowchart

#### Indicators

If an alarm or error occurs in the Analog I/O Unit, the ERC or ERH indicators on the front panel of the Unit will light.

Front panel of Unit




| LED          | Meaning                    | Indicator | Operating status                                                                        |
|--------------|----------------------------|-----------|-----------------------------------------------------------------------------------------|
| RUN (green)  | Operating                  | Lit       | Operating in normal mode.                                                               |
|              |                            | Not lit   | Unit has stopped exchanging data with the CPU Unit.                                     |
| ERC (red)    | Unit has detected an error | Lit       | Alarm has occurred (such as disconnection detection) or initial settings are incorrect. |
|              |                            | Not lit   | Operating normally.                                                                     |
| ERH (red)    | Error in the CPU Unit      | Lit       | Error has occurred during data exchange with the CPU Unit.                              |
|              |                            | Not lit   | Operating normally.                                                                     |
| ADJ (yellow) | Adjusting                  | Flashing  | Operating in offset/gain adjustment mode.                                               |
|              |                            | Not lit   | Other than the above.                                                                   |




### Troubleshooting Procedure

Use the following procedure for troubleshooting Analog I/O Unit errors.




## 9-10-2 Alarms Occurring at the Analog I/O Unit

When an alarm occurs at the Analog I/O Unit, the ERC indicator lights and the Alarm Flags are stored in bits 08 to 15 of CIO word n+9.



### ERC and RUN Indicators: Lit




The ERC and RUN indicators will be lit when an error occurs while the Unit is operating normally. The following alarm flags will turn ON in CIO word n+9. These alarm flags will turn OFF automatically when the error is cleared.

| Word n + 9     | Alarm flag                                | Error contents                                                 | I/O status                                              | Countermeasure                                                                                                                  |
|----------------|-------------------------------------------|----------------------------------------------------------------|---------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------|
| Bits 00 and 01 | Output Set Value Error                    | The output setting range has been exceeded.                    | Output value set by output hold function.               | Correct the set value.                                                                                                          |
| Bits 04 to 07  | Disconnection Detection                   | A disconnection was detected. (See note.)                      | Conversion data becomes 0000.                           | Check the rightmost byte of CIO word n+9. The inputs for bits that are ON may be disconnected. Restore any disconnected inputs. |
| Bit 14         | (Adjustment mode)<br>EEPROM Writing Error | An EEPROM writing error has occurred while in adjustment mode. | Holds the output status immediately prior to the error. | Turn the Set Bit OFF, ON, and OFF again.<br>If the error persists even after the reset, replace the Analog I/O Unit.            |

**Note** Disconnection detection operates for input numbers used with a range of 1 to 5 V (4 to 20 mA).


For the CIO word addresses,  $n = \text{CIO } 2000 + (\text{unit number} \times 10)$ .

**ERC Indicator and RUN Indicator: Lit, ADJ Indicator: Flashing**

This alarm will occur in the case of incorrect operation while in the adjustment mode. In adjustment mode, the Adjustment Mode ON Flag will turn ON in bit 15 of CIO word n+9.

| Word n + 9     | Alarm flag                                                 | Error contents                                                                                                                                                               | I/O status                                                                  | Countermeasure                                                                                                                                                                                       |
|----------------|------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Bit 12         | (Adjustment mode)<br>Input Value Adjustment Range Exceeded | In adjustment mode, offset or gain cannot be adjusted because input value is out of the permissible range for adjustment.                                                    | Conversion data corresponding to the input signal is monitored in word n+8. | If making the adjustment by means of a connected input device, first adjust the input device before adjusting the Analog I/O Unit.                                                                   |
| Bit 13         | (Adjustment mode)<br>I/O Number Setting Error              | In adjustment mode, adjustment cannot be performed because the specified input or output number is not set for use or because the wrong input or output number is specified. | Holds the values immediately prior to the error. No data is changed.        | Check whether the word n input or output number to be adjusted is set from 11 to 14, or 21 to 24. Check whether the input or output number to be adjusted is set for use by means of the DM setting. |
| Bit 15 only ON | (Adjustment Mode)<br>PLC Error                             | The PLC is in either MONITOR or RUN mode while the Analog I/O Unit is operating in adjustment mode.                                                                          | Holds the values immediately prior to the error. No data is changed.        | Change the setting in bits 00 to 07 of D(m+18) and then either turn the power supply to the PLC OFF and ON or turn ON the Special I/O Unit Restart Bit.                                              |

**Note** When a PLC error occurs in the adjustment mode, Unit operations will stop operating. (The input and output values immediately prior to the error will be held.)

**ERC Indicator: Lit, RUN Indicator: Not Lit**

The ERC indicator will be lit when the initial settings for the Analog I/O Unit are not set correctly. The alarm flags for the following errors will turn ON in


CIO word n+9. These alarm flags will turn OFF when the error is cleared and the Unit is restarted, or the Special I/O Unit Restart Bit is turned ON and then OFF again.

| Word n + 9 | Alarm flag                                               | Error contents                                                                                                                                                  | I/O status                                       | Countermeasure                       |
|------------|----------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|--------------------------------------|
| Bit 08     | Ratio Conversion Use Setting Error                       | The I/O number for the ratio conversion function has been set to be not used.                                                                                   | Conversion does not start and data becomes 0000. | Set the I/O number for use.          |
|            | Scaling Data Setting Error                               | There is a mistake in the upper or lower limit setting when scaling is used. The set value is exceeded, the upper limit equals the lower limit (not 0000), etc. |                                                  | Correct the settings.                |
| Bit 09     | Ratio Set Value Error                                    | A number outside of the 0 to 9999 BCD range has been specified for the ratio set value.                                                                         |                                                  | Specify a number from 0 to 9999 BCD. |
| Bit 10     | Output Hold Setting Error                                | The wrong output status for when conversion is stopped has been specified.                                                                                      |                                                  | Specify a number from 0000 to 0002.  |
| Bit 11     | Mean Value Processing Setting Error                      | The wrong number of samplings has been specified for mean processing.                                                                                           |                                                  | Specify a number from 0000 to 0006.  |
| Bit 12     | Conversion Time/Resolution, Operation Mode Setting Error | The conversion time/resolution setting or operation mode setting is incorrect.                                                                                  |                                                  | Set 00 hex or C1 hex.                |

### 9-10-3 Errors in the CPU Unit

When errors occur in the CPU Unit or I/O bus, and I/O refresh with the Special I/O Unit is not performed correctly resulting in the Analog I/O Unit malfunctioning, the ERH indicator will be lit.

#### ERH and RUN Indicators: Lit



The ERH and RUN indicators will be lit if an error occurs in the I/O bus causing a WDT (watchdog timer) error in the CPU Unit, resulting in incorrect I/O refresh with the Analog I/O Unit.


Turn ON the power supply again or restart the system.

For further details, refer to *CJ-series Programmable Controllers Operation Manual* (W393).

| Error                                 | Error contents                                             | Input condition                                    | Output condition                                   |
|---------------------------------------|------------------------------------------------------------|----------------------------------------------------|----------------------------------------------------|
| I/O bus error                         | Error has occurred during data exchange with the CPU Unit. | Conversion data becomes 0000.                      | Depends on the output hold function.               |
| CPU Unit monitoring error (See note.) | No response from CPU Unit during fixed period.             | Maintains the condition existing before the error. | Maintains the condition existing before the error. |
| CPU Unit WDT error                    | Error has been generated in CPU Unit.                      | Changes to undefined state.                        | Depends on the output hold function.               |

**Note** No error will be detected by the CPU Unit or displayed on the Programming Console, because the CPU Unit is continuing operation.

ERH Indicator: Lit, RUN Indicator: Not Lit



The unit number for the Analog I/O Unit has not been set correctly.

| Error                          | Error contents                                                                                                          | Input condition                                  | Output condition              |
|--------------------------------|-------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------|-------------------------------|
| Duplicate Unit Number          | The same unit number has been assigned to more than one Unit or the unit number was set to a value other than 00 to 95. | Conversion does not start and data becomes 0000. | The output value will be 0 V. |
| Special I/O Unit Setting Error | The Special I/O Units registered in the I/O table are different from the ones actually mounted.                         |                                                  |                               |

### 9-10-4 Restarting Special I/O Units

There are two ways to restart Special I/O Unit operation after having changed DM contents or having cleared the cause of an error. The first way is to turn the power to the PLC OFF and ON, and the second way is to turn ON the Special I/O Unit Restart Bit ON.

#### Special I/O Unit Restart Bits

| Bits   | Functions            |                                                                                |
|--------|----------------------|--------------------------------------------------------------------------------|
| A50200 | Unit #0 Restart Bit  | Turning the Restart Bit for any Unit ON and then OFF again restarts that Unit. |
| A50201 | Unit #1 Restart Bit  |                                                                                |
| to     | to                   |                                                                                |
| A50215 | Unit #15 Restart Bit |                                                                                |
| A50300 | Unit #16 Restart Bit |                                                                                |
| to     | to                   |                                                                                |
| A50715 | Unit #95 Restart Bit |                                                                                |

If the error is not cleared even after turning the Special I/O Unit Restart Bit ON and then OFF again, then replace the Unit.

Input data will be 0000 and output will be 0 V or 0 mA during restart.

### 9-10-5 Troubleshooting

The following tables explain the probable causes of troubles that may occur, and the countermeasures for dealing with them.

#### Conversion Data Does Not Change

| Probable cause                                                                           | Countermeasure                                                            | Page |
|------------------------------------------------------------------------------------------|---------------------------------------------------------------------------|------|
| The input is not set for being used.                                                     | Set the input to be used.                                                 | 400  |
| The peak value hold function is in operation.                                            | Turn OFF the peak value hold function if it is not required.              | 405  |
| The input device is not working, the input wiring is wrong, or there is a disconnection. | Using a tester, check to see if the input voltage or current is changing. | ---  |
|                                                                                          | Use Unit's alarm flags to check for a disconnection.                      | 408  |

**Value Does Not Change as Intended**

| Probable cause                                                                                                              | Countermeasure                                                                                    | Page     |
|-----------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------|----------|
| The input device's signal range does not match the input signal range for the relevant input number at the Analog I/O Unit. | Check the specifications of the input device, and match the settings for the input signal ranges. | 373      |
| The offset and gain are not adjusted.                                                                                       | Adjust the offset and gain.                                                                       | 418      |
| When using the 4 mA to 20 mA range, the voltage/current switch is not turned ON.                                            | Turn ON the voltage/current switch.                                                               | 378, 385 |
| The voltage and current ranges are not set in D (m+35).                                                                     | Set D (m+35) correctly.                                                                           | 401      |
| The ratio conversion function is set to be used, so the calculation results are being monitored.                            | Correct the conversion settings.                                                                  | 436      |

**Conversion Values are Inconsistent**

| Probable cause                                          | Countermeasure                                                                                                        | Page |
|---------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------|------|
| The input signals are being affected by external noise. | Change the shielded cable connection to the Unit's COM terminal.                                                      | 390  |
|                                                         | Insert a 0.01- $\mu$ F to 0.1- $\mu$ F ceramic capacitor or film capacitor between the input's (+) and (–) terminals. | ---  |
|                                                         | Try increasing the number of mean value processing buffers.                                                           | 402  |

**Analog Output Does Not Change**

| Probable Cause                                                | Countermeasure                            | Page     |
|---------------------------------------------------------------|-------------------------------------------|----------|
| The output is not set for being used.                         | Set the output to be used.                | 409      |
| The output hold function is in operation.                     | Turn ON the Output Conversion Enable Bit. | 412      |
| The conversion value is set outside of the permissible range. | Set the data within the range.            | 375, 409 |

**Output Does Not Change as Intended**


| Probable Cause                                                                                                                     | Countermeasure                           | Page |
|------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|------|
| The output signal range setting is wrong.                                                                                          | Correct the output signal range setting. | 410  |
| The I/O specifications of the output device do not match those of the Analog I/O Unit (e.g., input signal range, input impedance). | Change the output device.                | 371  |
| The offset or gain is not adjusted.                                                                                                | Adjust the offset or gain.               | 418  |
| The voltage and current ranges are not set in D (m+35).                                                                            | Set D (m+35) correctly.                  | 401  |
| The ratio conversion function is set to be used.                                                                                   | Correct the conversion settings.         | 415  |

**Outputs are Inconsistent**


| Probable Cause                                           | Countermeasure                                                                         | Page |
|----------------------------------------------------------|----------------------------------------------------------------------------------------|------|
| The output signals are being affected by external noise. | Try changing the shielded cable connection (e.g., the grounding at the output device). | ---  |

# Appendix A Dimensions

**CS-series Units: CS1W-AD041-V1/081-V1, CS1W-DA08V/08C/041, CS1W-MAD44**




**CS1W-AD161**




## CS-series Unit Terminal Block Dimensions

Terminal size: M3




## CJ-series Units: CJ1W-AD041-V1/081-V1/042, CJ1W-DA021/041/08V/08C/042V, CJ1W-MAD42





## CJ-series Unit Terminal Block Dimensions



**Note** The appearance varies with the model.



# Appendix B

## Sample Programs


### Obtaining Analog Input Conversion Values

This is a program for obtaining the Analog Input Unit's input conversion values. Individual input values are obtained by MOV(021) when their Disconnection Detection Flags are OFF.

#### Unit Settings

| Item               | Setting contents            | Actual settings                |
|--------------------|-----------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1               | ---                            |
| Unit number        | #0                          | Unit number switches: 00       |
| Operation mode     | Normal mode                 | Back-panel DIP switch: All OFF |
| Input number       | Inputs 1 to 8 used          | D20000 = 00FF                  |
| Input signal range | All input numbers, 1 to 5 V | D20001 = AAAA                  |

#### Program Example




### Writing Analog Output Set Values

This is a program for writing the Analog Output Unit's output set values.

#### Unit Settings


| Item                | Setting contents           | Actual settings                |
|---------------------|----------------------------|--------------------------------|
| Unit                | CS1W-DA08V                 | ---                            |
| Unit number         | #0                         | Unit number switches: 00       |
| Operation mode      | Normal mode                | Back-panel DIP switch: All OFF |
| Output number       | Output 1 used              | D20000 = 0001                  |
| Output signal range | Output number 1, 0 to 10 V | D20001 = 0001                  |

## Program Example



## Upper and Lower-limit Alarm (Constant Monitoring)


Comparisons are made to the upper and lower limits of the A/D conversion values or D/A output values from the beginning of operation. If they fall outside the specified range, the Alarm Flag will turn ON.



## Unit Settings


| Item               | Setting contents          | Actual settings                |
|--------------------|---------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1             | ---                            |
| Unit number        | #0                        | Unit number switches: 00       |
| Operation mode     | Normal mode               | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used              | D20000 = 0001                  |
| Input signal range | Input number 1, 0 to 10 V | D20001 = 0001                  |

## Program Example



# Upper and Lower-limit Alarm (with Standby Sequence)


Comparisons are made to the upper and lower limits of the A/D conversion values or D/A output values after the value falls within the range between the upper limit and lower limit following the beginning of operation. If they fall outside the specified range, the Alarm Flag will turn ON.



## Unit Settings

| Item               | Setting contents          | Actual settings                |
|--------------------|---------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1             | ---                            |
| Unit number        | #0                        | Unit number switches: 00       |
| Operation mode     | Normal mode               | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used              | D20000 = 0001                  |
| Input signal range | Input number 1, 0 to 10 V | D20001 = 0001                  |

## Program Example



## Scaling

### Using the Scaling Functions

**Note** This function is supported only by the CS1W-AD161, CJ1W-MAD42, CJ1W-DA08V/08C/042V, and CJ1W-AD042.


#### Outline

A pressure sensor is connected to analog input 1 of CJ1W-MAD42. The pressure sensor outputs an analog signal of between 0 and 20 mA for a pressure between 0 and 500 Pa. Therefore, for a 4 to 20-mA input, a binary value of 0000 to 01F4 (0 to 500 decimal) in engineering units for the pressure in Pa is directly set using the MOV instruction. The analog input scaling function of the CJ1W-MAD42 is used here. Therefore, scaling in the ladder program (using the SCL or other instruction) is not required to convert the values 0000 to 0FA0 of the resolution to engineering units 0000 to 01F4.

#### Unit Settings

| Item                                                  | Setting contents                                                    | Actual settings                                          |
|-------------------------------------------------------|---------------------------------------------------------------------|----------------------------------------------------------|
| Unit                                                  | CJ1W-MAD42                                                          | ---                                                      |
| Unit number                                           | #0                                                                  | Unit number switches: 00                                 |
| Input number                                          | Input 1 (and output 1) used                                         | D20000 = 0011                                            |
| Input signal range                                    | 1 to 5 V/4 to 20 mA                                                 | D20001 = 0202                                            |
| Voltage/current range                                 | Current: 4 to 20 mA                                                 | D20035 = 0011                                            |
| Conversion time/resolution setting and operation mode | Conversion time: 1 ms, resolution: 4,000<br>Normal mode             | D20018 = 0000                                            |
| Scaling settings for input 1                          | Lower limit: 0000 (0000 decimal)<br>Upper limit: 01F4 (500 decimal) | D20027 (lower limit) = 0000<br>D20028 (upper limit) 01F4 |

#### Program Example




### Not Using the Scaling Function

#### Outline

A/D conversion values are converted according to the linear function calculated from the offset and the values of  $\Delta X$  and  $\Delta Y$ , and retrieved as scaling data.

- The following example uses at resolution of 4,000 and an input signal range of 1 to 5 V where 1 to 5 V is scaled to 0000 to 0300 (0°C to 300°C).



Unit Settings

| Item               | Setting contents         | Actual settings                |
|--------------------|--------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1            | ---                            |
| Unit number        | #0                       | Unit number switches: 00       |
| Operation mode     | Normal mode              | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used             | D20000 = 0001                  |
| Input signal range | Input number 1, 1 to 5 V | D20001 = 0002                  |

Program Example

- Data Flow (Unit Number 0):  
Word CIO 2001 (A/D Conversion Value) → D00200 (Scaling Result)




The value of word CIO 2005 is scaled according to the linear function calculated using the offset (0000 hex), and the values of  $\Delta X$  (1068 hex) and  $\Delta Y$  (0315 hex). The scaled value is then stored in word D00200.

DM Area Settings

|              |                  |
|--------------|------------------|
| D00100: 0000 | Offset           |
| D00101: 1068 | $\Delta X$ value |
| D00102: 0315 | $\Delta Y$ value |

**Note** The value scaled using SCL2(486) is stored as positive or negative BCD data according to the status of the CY (Carry) Flag. To convert the BCD data into signed binary data, use the SCL3(487) instruction.





### DM Area Settings

|              |                                  |
|--------------|----------------------------------|
| D00300: 0000 | - - - - Offset                   |
| D00301: 0200 | - - - - ΔX value                 |
| D00302: 00C8 | - - - - ΔY value                 |
| D00303: 00C8 | - - - - Maximum conversion value |
| D00304: FF9C | - - - - Minimum conversion value |

## Signed Binary-to-Signed BCD Conversion

A/D conversion values (16-bit binary data) are recognized as 4-digit signed binary data, and converted into 8-digit signed BCD data. When the leftmost bit is 1, the binary data is recognized as a two's complement. The "signed BCD" data refers to BCD data that is indicated by 7-digit data and 1-digit sign (0: +; F: -).

- Conversion Graph (Horizontal Axis: Input Voltage, Vertical Axis: BCD Data)




### Unit Settings

| Item               | Setting contents          | Actual settings                |
|--------------------|---------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1             | ---                            |
| Unit number        | #0                        | Unit number switches: 00       |
| Operation mode     | Normal mode               | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used              | D20000 = 0001                  |
| Input signal range | Input number 1, 0 to 10 V | D20001 = 0001                  |



### Program Example

- Data Flow (Unit Number 0):  
Word 2001 (A/D Conversion Value) → Words 0201 and 0200 (Conversion Result)



- (1) If the leftmost bit is a 1 (negative number) in 16-bit binary data, the data is reversed and the leftmost word becomes F000.
- (2) 16-bit binary data is converted to BCD.
- (3) Signed BCD data is output to words 0200 and 0201.

## Square Root Calculation


Data expressed as quadratic curves, such as thermocouple inputs, is converted and output to linear data (0000 to 4000).

### Unit Settings

| Item               | Setting contents          | Actual settings                |
|--------------------|---------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1             | ---                            |
| Unit number        | #0                        | Unit number switches: 00       |
| Operation mode     | Normal mode               | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used              | D20000 = 0001                  |
| Input signal range | Input number 1, 0 to 10 V | D20001 = 0001                  |

### Program Example

- Data Flow (Unit Number 0): Word 2001 (A/D Conversion Value) → Word 0200 (Calculation Result)



- (1) The negative number portion is added to the conversion value (word 2001).
- (2) The binary data is scaled to a range of 0 to 4000.
- (3) The scaling results are multiplied by 4400.
- (4) The square root is calculated, and the result is output to word 0200.

### DM Area Settings

Input signal range: 0 to 10 V / 1 to 5 V / 4 to 20 mA

|                                |                                       |                                |
|--------------------------------|---------------------------------------|--------------------------------|
| D00000: 00C8                   | Digital value for -5%                 | Used with SCL(194) instruction |
| D00001: (Used for calculation) | Conversion value +C8 (-5% portion)    |                                |
| D00002: 0000                   | Lower limit: BCD                      |                                |
| D00003: 0000                   | Lower limit +C8 (-5% portion): Binary |                                |
| D00004: 4400                   | Upper limit: BCD                      |                                |
| D00005: 1130                   | Upper limit +C8 (-5% portion): Binary |                                |
| D00006: (Used for calculation) |                                       |                                |

If the result of the binary-to-BCD conversion is negative, an error will be generated by the ROOT(072) instruction.

With a signal range of -10 to 10 V, scaling is executed by augmenting the negative portion (-10 V -5%). In this program example, the value of D00000 is converted to 0898. Refer to *Scaling* on page 448 for details.

## Mean Value Processing

Data is taken for the set number of samplings and the mean value is calculated.

### Unit Settings


| Item               | Setting contents          | Actual settings                |
|--------------------|---------------------------|--------------------------------|
| Unit               | CS1W-AD081-V1             | ---                            |
| Unit number        | #0                        | Unit number switches: 00       |
| Operation mode     | Normal mode               | Back-panel DIP switch: All OFF |
| Input number       | Input 1 used              | D20000 = 0001                  |
| Input signal range | Input number 1, 0 to 10 V | D20001 = 0001                  |

**Program Example**


- Data Flow (Unit Number 0): Word 2001 (AD Conversion Value) → D00001 (Mean Value Result)

**Limit**

If the output value range is exceeded, the output voltage is held when the Conversion Enable Flag turns OFF.

**Unit Settings**

| Item                 | Setting contents              | Actual settings                |
|----------------------|-------------------------------|--------------------------------|
| Unit                 | CS1W-DA08V                    | ---                            |
| Unit number          | #0                            | Unit number switches: 00       |
| Operation mode       | Normal mode                   | Back-panel DIP switch: All OFF |
| Output number        | Output 1 used                 | D20000 = 0001                  |
| Output signal range  | All output numbers, 0 to 10 V | D20001 = 0001                  |
| Output hold function | HOLD                          | D20002 = 0001                  |

**Program Example****DM Area Settings**

|              |                  |
|--------------|------------------|
| D00001: 0000 | Lower limit: 0 V |
| D00002: 03E8 | Upper limit: 5 V |



# **Appendix C**

## **Data Memory Coding Sheets**

## CS1W-AD041-V1/CJ1W-AD041-V1

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□01  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□18  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM word | Setting contents                       |   |                        |                            |
|---------|----------------------------------------|---|------------------------|----------------------------|
|         | 15                                     | 8 | 7                      | 0                          |
| m       |                                        |   |                        | Input use designation      |
| m+1     |                                        |   |                        | Input signal range setting |
| m+2     | Input 1: Mean value processing setting |   |                        |                            |
| m+3     | Input 2: Mean value processing setting |   |                        |                            |
| m+4     | Input 3: Mean value processing setting |   |                        |                            |
| m+5     | Input 4: Mean value processing setting |   |                        |                            |
| m+18    | Conversion time/resolution setting     |   | Operation mode setting |                            |

## Use Designation

|         |         |         |         |
|---------|---------|---------|---------|
| 03      | 02      | 01      | 00      |
|         |         |         |         |
| Input 4 | Input 3 | Input 2 | Input 1 |

0: Do not use.  
1: Use

## Signal Range Setting

|         |    |         |    |         |    |         |    |
|---------|----|---------|----|---------|----|---------|----|
| 07      | 06 | 05      | 04 | 03      | 02 | 01      | 00 |
|         |    |         |    |         |    |         |    |
| Input 4 |    | Input 3 |    | Input 2 |    | Input 1 |    |

00: -10 to 10 V  
01: 0 to 10 V  
10: 1 to 5 V / 4 to 20 mA (change using voltage/current switch)  
11: 0 to 5 V

## Mean Value Processing Setting

|        |    |        |    |        |    |        |    |
|--------|----|--------|----|--------|----|--------|----|
| 15     | 12 | 11     | 08 | 07     | 04 | 03     | 00 |
|        |    |        |    |        |    |        |    |
| $16^3$ |    | $16^2$ |    | $16^1$ |    | $16^0$ |    |

0000: Mean value processing with 2 buffers.  
0001: No mean value processing  
0002: Mean value processing with 4 buffers.  
0003: Mean value processing with 8 buffers.  
0004: Mean value processing with 16 buffers.  
0005: Mean value processing with 32 buffers.  
0006: Mean value processing with 64 buffers.

## Conversion Time/Resolution Setting

|        |    |        |    |
|--------|----|--------|----|
| 15     | 12 | 11     | 08 |
|        |    |        |    |
| $16^3$ |    | $16^2$ |    |

00: Conversion time of 1 ms and resolution of 4,000  
C1: Conversion time of 250  $\mu$ s and resolution of 8,000

## Operation Mode Setting

|        |    |        |    |
|--------|----|--------|----|
| 07     | 04 | 03     | 00 |
|        |    |        |    |
| $16^1$ |    | $16^0$ |    |

00: Normal mode  
C1: Adjustment mode

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CS1W-AD081-V1/CJ1W-AD081-V1

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□01  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|         |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□07  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□08  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□09  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□18  |                  |    |    |    |    |    |    |    | 0  |    |    |    |    |    |    |    |



| DM word | Setting contents                       |   |                        |   |
|---------|----------------------------------------|---|------------------------|---|
|         | 15                                     | 8 | 7                      | 0 |
| m       | Not used.                              |   | Input use designation  |   |
| m+1     |                                        |   |                        |   |
| m+2     | Input 1: Mean value processing setting |   |                        |   |
| m+3     | Input 2: Mean value processing setting |   |                        |   |
| m+4     | Input 3: Mean value processing setting |   |                        |   |
| m+5     | Input 4: Mean value processing setting |   |                        |   |
| m+6     | Input 5: Mean value processing setting |   |                        |   |
| m+7     | Input 6: Mean value processing setting |   |                        |   |
| m+8     | Input 7: Mean value processing setting |   |                        |   |
| m+9     | Input 8: Mean value processing setting |   |                        |   |
| m+18    | Conversion time/resolution setting     |   | Operation mode setting |   |

## Use Designation

|         |         |         |         |         |         |         |         |
|---------|---------|---------|---------|---------|---------|---------|---------|
| 07      | 06      | 05      | 04      | 03      | 02      | 01      | 00      |
|         |         |         |         |         |         |         |         |
| Input 8 | Input 7 | Input 6 | Input 5 | Input 4 | Input 3 | Input 2 | Input 1 |

0: Do not use.  
1: Use

## Signal Range Setting

|         |         |         |         |    |    |    |    |
|---------|---------|---------|---------|----|----|----|----|
| 07      | 06      | 05      | 04      | 03 | 02 | 01 | 00 |
|         |         |         |         |    |    |    |    |
| Input 4 | Input 3 | Input 2 | Input 1 |    |    |    |    |

|         |         |         |         |    |    |    |    |
|---------|---------|---------|---------|----|----|----|----|
| 15      | 14      | 13      | 12      | 11 | 10 | 09 | 08 |
|         |         |         |         |    |    |    |    |
| Input 8 | Input 7 | Input 6 | Input 5 |    |    |    |    |

00: -10 to 10 V  
01: 0 to 10 V  
10: 1 to 5 V / 4 to 20 mA (change using voltage/current switch)  
11: 0 to 5 V

## Mean Value Processing Setting

|        |        |        |        |    |    |    |    |
|--------|--------|--------|--------|----|----|----|----|
| 15     | 12     | 11     | 08     | 07 | 04 | 03 | 00 |
|        |        |        |        |    |    |    |    |
| $16^3$ | $16^2$ | $16^1$ | $16^0$ |    |    |    |    |

0000: Mean value processing with 2 buffers.  
0001: No mean value processing  
0002: Mean value processing with 4 buffers.  
0003: Mean value processing with 8 buffers.  
0004: Mean value processing with 16 buffers.  
0005: Mean value processing with 32 buffers.  
0006: Mean value processing with 64 buffers.

## Conversion Time/Resolution Setting

|        |        |    |    |
|--------|--------|----|----|
| 15     | 12     | 11 | 08 |
|        |        |    |    |
| $16^3$ | $16^2$ |    |    |

00: Conversion time of 1 ms and resolution of 4,000  
C1: Conversion time of 250  $\mu$ s and resolution of 8,000

## Operation Mode Setting

|        |        |    |    |
|--------|--------|----|----|
| 07     | 04     | 03 | 00 |
|        |        |    |    |
| $16^1$ | $16^0$ |    |    |

00: Normal mode  
C1: Adjustment mode

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CS1W-AD161

□□: Unit number

| DM Area<br>address | Bit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|--------------------|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|                    | 15  | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□01             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□03             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□04             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□05             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□06             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□07             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□08             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□09             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□10             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□11             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□12             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□13             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□14             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□15             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□16             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□17             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□18             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□19             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□20             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□21             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□22             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□23             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□24             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□25             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□26             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□27             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□28             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□29             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□30             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□31             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□32             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□33             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□34             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□35             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□36             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□37             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□38             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□39             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□40             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□41             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□42             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□43             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□44             |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM Area address | Bit |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|-----------------|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|                 | 15  | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□45          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□46          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□47          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□48          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□49          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□50          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□51          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□52          |     |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

$m = D20000 + \text{unit number} \times 100$

| DM Area address | Setting contents                            |                        |
|-----------------|---------------------------------------------|------------------------|
|                 | 15 to 08                                    | 07 to 00               |
| m               | Input use setting                           |                        |
| m+1             | Input signal range setting (inputs 1 to 8)  |                        |
| m+2             | Input signal range setting (inputs 9 to 16) |                        |
| m+3             | Input 1 mean value processing setting       |                        |
| m+4             | Input 2 mean value processing setting       |                        |
| m+5             | Input 3 mean value processing setting       |                        |
| m+6             | Input 4 mean value processing setting       |                        |
| m+7             | Input 5 mean value processing setting       |                        |
| m+8             | Input 6 mean value processing setting       |                        |
| m+9             | Input 7 mean value processing setting       |                        |
| m+10            | Input 8 mean value processing setting       |                        |
| m+11            | Input 9 mean value processing setting       |                        |
| m+12            | Input 10 mean value processing setting      |                        |
| m+13            | Input 11 mean value processing setting      |                        |
| m+14            | Input 12 mean value processing setting      |                        |
| m+15            | Input 13 mean value processing setting      |                        |
| m+16            | Input 14 mean value processing setting      |                        |
| m+17            | Input 15 mean value processing setting      |                        |
| m+18            | Input 16 mean value processing setting      |                        |
| m+19            | Conversion time/resolution setting          | Operation mode setting |
| m+20            | Input 1 scaling lower limit                 |                        |
| m+21            | Input 1 scaling upper limit                 |                        |
| m+22            | Input 2 scaling lower limit                 |                        |
| m+23            | Input 2 scaling upper limit                 |                        |
| m+24            | Input 3 scaling lower limit                 |                        |
| m+25            | Input 3 scaling upper limit                 |                        |
| m+26            | Input 4 scaling lower limit                 |                        |
| m+27            | Input 4 scaling upper limit                 |                        |
| m+28            | Input 5 scaling lower limit                 |                        |
| m+29            | Input 5 scaling upper limit                 |                        |
| m+30            | Input 6 scaling lower limit                 |                        |
| m+31            | Input 6 scaling upper limit                 |                        |
| m+32            | Input 7 scaling lower limit                 |                        |
| m+33            | Input 7 scaling upper limit                 |                        |
| m+34            | Input 8 scaling lower limit                 |                        |
| m+35            | Input 8 scaling upper limit                 |                        |

| DM Area address | Setting contents                                                  |          |
|-----------------|-------------------------------------------------------------------|----------|
|                 | 15 to 08                                                          | 07 to 00 |
| m+36            | Input 9 scaling lower limit                                       |          |
| m+37            | Input 9 scaling upper limit                                       |          |
| m+38            | Input 10 scaling lower limit                                      |          |
| m+39            | Input 10 scaling upper limit                                      |          |
| m+40            | Input 11 scaling lower limit                                      |          |
| m+41            | Input 11 scaling upper limit                                      |          |
| m+42            | Input 12 scaling lower limit                                      |          |
| m+43            | Input 12 scaling upper limit                                      |          |
| m+44            | Input 13 scaling lower limit                                      |          |
| m+45            | Input 13 scaling upper limit                                      |          |
| m+46            | Input 14 scaling lower limit                                      |          |
| m+47            | Input 14 scaling upper limit                                      |          |
| m+48            | Input 15 scaling lower limit                                      |          |
| m+49            | Input 15 scaling upper limit                                      |          |
| m+50            | Input 16 scaling lower limit                                      |          |
| m+51            | Input 16 scaling upper limit                                      |          |
| m+52            | Voltage/current range setting (Only for 1 to 5 V and 4 to 20 mA.) |          |

m = D20000 + unit number x 100

### Input Use Setting

|                          |                          |                          |                          |                          |                          |                          |                          |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| 07                       | 06                       | 05                       | 04                       | 03                       | 02                       | 01                       | 00                       |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Input 8                  | Input 7                  | Input 6                  | Input 5                  | Input 4                  | Input 3                  | Input 2                  | Input 1                  |
| 15                       | 14                       | 13                       | 12                       | 11                       | 10                       | 09                       | 08                       |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Input 16                 | Input 15                 | Input 14                 | Input 13                 | Input 12                 | Input 11                 | Input 10                 | Input 09                 |

0: Not used

1: Used

### Input Signal Range Setting

|                          |                          |                          |                          |                          |                          |                          |                          |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| 05-14                    | 13-12                    | 11-10                    | 09-08                    | 07-06                    | 05-04                    | 03-02                    | 01-00                    |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Input 8                  | Input 7                  | Input 6                  | Input 5                  | Input 4                  | Input 3                  | Input 2                  | Input 1                  |
| 05-14                    | 13-12                    | 11-10                    | 09-08                    | 07-06                    | 05-04                    | 03-02                    | 01-00                    |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Input 16                 | Input 15                 | Input 14                 | Input 13                 | Input 12                 | Input 11                 | Input 10                 | Input 9                  |

00: -10 to +10 V

01: 0 to 10 V

10: 1 to 5 V/4 to 20 mA (Select voltage/current in DM word m+52)

10: 0 to 5 V

**Mean Value Processing Setting**

15 to 12 11 to 08 07 to 04 03 to 00

|        |        |        |        |
|--------|--------|--------|--------|
| $16^3$ | $16^2$ | $16^1$ | $16^0$ |
|--------|--------|--------|--------|

0000: Mean value processing with 2 buffers

0001: No mean value processing

0002: Mean value processing with 4 buffers

0003: Mean value processing with 8 buffers

0004: Mean value processing with 16 buffers

0005: Mean value processing with 32 buffers

0006: Mean value processing with 64 buffers

**Conversion Time/Resolution or Operation Mode Setting**

15 to 12 11 to 08 07 to 04 03 to 00

|        |        |        |        |
|--------|--------|--------|--------|
| $16^3$ | $16^2$ | $16^1$ | $16^0$ |
|--------|--------|--------|--------|

00: Conversion time  
= 1 ms /resolution of  
4,000C1: Conversion time  
= 1 ms /resolution of  
4,00000: Normal mode  
01: Adjustment mode**Scaling data**

-32000 to +32000

**Voltage/current range setting (Only for 1 to 5 V and 4 to 20 mA.)**

|       |       |       |       |       |       |       |       |
|-------|-------|-------|-------|-------|-------|-------|-------|
| 07    | 06    | 05    | 04    | 03    | 02    | 01    | 00    |
|       |       |       |       |       |       |       |       |
| Input | Input | Input | Input | Input | Input | Input | Input |
| 8     | 7     | 6     | 5     | 4     | 3     | 2     | 1     |
| 15    | 14    | 13    | 12    | 11    | 10    | 09    | 08    |
|       |       |       |       |       |       |       |       |
| Input | Input | Input | Input | Input | Input | Input | Input |
| 16    | 15    | 14    | 13    | 12    | 11    | 10    | 9     |

0: Voltage

1: Current

**CJ1W-DA021**

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    | 0  | 0  |    |    |
| D2□□01  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |

| DM word | Setting contents |   |                                                 |                             |
|---------|------------------|---|-------------------------------------------------|-----------------------------|
|         | 15               | 8 | 7                                               | 0                           |
| m       | /                | / | ---                                             | Output use designation      |
| m+1     |                  |   | ---                                             | Output signal range setting |
| m+2     |                  |   | Output 1: Output status when conversion stopped |                             |
| m+3     |                  |   | Output 2: Output status when conversion stopped |                             |

## Use Designation

|    |    |
|----|----|
| 01 | 00 |
|    |    |

Output 2  
Output 1

0: Do not use.  
1: Use

## Signal Range Setting

|    |    |    |    |
|----|----|----|----|
| 03 | 02 | 01 | 00 |
|    |    |    |    |

Output 2  
Output 1

00: -10 to 10V  
01: 0 to 10 V  
10: 1 to 5 V / 4 to 20 mA  
11: 0 to 5 V

## Output Status when Conversion Stopped

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

00: CLR (0 or minimum value for each range output)  
01: HOLD (Hold prior output value.)  
02: MAX (Output maximum value of range.)

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CS1W-DA041/CJ1W-DA041

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□01  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |



| DM word | Setting contents |   |   |                                                 |
|---------|------------------|---|---|-------------------------------------------------|
|         | 15               | 8 | 7 | 0                                               |
| m       |                  |   |   | Output use designation                          |
| m+1     |                  |   |   | Output signal range setting                     |
| m+2     |                  |   |   | Output 1: Output status when conversion stopped |
| m+3     |                  |   |   | Output 2: Output status when conversion stopped |
| m+4     |                  |   |   | Output 3: Output status when conversion stopped |
| m+5     |                  |   |   | Output 4: Output status when conversion stopped |

## Use Designation

|          |          |          |          |
|----------|----------|----------|----------|
| 03       | 02       | 01       | 00       |
|          |          |          |          |
| Output 4 | Output 3 | Output 2 | Output 1 |

0: Do not use.  
1: Use

## Signal Range Setting

|          |          |          |          |    |    |    |    |
|----------|----------|----------|----------|----|----|----|----|
| 07       | 06       | 05       | 04       | 03 | 02 | 01 | 00 |
|          |          |          |          |    |    |    |    |
| Output 4 | Output 3 | Output 2 | Output 1 |    |    |    |    |

00: -10 to 10V  
01: 0 to 10 V  
10: 1 to 5 V / 4 to 20 mA  
11: 0 to 5 V

## Output Status when Conversion Stopped


|                 |                 |    |    |
|-----------------|-----------------|----|----|
| 07              | 04              | 03 | 00 |
|                 |                 |    |    |
| 16 <sup>1</sup> | 16 <sup>0</sup> |    |    |

00: CLR (0 or minimum value for each range output)  
01: HOLD (Hold prior output value.)  
02: MAX (Output maximum value of range.)

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CS1W-DA08V/08C

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□01  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|         |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□07  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□08  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□09  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |

| DM word | Setting contents                                                                   |   |                                                 |   |
|---------|------------------------------------------------------------------------------------|---|-------------------------------------------------|---|
|         | 15                                                                                 | 8 | 7                                               | 0 |
| m       |                                                                                    |   | Output use designation                          |   |
| m+1     | Output signal range setting                                                        |   |                                                 |   |
| m+2     |  |   | Output 1: Output status when conversion stopped |   |
| m+3     |                                                                                    |   | Output 2: Output status when conversion stopped |   |
| m+4     |                                                                                    |   | Output 3: Output status when conversion stopped |   |
| m+5     |                                                                                    |   | Output 4: Output status when conversion stopped |   |
| m+6     |                                                                                    |   | Output 5: Output status when conversion stopped |   |
| m+7     |                                                                                    |   | Output 6: Output status when conversion stopped |   |
| m+8     |                                                                                    |   | Output 7: Output status when conversion stopped |   |
| m+9     |                                                                                    |   | Output 8: Output status when conversion stopped |   |

## Use Designation

0: Do not use.  
1: Use

|          |          |          |          |          |          |          |          |
|----------|----------|----------|----------|----------|----------|----------|----------|
| 07       | 06       | 05       | 04       | 03       | 02       | 01       | 00       |
|          |          |          |          |          |          |          |          |
| Output 8 | Output 7 | Output 6 | Output 5 | Output 4 | Output 3 | Output 2 | Output 1 |

## Signal Range Setting (not valid for CS1W-DA08C)

|          |          |          |          |    |    |    |    |
|----------|----------|----------|----------|----|----|----|----|
| 07       | 06       | 05       | 04       | 03 | 02 | 01 | 00 |
|          |          |          |          |    |    |    |    |
| Output 4 | Output 3 | Output 2 | Output 1 |    |    |    |    |
| 15       | 14       | 13       | 12       | 11 | 10 | 09 | 08 |
| Output 8 | Output 7 | Output 6 | Output 5 |    |    |    |    |

00: -10 to 10 V  
01: 0 to 10 V  
10: 1 to 5 V  
11: 0 to 5 V

## Output Status when Conversion Stopped

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

00: CLR (0 or minimum value for each range output)  
01: HOLD (Hold prior output value.)  
02: MAX (Output maximum value of range.)

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CJ1W-DA08V/08C

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□01  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□07  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□08  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□09  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□18  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□20  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□21  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□22  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□23  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□24  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□25  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□26  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□27  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□28  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□29  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□30  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□31  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□32  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□33  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□34  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM word      | Setting contents                   |                                                 |
|--------------|------------------------------------|-------------------------------------------------|
|              | 158                                | 70                                              |
| m            | ---                                | Output use designation                          |
| m+1          | Output signal range settings       |                                                 |
| m+2          | ---                                | Output 1: Output status when conversion stopped |
| m+3          | ---                                | Output 2: Output status when conversion stopped |
| m+4          | ---                                | Output 3: Output status when conversion stopped |
| m+5          | ---                                | Output 4: Output status when conversion stopped |
| m+6          | ---                                | Output 5: Output status when conversion stopped |
| m+7          | ---                                | Output 6: Output status when conversion stopped |
| m+8          | ---                                | Output 7: Output status when conversion stopped |
| m+9          | ---                                | Output 8: Output status when conversion stopped |
| m+10 to m+17 | ---                                |                                                 |
| m+18         | Conversion time/resolution setting | Operation mode setting                          |
| m+19         | Output 1 scaling lower limit       |                                                 |
| m+20         | Output 1 scaling upper limit       |                                                 |
| m+21         | Output 2 scaling lower limit       |                                                 |
| m+22         | Output 2 scaling upper limit       |                                                 |
| m+23         | Output 3 scaling lower limit       |                                                 |
| m+24         | Output 3 scaling upper limit       |                                                 |
| m+25         | Output 4 scaling lower limit       |                                                 |
| m+26         | Output 4 scaling upper limit       |                                                 |
| m+27         | Output 5 scaling lower limit       |                                                 |
| m+28         | Output 5 scaling upper limit       |                                                 |
| m+29         | Output 6 scaling lower limit       |                                                 |
| m+30         | Output 6 scaling upper limit       |                                                 |
| m+31         | Output 7 scaling lower limit       |                                                 |
| m+32         | Output 7 scaling upper limit       |                                                 |
| m+33         | Output 8 scaling lower limit       |                                                 |
| m+34         | Output 8 scaling upper limit       |                                                 |

## Use Designation

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|    |    |    |    |    |    |    |    |

|          |          |          |          |          |          |          |          |
|----------|----------|----------|----------|----------|----------|----------|----------|
| Output 8 | Output 7 | Output 6 | Output 5 | Output 4 | Output 3 | Output 2 | Output 1 |
|----------|----------|----------|----------|----------|----------|----------|----------|

0: Do not use  
1: Use

Output Signal Range Settings  
(Not valid for the CJ1W-DA08C.)

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|    |    |    |    |    |    |    |    |

|          |          |          |          |
|----------|----------|----------|----------|
| Output 4 | Output 3 | Output 2 | Output 1 |
|----------|----------|----------|----------|

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 15 | 14 | 13 | 12 | 11 | 10 | 09 | 08 |
|    |    |    |    |    |    |    |    |

|          |          |          |          |
|----------|----------|----------|----------|
| Output 8 | Output 7 | Output 6 | Output 5 |
|----------|----------|----------|----------|

00: -10 to 10 V  
01: 0 to 10 V  
10: 1 to 5 V  
11: 0 to 5 V

## Output Status when Conversion Stopped

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

00: CLR (0 or minimum value for each range output)  
01: HOLD (Hold prior output value.)  
02: MAX (Output maximum value of range.)

## Conversion Time and Resolution Setting

|    |    |    |    |
|----|----|----|----|
| 15 | 12 | 11 | 08 |
|    |    |    |    |

00: Conversion time = 1 ms, resolution = 4,000  
C1: Conversion time = 250 μs, resolution = 8,000

## Operation Mode

|    |    |    |    |
|----|----|----|----|
| 07 | 04 | 03 | 00 |
|    |    |    |    |

00: Normal mode  
C1: Adjustment mode

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CS1W-MAD44

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□01  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□03  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□04  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□05  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□07  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□08  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□09  | 0                |    |    |    | 0  |    |    |    |    | 0  |    |    |    |    |    |    |
| D2□□10  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□11  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□12  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□13  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□14  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□15  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□16  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□17  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM word                                         | Setting contents                        |   |                                                 |                        |
|-------------------------------------------------|-----------------------------------------|---|-------------------------------------------------|------------------------|
|                                                 | 15                                      | 8 | 7                                               | 0                      |
| m                                               | Ratio conversion use designation        |   | Input use designation                           | Output use designation |
| m+1                                             | Input signal range setting              |   | Output signal range setting                     |                        |
| m+2                                             |                                         |   | Output 1: Output status when conversion stopped |                        |
| Output 2: Output status when conversion stopped |                                         |   |                                                 |                        |
| Output 3: Output status when conversion stopped |                                         |   |                                                 |                        |
| Output 4: Output status when conversion stopped |                                         |   |                                                 |                        |
| m+6                                             | Input 1: Mean value processing setting  |   |                                                 |                        |
| m+7                                             | Input 2: Mean value processing setting  |   |                                                 |                        |
| m+8                                             | Input 3: Mean value processing setting  |   |                                                 |                        |
| m+9                                             | Input 4: Mean value processing setting  |   |                                                 |                        |
| m+10                                            | Loop 1 (input 1 → output 1), A constant |   |                                                 |                        |
| m+11                                            | Loop 1 (input 1 → output 1), B constant |   |                                                 |                        |
| m+12                                            | Loop 2 (input 2 → output 2), A constant |   |                                                 |                        |
| m+13                                            | Loop 2 (input 2 → output 2), B constant |   |                                                 |                        |
| m+14                                            | Loop 3 (input 3 → output 3), A constant |   |                                                 |                        |
| m+15                                            | Loop 3 (input 3 → output 3), B constant |   |                                                 |                        |
| m+16                                            | Loop 4 (input 4 → output 4), A constant |   |                                                 |                        |
| m+17                                            | Loop 4 (input 4 → output 4), B constant |   |                                                 |                        |

**A Constant**

0 to 9999 BCD (0.00 to 99.99; unit: 0.01)

**B Constant**

16-bit binary data

**Use Designation**

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|    |    |    |    |    |    |    |    |

0: Do not use.  
1: Use

|         |         |         |         |          |          |          |          |
|---------|---------|---------|---------|----------|----------|----------|----------|
| Input 4 | Input 3 | Input 2 | Input 1 | Output 4 | Output 3 | Output 2 | Output 1 |
|---------|---------|---------|---------|----------|----------|----------|----------|

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 15 | 14 | 13 | 12 | 11 | 10 | 09 | 08 |
|    |    |    |    |    |    |    |    |

Loop 4      Loop 3      Loop 2      Loop 1

00: Do not use.  
01: Positive gradient conversion  
10: Negative gradient conversion  
11: Same as the above "00" setting**Signal Range Setting**

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
|    |    |    |    |    |    |    |    |

|          |          |          |          |
|----------|----------|----------|----------|
| Output 4 | Output 3 | Output 2 | Output 1 |
|----------|----------|----------|----------|

|    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|
| 15 | 14 | 13 | 12 | 11 | 10 | 09 | 08 |
|    |    |    |    |    |    |    |    |

Input 4      Input 3      Input 2      Input 1

00: -10 to 10 V  
01: 0 to 10 V  
10: 1 to 5 V / 4 to 20 mA (4 to 20 mA is for analog input only)  
11: 0 to 5 V**Output Status when Conversion Stopped**

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

00: CLR (0 or minimum value for each range output)  
01: HOLD (Hold prior output value.)  
02: MAX (Output maximum value of range.)**Mean Value Processing Setting**

|                 |    |                 |    |                 |    |                 |    |
|-----------------|----|-----------------|----|-----------------|----|-----------------|----|
| 15              | 12 | 11              | 08 | 07              | 04 | 03              | 00 |
| 16 <sup>3</sup> |    | 16 <sup>2</sup> |    | 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |


0000: Mean value processing with 2 buffers.  
0001: No mean value processing  
0002: Mean value processing with 4 buffers.  
0003: Mean value processing with 8 buffers.  
0004: Mean value processing with 16 buffers.  
0005: Mean value processing with 32 buffers.  
0006: Mean value processing with 64 buffers.**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CJ1W-MAD42


| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  |                  |    |    |    |    |    |    |    |    |    |    |    | 0  | 0  |    |    |
| D2□□01  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□03  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□06  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□07  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□08  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□09  |                  | 0  |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |
| D2□□10  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□11  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□12  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□13  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□18  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□19  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□20  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□21  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□22  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□27  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□28  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□29  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□30  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□31  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□32  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□33  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□34  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□35  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□35  |                  | 0  |    |    |    | 0  |    |    |    |    |    |    | 0  | 0  |    |    |




| DM word      | Setting contents                                                     |   |                                                 |                        |
|--------------|----------------------------------------------------------------------|---|-------------------------------------------------|------------------------|
|              | 15                                                                   | 8 | 7                                               | 0                      |
| m            | Ratio conversion use designation                                     |   | Input use designation                           | Output use designation |
| m+1          | Input signal range setting                                           |   | Output signal range setting                     |                        |
| m+2          | ---                                                                  |   | Output 1: Output status when conversion stopped |                        |
| m+3          | ---                                                                  |   | Output 2: Output status when conversion stopped |                        |
| m+4          | ---                                                                  |   |                                                 |                        |
| m+5          | ---                                                                  |   |                                                 |                        |
| m+6          | Input 1: Mean value processing setting                               |   |                                                 |                        |
| m+7          | Input 2: Mean value processing setting                               |   |                                                 |                        |
| m+8          | Input 3: Mean value processing setting                               |   |                                                 |                        |
| m+9          | Input 4: Mean value processing setting                               |   |                                                 |                        |
| m+10         | Loop 1 (input 1 → output 1), A constant                              |   |                                                 |                        |
| m+11         | Loop 1 (input 1 → output 1), B constant                              |   |                                                 |                        |
| m+12         | Loop 2 (input 1 → output 1), A constant                              |   |                                                 |                        |
| m+13         | Loop 2 (input 1 → output 1), B constant                              |   |                                                 |                        |
| m+14 to m+17 | ---                                                                  |   |                                                 |                        |
| m+18         | Conversion time/ resolution setting                                  |   | Operation mode setting                          |                        |
| m+19         | Output 1 scaling lower limit                                         |   |                                                 |                        |
| m+20         | Output 1 scaling upper limit                                         |   |                                                 |                        |
| m+21         | Output 2 scaling lower limit                                         |   |                                                 |                        |
| m+22         | Output 2 scaling upper limit                                         |   |                                                 |                        |
| m+23 to m+26 | ---                                                                  |   |                                                 |                        |
| m+27         | Input 1 scaling lower limit                                          |   |                                                 |                        |
| m+28         | Input 1 scaling upper limit                                          |   |                                                 |                        |
| m+29         | Input 2 scaling lower limit                                          |   |                                                 |                        |
| m+30         | Input 2 scaling upper limit                                          |   |                                                 |                        |
| m+31         | Input 3 scaling lower limit                                          |   |                                                 |                        |
| m+32         | Input 3 scaling upper limit                                          |   |                                                 |                        |
| m+33         | Input 4 scaling lower limit                                          |   |                                                 |                        |
| m+34         | Input 4 scaling upper limit                                          |   |                                                 |                        |
| m+35         | Voltage/current range setting<br>(Valid for 1 to 5 V or 4 to 20 mA.) |   |                                                 |                        |
|              | ---                                                                  |   | Input                                           | Output                 |

**Conversion Time and Resolution Setting**

00: Conversion time = 1 ms, resolution = 4,000  
 C1: Conversion time = 500 μs, resolution = 8,000


**Operation Mode**

00: Normal mode  
 C1: Adjustment mode

**Use Designation**

0: Do not use.

1: Use





00: Do not use.

01: Positive gradient conversion

10: Negative gradient conversion

11: Same as the above "00" setting


**Signal Range Setting**

00: -10 to 10 V

01: 0 to 10 V

10: 1 to 5 V/4 to 20 mA


11: 0 to 5 V

**Output Status when Conversion Stopped**

00: CLR (0 or minimum value for each range output)

01: HOLD (Hold prior output value.)

02: MAX (Output maximum value of range.)

**Mean Value Processing Setting**

0000: Mean value processing with 2 buffers.

0001: No mean value processing

0002: Mean value processing with 4 buffers.

0003: Mean value processing with 8 buffers.


0004: Mean value processing with 16 buffers.

0005: Mean value processing with 32 buffers.

0006: Mean value processing with 64 buffers.

**Voltage/Current Specifications  
(when 1 to 5 V/4 to 20 mA is selected)**

This setting is valid for inputs and/or outputs only if "10" (1 to 5 V/4 to 20 mA) was specified in m+1.



0: Voltage (1 to 5 V)

1: Current (4 to 20 mA)

**Note** m = 20000 + unit number x 100 is allocated as the DM number.

## CJ1W-AD042

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□01  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□03  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□04  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□05  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□07  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□08  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□09  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□10  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□11  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□12  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□13  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□14  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□15  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□16  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□17  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM Area<br>word (See note.) | Settings                                 |                         |     |                          |
|-----------------------------|------------------------------------------|-------------------------|-----|--------------------------|
|                             | 15                                       | 08                      | 07  | 00                       |
| m                           | ---                                      |                         | --- | Number of<br>inputs used |
| m+1                         | ---                                      | Conversion mode setting |     |                          |
| m+2                         | ---                                      | Input 1 signal range    |     |                          |
| m+3                         | Number of mean value buffers for input 1 |                         |     |                          |
| m+4                         | Input 1 scaling lower limit              |                         |     |                          |
| m+5                         | Input 1 scaling upper limit              |                         |     |                          |
| m+6                         | ---                                      | Input 2 signal range    |     |                          |
| m+7                         | Number of mean value buffers for input 2 |                         |     |                          |
| m+8                         | Input 2 scaling lower limit              |                         |     |                          |
| m+9                         | Input 2 scaling upper limit              |                         |     |                          |
| m+10                        | ---                                      | Input 3 signal range    |     |                          |
| m+11                        | Number of mean value buffers for input 3 |                         |     |                          |
| m+12                        | Input 3 scaling lower limit              |                         |     |                          |
| m+13                        | Input 3 scaling upper limit              |                         |     |                          |
| m+14                        | ---                                      | Input 4 signal range    |     |                          |
| m+15                        | Number of mean value buffers for input 4 |                         |     |                          |
| m+16                        | Input 4 scaling lower limit              |                         |     |                          |
| m+17                        | Input 4 scaling upper limit              |                         |     |                          |

**Note:** For the DM word addresses, m = D20000 + (unit number x 100)

#### Number of Analog Inputs Used

|                 |    |
|-----------------|----|
| 03              | 00 |
| 16 <sup>0</sup> |    |

0: No inputs used.  
1: One input used  
2: Two inputs used  
3: Three inputs used  
4: Four inputs used

#### Conversion Mode Setting

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

00 hex: Cyclic Conversion Mode  
A5 hex: Direct Conversion Mode

#### Input Signal Range Setting

|                 |    |                 |    |
|-----------------|----|-----------------|----|
| 07              | 04 | 03              | 00 |
| 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

0: -10 to 10 V  
2: 0 to 10 V  
3: 4 to 20 mA  
6: -5 to 5 V  
7: 1 to 5 V

#### Numbers of Mean Value Buffers

|                 |    |                 |    |                 |    |                 |    |
|-----------------|----|-----------------|----|-----------------|----|-----------------|----|
| 15              | 12 | 11              | 08 | 07              | 04 | 03              | 00 |
| 16 <sup>3</sup> |    | 16 <sup>2</sup> |    | 16 <sup>1</sup> |    | 16 <sup>0</sup> |    |

0: Mean value processing not used.  
1: Mean value processing with 2 buffers  
2: Mean value processing with 4 buffers  
3: Mean value processing with 8 buffers  
4: Mean value processing with 16 buffers  
5: Mean value processing with 32 buffers  
6: Mean value processing with 64 buffers  
7: Mean value processing with 128 buffers  
8: Mean value processing with 256 buffers  
9: Mean value processing with 512 buffers

**CJ1W-DA042V**

| DM word | Setting contents |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|---------|------------------|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
|         | 15               | 14 | 13 | 12 | 11 | 10 | 09 | 08 | 07 | 06 | 05 | 04 | 03 | 02 | 01 | 00 |
| D2□□00  | 0                |    |    |    | 0  |    |    |    | 0  |    |    |    |    |    |    |    |
| D2□□01  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□02  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□03  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□04  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□05  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□06  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□07  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□08  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□09  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□10  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□11  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□12  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□13  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□14  | 0                |    |    |    | 0  |    |    |    |    |    |    |    |    |    |    |    |
| D2□□15  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□16  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
| D2□□17  |                  |    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |

| DM Area<br>word (See note.) | Settings                                     |    |                                         |                           |
|-----------------------------|----------------------------------------------|----|-----------------------------------------|---------------------------|
|                             | 15                                           | 08 | 07                                      | 00                        |
| m                           | ---                                          |    | ---                                     | Number of<br>outputs used |
| m+1                         | ---                                          |    | Conversion mode setting                 |                           |
| m+2                         | ---                                          |    | Output 1 output signal<br>range setting |                           |
| m+3                         | Output 1 output status when conversion stops |    |                                         |                           |
| m+4                         | Output 1 scaling lower limit                 |    |                                         |                           |
| m+5                         | Output 1 scaling upper limit                 |    |                                         |                           |
| m+6                         | ---                                          |    | Output 2 output signal<br>range setting |                           |
| m+7                         | Output 2 output status when conversion stops |    |                                         |                           |
| m+8                         | Output 2 scaling lower limit                 |    |                                         |                           |
| m+9                         | Output 2 scaling upper limit                 |    |                                         |                           |
| m+10                        | ---                                          |    | Output 3 output signal<br>range setting |                           |
| m+11                        | Output 3 output status when conversion stops |    |                                         |                           |
| m+12                        | Output 3 scaling lower limit                 |    |                                         |                           |
| m+13                        | Output 3 scaling upper limit                 |    |                                         |                           |
| m+14                        | ---                                          |    | Output 4 output signal<br>range setting |                           |
| m+15                        | Output 4 output status when conversion stops |    |                                         |                           |
| m+16                        | Output 4 scaling lower limit                 |    |                                         |                           |
| m+17                        | Output 4 scaling upper limit                 |    |                                         |                           |

**Note:** For the DM word addresses, m = D20000 + (unit number x 100)

#### Number of Analog Outputs Used

03 00  
 $16^0$

0: No outputs used.  
1: One output used  
2: Two outputs used  
3: Three outputs used  
4: Four outputs used

#### Conversion Mode Setting

07 04 03 00  
 $16^1$   $16^0$

00 hex: Cyclic Conversion Mode  
A5 hex: Direct Conversion Mode

#### Output Signal Range Setting

07 04 03 00  
 $16^1$   $16^0$

1: 0 to 10 V  
3: -10 to 10 V  
6: 1 to 5 V

#### Output Status when Conversion Stops

15 12 11 08 07 04 03 00  
 $16^3$   $16^2$   $16^1$   $16^0$

0: CLR (Outputs 0 or minimum value of output range)  
1: HOLD (Holds output value prior to stop.)  
2: MAX (Outputs maximum value of output range)



## Appendix D

### Execution Times for Special Instructions for the CJ1W-AD042/-DA042V

Execution times for the ANALOG INPUT DIRECT CONVERSION (AIDC) instruction and ANALOG OUTPUT DIRECT CONVERSION (AODC) instruction are provided below.

| Instruction                                              | Mnemonic | Function No. | Execution time (μs) | Conditions                                              |
|----------------------------------------------------------|----------|--------------|---------------------|---------------------------------------------------------|
|                                                          |          |              | CJ2H-CPU6□(-EIP)    |                                                         |
| ANALOG INPUT DIRECT CONVERSION<br>(for the CJ1W-AD042)   | AIDC     | 216          | 26.0                | Analog input 1, number of analog inputs used set to 4   |
|                                                          |          |              | 27.7                | Analog input 2, number of analog inputs used set to 4   |
|                                                          |          |              | 34.6                | Analog input 3, number of analog inputs used set to 4   |
|                                                          |          |              | 35.9                | Analog input 4, number of analog inputs used set to 4   |
|                                                          |          |              | 29.8                | Analog input 0, number of analog inputs used set to 1   |
|                                                          |          |              | 32.7                | Analog input 0, number of analog inputs used set to 2   |
|                                                          |          |              | 39.4                | Analog input 0, number of analog inputs used set to 3   |
|                                                          |          |              | 41.6                | Analog input 0, number of analog inputs used set to 4   |
| ANALOG OUTPUT DIRECT CONVERSION<br>(for the CJ1W-DA042V) | AODC     | 217          | 24.6                | Analog output 1, number of analog outputs used set to 4 |
|                                                          |          |              | 24.6                | Analog output 2, number of analog outputs used set to 4 |
|                                                          |          |              | 24.6                | Analog output 3, number of analog outputs used set to 4 |
|                                                          |          |              | 24.6                | Analog output 4, number of analog outputs used set to 4 |
|                                                          |          |              | 28.4                | Analog output 0, number of analog outputs used set to 1 |
|                                                          |          |              | 34.5                | Analog output 0, number of analog outputs used set to 2 |
|                                                          |          |              | 39.1                | Analog output 0, number of analog outputs used set to 3 |
|                                                          |          |              | 45.8                | Analog output 0, number of analog outputs used set to 4 |





# Index

## A–B

- A constant
  - Analog I/O Unit, 328, 344, 396, 417
- A/D conversion time
  - Analog I/O Unit, 303, 370
- adjustment mode
  - allocations
    - Analog I/O Unit, 331, 399
    - Analog Input Unit, 54, 107
    - Analog Output Unit, 196, 243
  - operational flow
    - Analog I/O Unit, 346, 419
    - Analog Input Unit, 64, 116
    - Analog Output Unit, 201, 252
- Alarm Flags
  - Analog I/O Unit, 330, 332, 363, 398, 399, 436
  - Analog Input Unit, 53, 55, 107, 108, 156
  - Analog Output Unit, 196, 197, 213, 243, 244, 265, 288
- alarms
  - Analog I/O Unit, 361, 434
  - Analog Input Unit, 73, 124, 166
  - Analog Output Unit, 211, 263, 296
  - upper and lower limit, 446
- B constant
  - Analog I/O Unit, 328, 344, 396, 417
- bias
  - Analog I/O Unit, 344, 417

## C

- circuitry
  - input
    - Analog I/O Unit, 321, 387
    - Analog Input Unit, 37, 98, 145
  - internal
    - Analog I/O Unit, 321, 387
    - Analog Input Unit, 37, 98, 145
    - Analog Output Unit, 188, 234, 280
  - output
    - Analog I/O Unit, 321, 387
    - Analog Output Unit, 188, 234, 280
- Clear Bit
  - Analog I/O Unit, 331, 347, 353, 399, 420, 426
  - Analog Input Unit, 55, 67, 108, 118
  - Analog Output Unit, 197, 203, 244, 255
- components
  - Analog I/O Unit, 317, 384
  - Analog Input Unit, 31, 93, 142

- Analog Output Unit, 184, 230
- configuration
  - internal
    - Analog I/O Unit, 321, 388
    - Analog Input Unit, 38, 98, 145
    - Analog Output Unit, 188, 234, 281
- conversion
  - signed binary to signed BCD, 450
  - stopping and starting
    - Analog I/O Unit, 340, 411
    - Analog Output Unit, 199, 247, 290
  - time
    - Analog I/O Unit, 303, 370
  - values
    - Analog I/O Unit, 332, 339, 400, 409
    - Analog Input Unit, 56, 108, 157
    - Analog Output Unit, 197, 245, 289
- Conversion Enable Bit
  - Analog I/O Unit, 340, 411
  - Analog Output Unit, 199, 247, 290
- conversion time
  - Analog Input Units
    - setting, 29, 47, 48, 58, 91, 104, 110, 227, 247, 402, 411
- cyclic conversion
  - Analog Input Unit, 158
  - Analog Output Unit, 291

## D

- D/A conversion time
  - Analog I/O Unit, 303
- data exchange
  - Analog I/O Unit, 302, 324, 370, 391
  - Analog Input Unit, 18, 42, 82, 101, 132, 149
  - Analog Output Unit, 174, 175, 190, 218, 236, 270, 283
- data memory coding sheets, 455
- dimensions, 441
  - Analog I/O Unit, 302, 370
  - Analog Input Unit, 82, 132
  - Analog Output Unit, 174, 218, 270
- direct conversion, 7
  - Analog Input Unit, 158
  - Analog Output Unit, 291
- disconnection
  - voltage input
    - Analog I/O Unit, 322, 389
    - Analog Input Unit, 38, 99, 146
- Disconnection Detection Flag, 445

- Analog I/O Unit, 315, 382
- Analog Input Unit, 30, 92, 141
- DM allocations
  - contents
    - Analog I/O Unit, 327, 395
    - Analog Input Unit, 47, 104, 152
    - Analog Output Unit, 193, 238, 285
- Down Bit
  - Analog I/O Unit, 331, 353, 399, 426
  - Analog Input Unit, 55, 108
  - Analog Output Unit, 197, 203, 244, 255

## E

- EC Directives, xxi
- errors
  - Analog I/O Unit, 361, 434
  - Analog Input Unit, 73, 124, 166
  - Analog Output Unit, 211, 263, 296
  - CPU Unit, 77, 128, 169, 214, 267, 299, 365, 438
  - UNIT No. DPL ERR
    - Analog I/O Unit, 326, 394
    - Analog Input Unit, 46, 103
    - Analog Output Unit, 192, 238
- external terminals
  - Analog I/O Unit, 302, 370
  - Analog Input Unit, 82, 132
  - Analog Output Unit, 174, 218, 270

## F

- fixed data
  - allocations
    - Analog I/O Unit, 326, 394
    - Analog Input Unit, 45, 103
    - Analog Output Unit, 192, 238
  - Analog I/O Unit, 324, 391
  - Analog Input Unit, 42, 101
  - Analog Output Unit, 190, 236
  - set values
    - Analog I/O Unit, 328, 396
    - Analog Input Unit, 49, 105
    - Analog Output Unit, 193, 240
  - stored values
    - Analog I/O Unit, 328, 396
    - Analog Input Unit, 49, 105
    - Analog Output Unit, 193, 240
- functions, 2
  - applications, 16
  - input

- Analog I/O Unit, 303
- other
  - Analog I/O Unit, 303
- output
  - Analog I/O Unit, 303

## G–H

- gain adjustment function, 6
  - Analog I/O Unit, 345, 350, 356, 418, 423, 429
  - Analog Input Unit, 64, 70, 116, 121
  - Analog Output Unit, 201, 207, 252, 259
  - applications, 16
  - clearing adjusted values
    - Analog I/O Unit, 352, 359, 425, 432
    - Analog Input Unit, 72, 123
    - Analog Output Unit, 210, 262
  - setting procedure
    - Analog I/O Unit, 310, 377
    - Analog Input Unit, 24, 87
    - Analog Output Unit, 179, 223, 224
- Gain Bit
  - Analog I/O Unit, 331, 347, 353, 399, 420, 426
  - Analog Input Unit, 55, 67, 108, 118
  - Analog Output Unit, 197, 203, 244, 255
- gradient conversion
  - negative
    - Analog I/O Unit, 343, 416
  - positive
    - Analog I/O Unit, 343, 416
- history buffers
  - Analog I/O Unit, 334, 402
  - Analog Input Unit, 59, 111, 160

## I–L

- I/O refresh data
  - allocations
    - Analog I/O Unit, 329, 397
    - Analog Input Unit, 50, 105, 154
    - Analog Output Unit, 194, 241, 287
  - Analog I/O Unit, 324, 391
  - Analog Input Unit, 42, 101, 149
  - Analog Output Unit, 190, 236, 283
  - set values
    - Analog I/O Unit, 330, 398
    - Analog Input Unit, 53, 107, 156
    - Analog Output Unit, 196, 243, 288
  - stored values
    - Analog I/O Unit, 330, 398

- Analog Input Unit, 53, 107, 156
- Analog Output Unit, 196, 243, 288
- I/O tables
  - creation
    - Analog I/O Unit, 313, 379
    - Analog Input Unit, 27, 89, 138
    - Analog Output Unit, 181, 226, 275
- indicators
  - Analog I/O Unit, 318, 385
  - Analog Input Unit, 32, 94, 143
  - Analog Output Unit, 185, 231, 279
- errors
  - Analog I/O Unit, 361, 434
  - Analog Input Unit, 73, 124, 166
  - Analog Output Unit, 211, 263, 296
- initial data
  - settings
    - Analog I/O Unit, 313, 379
    - Analog Input Unit, 28, 90, 139
    - Analog Output Unit, 181, 226, 276
- input
  - circuitry
    - Analog I/O Unit, 321, 387
    - Analog Input Unit, 37, 98, 145
  - impedance
    - Analog I/O Unit, 303, 370
    - Analog Input Unit, 18, 82, 132
  - numbers
    - Analog I/O Unit, 332, 347, 400, 420
    - Analog Input Unit, 56, 66, 108, 118
  - settings
    - Analog I/O Unit, 332, 400
    - Analog Input Unit, 56, 108, 157
  - signal range, 2, 3
    - Analog I/O Unit, 303, 328, 333, 370, 371, 396, 400
    - Analog Input Unit, 18, 49, 56, 82, 105, 109, 132, 153, 157
  - specifications
    - Analog I/O Unit, 303, 305, 373
    - Analog Input Unit, 21, 84, 134
  - input disconnection detection function, 5
    - Analog I/O Unit, 338, 408
    - Analog Input Unit, 63, 115, 165
    - applications, 16
  - input functions
    - block diagram
      - Analog I/O Unit, 305, 372
      - Analog Input Unit, 21, 84, 134
  - installation
    - procedure
      - Analog I/O Unit, 310, 377

- Analog Input Unit, 24, 87, 137
- Analog Output Unit, 178, 222, 274
- isolation
  - Analog I/O Unit, 302, 370
  - Analog Input Unit, 18, 82, 132
  - Analog Output Unit, 174, 218, 270
- ladder programs
  - Analog I/O Unit, 314, 381
  - Analog Input Unit, 29, 91, 140
  - Analog Output Unit, 182, 228, 277
- limit, 453
- loops
  - Analog I/O Unit, 344, 417

## M–N

- maximum Units
  - per Rack
    - Analog I/O Unit, 302, 370
    - Analog Input Unit, 18, 82, 132
    - Analog Output Unit, 174, 218, 270
  - per system
    - Analog I/O Unit, 302
- mean value function, 6
  - applications, 16
  - settings
    - Analog I/O Unit, 328, 396
    - Analog Input Unit, 49, 105, 153
- mean value processing, 452
  - Analog I/O Unit, 334, 402
  - Analog Input Unit, 59, 111, 160
- mounting
  - position
    - Analog I/O Unit, 302, 370
    - Analog Input Unit, 18, 82, 132
    - Analog Output Unit, 174, 218, 270
  - precautions
    - Analog I/O Unit, 346, 419
    - Analog Input Unit, 65, 117
    - Analog Output Unit, 202, 253, 254
  - restrictions, 12
- normal mode
  - allocations
    - Analog I/O Unit, 330, 398
    - Analog Output Unit, 195, 241
- number of analog inputs used, 157
- number of analog outputs used, 289

## O

offset adjustment function, 6

- Analog I/O Unit, 345, 348, 353, 418, 421, 426
- Analog Input Unit, 64, 67, 116, 119
- Analog Output Unit, 201, 204, 252, 256
- applications, 16
- clearing adjusted values
  - Analog I/O Unit, 352, 359, 425, 432
  - Analog Input Unit, 72, 123
  - Analog Output Unit, 210, 262
- setting procedure
  - Analog I/O Unit, 310, 377
  - Analog Input Unit, 24, 87
  - Analog Output Unit, 179, 223, 224

Offset Bit

- Analog I/O Unit, 331, 347, 353, 399, 420, 426
- Analog Input Unit, 55, 67, 108, 118
- Analog Output Unit, 197, 203, 244, 255

operating procedure

- Analog I/O Unit, 310, 377
- Analog Input Unit, 24, 87, 137
- Analog Output Unit, 179, 223, 224

operation mode switch

- Analog I/O Unit, 319
- Analog Input Unit, 34, 95
- Analog Output Unit, 186, 232

output

- circuitry
  - Analog I/O Unit, 321, 387
  - Analog Output Unit, 188, 234, 280
- current
  - Analog I/O Unit, 303, 371
  - Analog Output Unit, 174, 218
- data
  - Analog I/O Unit, 303, 370, 371
  - Analog Input Unit, 82
- impedance
  - Analog I/O Unit, 303, 371
  - Analog Output Unit, 174, 218, 270
- numbers
  - Analog I/O Unit, 339, 353, 409, 426
  - Analog Output Unit, 197, 203, 245, 255
- setting errors
  - Analog I/O Unit, 342, 415
  - Analog Output Unit, 201, 251, 295
- settings
  - Analog I/O Unit, 339, 409
  - Analog Output Unit, 197, 245, 289
- signal range, 2, 3
  - Analog I/O Unit, 303, 328, 339, 341, 396, 410, 412

- Analog Output Unit, 174, 193, 198, 200, 218, 240, 245, 248, 270, 286, 289

specifications

- Analog I/O Unit, 303, 307, 375

- Analog Output Unit, 176, 220

status, 193, 240

- Analog I/O Unit, 328, 341, 396, 412

- Analog Output Unit, 200, 248

output functions

- block diagram

- Analog I/O Unit, 305, 372

- Analog Output Unit, 176, 220, 271

output hold function, 5

- Analog I/O Unit, 341, 412

- Analog Output Unit, 200, 248, 292

- applications, 16

## P

Peak Value Hold Bit

- Analog I/O Unit, 337, 406

- Analog Input Unit, 63, 114

peak value hold function, 5

- Analog I/O Unit, 337, 405

- Analog Input Unit, 62, 114, 164

- applications, 16

power consumption

- Analog I/O Unit, 302, 370

- Analog Input Unit, 18, 82, 132

- Analog Output Unit, 174, 218, 270

Power Supply Units, 12, 13, 19, 83

precautions, 15

- application, xx

- general, xviii

- mounting

- Analog I/O Unit, 346, 419

- Analog Input Unit, 65, 117

- Analog Output Unit, 202, 253, 254

- operating environment, xix

- safety, xviii

Programming Console

- errors

- Analog I/O Unit, 326, 329, 394, 397

- Analog Input Unit, 46, 51, 103, 106

- Analog Output Unit, 192, 194, 238, 241

Programming Devices

- Analog I/O Unit, 332, 400

- Analog Input Unit, 56, 108

- Analog Output Unit, 197, 245

## R

### rated input

- Analog I/O Unit, 303, 370
- Analog Input Unit, 18, 82, 132

### ratio conversion function

- Analog I/O Unit, 342, 415
- applications, 16

### ratio set value

- Analog I/O Unit, 344, 417

### resolution

- Analog Input Units
  - setting, 29, 47, 48, 58, 91, 104, 110, 227, 247, 402, 411

### input

- Analog I/O Unit, 303, 370, 371
- Analog Input Unit, 18, 82, 132

### output

- Analog I/O Unit, 303
- Analog Output Unit, 174, 218, 270

## S–T

### safety precautions, xviii

### scaling, 448

### Set Bit

- Analog I/O Unit, 331, 347, 353, 399, 420, 426
- Analog Input Unit, 55, 67, 108, 118
- Analog Output Unit, 197, 203, 244, 255

### set data

- Analog I/O Unit, 303
- Analog Output Unit, 174, 218, 270

### settings

- procedure
  - Analog I/O Unit, 310, 377
  - Analog Input Unit, 24, 87, 137
  - Analog Output Unit, 178, 222

### Special I/O Unit Area

- Analog I/O Unit, 302, 370
- Analog Input Unit, 132
- Analog Output Unit, 174, 175, 218, 270

### Special I/O Unit DM Area

- Analog I/O Unit, 302, 326, 370, 394
- Analog Input Unit, 45, 103, 132, 151
- Analog Output Unit, 174, 175, 192, 218, 238, 270, 285

### Special I/O Unit Restart Bits

- Analog I/O Unit, 325, 334, 366, 393, 403, 439
- Analog Input Unit, 44, 60, 78, 102, 129, 150, 170
- Analog Output Unit, 191, 215, 237, 268, 284, 300

### specifications

Analog I/O Unit, 302, 371

Analog Input Unit, 18, 82, 132

Analog Output Unit, 174, 218, 270

### general

- Analog I/O Unit, 302, 370
- Analog Input Unit, 18, 82, 132
- Analog Output Unit, 174, 218, 270

### input

- Analog I/O Unit, 303, 305, 373
- Analog Input Unit, 21, 84, 134

### output

- Analog I/O Unit, 303, 307, 375
- Analog Output Unit, 176, 220

square root calculation, 451

### switch settings

- Analog I/O Unit, 317, 384
- Analog Input Unit, 31, 93, 142
- Analog Output Unit, 184, 230, 278

system configuration, 11

### terminal arrangement

- Analog I/O Unit, 320, 387
- Analog Input Unit, 36, 97, 144
- Analog Output Unit, 187, 232, 280

## U

### UNIT No. DPL ERR

- Analog I/O Unit, 326, 329, 394, 397
- Analog Input Unit, 46, 51, 103, 106
- Analog Output Unit, 192, 194, 238, 241

### unit number

#### settings

- Analog I/O Unit, 325, 392
- Analog Input Unit, 43, 102, 150
- Analog Output Unit, 191, 237, 284

### unit number switches

- Analog I/O Unit, 319, 385
- Analog Input Unit, 33, 94, 143
- Analog Output Unit, 186, 231, 279

### Up Bit

- Analog I/O Unit, 331, 353, 399, 426
- Analog Input Unit, 55, 108
- Analog Output Unit, 197, 203, 244, 255

## V

### voltage input disconnection

- Analog I/O Unit, 322, 389
- Analog Input Unit, 38, 99, 146

voltage/current switch

Analog I/O Unit, 320, 386

Analog Input Unit, 35, 96

## **W**

weight

Analog I/O Unit, 302, 370

Analog Input Unit, 18, 82, 132

Analog Output Unit, 174, 218, 270

wiring

Analog I/O Unit, 320, 387

Analog Input Unit, 36, 97, 144

Analog Output Unit, 187, 232, 280

considerations

Analog I/O Unit, 324, 391

Analog Input Unit, 42, 100, 148

Analog Output Unit, 190, 235, 282

examples

Analog I/O Unit, 323, 390

Analog Input Unit, 39, 100, 146

Analog Output Unit, 189, 235, 281

## Revision History

A manual revision code appears as a suffix to the catalog number on the front cover of the manual.

Cat. No. W345-E1-12



The following table outlines the changes made to the manual during each revision. Page numbers refer to the previous version.

| Revision code | Date           | Revised content                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |
|---------------|----------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 01            | March 1999     | Original production                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |
| 02            | August 1999    | Revised to include information on CS1W-AD041/081, CS1W-DA041/08V/08C.                                                                                                                                                                                                                                                                                                                                                                                                                              |
| 03            | May 2001       | Revised to add CJ1W-AD081 and CJ1W-DA041 Analog I/O Units and one new section added on each. "CS1" changed to "CS (-series)" or "CS/CJ (-series)" accordingly.<br>Other changes are as follows:<br><b>Page xiv:</b> Precautions added.<br><b>Pages 11 and 57:</b> Note added.                                                                                                                                                                                                                      |
| 04            | November 2001  | Revised to include information on CS1W-AD041-V1, CS1W-AD081-V1, CJ1W-AD041-V1, CJ1W-AD081-V1, CJ1W-DA021.                                                                                                                                                                                                                                                                                                                                                                                          |
| 05            | November 2002  | Revised to include information on CJ1W-DA08V and CJ1W-MAD42.<br>Changes include changes and additions to the following items.<br>Conversion time/resolution settings and operation mode settings<br>Voltage and current range settings<br>Scaling function<br>Offset and gain adjustment                                                                                                                                                                                                           |
| 06            | July 2003      | Revised to include information on the CJ1W-DA08C, including the following changes.<br><b>Page 8:</b> "CS1W-DA8C" corrected to "CS1W-DA08C" in table heading.<br><b>Pages 104, 253, and 324:</b> Note corrected at the bottom of each page regarding the ON/OFF status of the Offset Bit and Gain Bit and the conversion data.<br><b>Pages 53, 55, 102, 255, and 326:</b> Note added at the bottom of each page regarding the ON/OFF status of the Offset Bit and Gain Bit and the conversion data. |
| 07            | December 2004  | Revised to include information on the CS1W-AD161, and remove certain information on the CS1W-AD041, CS1W-AD081, and CJ1W-AD081.                                                                                                                                                                                                                                                                                                                                                                    |
| 08            | July 2005      | <b>Page xii:</b> Information on liability and warranty added.<br><b>Pages xvii and xviii:</b> Common Emission Standard EN50081-2 changed to EN61000-6-4.                                                                                                                                                                                                                                                                                                                                           |
| 09            | September 2006 | <b>Page xxi:</b> Information on EC Directives replaced.<br><b>Page 34:</b> Wiring diagram corrected.<br><b>Page 38:</b> Note added at bottom of page.<br><b>Pages 49 and 195:</b> Left column removed from bottom table.<br><b>Pages 70, 120, 163, 215, 281, and 352:</b> Flowchart expanded.<br><b>Page 103:</b> Left column removed from top table.<br><b>Page 145:</b> Information added to note 1.<br><b>Page 148:</b> Value of bits 4 to 7 of word n corrected.                               |
| 10            | March 2008     | <b>Page xi:</b> Updated related manual table.<br><b>Page xviii:</b> Added warning to the general precautions.<br><b>Page 96:</b> Corrected wiring diagram and added asterisks.                                                                                                                                                                                                                                                                                                                     |
| 11            | August 2009    | Added CJ1W-AD042 Analog Input Unit and CJ1W-DA042V Analog Output Unit                                                                                                                                                                                                                                                                                                                                                                                                                              |

| Revision code | Date         | Revised content                                                                                                                                                                                         |
|---------------|--------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 12            | October 2010 | Added information on operating mode switch, changed figures, added setting procedures for scheduled interrupt tasks, and added basic procedures for analog-to-digital and digital-to-analog conversion. |





**OMRON Corporation**    **Industrial Automation Company**  
Tokyo, JAPAN

**Contact:** [www.ia.omron.com](http://www.ia.omron.com)

**Regional Headquarters**

**OMRON EUROPE B.V.**

Wegalaan 67-69-2132 JD Hoofddorp  
The Netherlands  
Tel: (31)2356-81-300/Fax: (31)2356-81-388

**OMRON ASIA PACIFIC PTE. LTD.**

No. 438A Alexandra Road # 05-05/08 (Lobby 2),  
Alexandra Technopark,  
Singapore 119967  
Tel: (65) 6835-3011/Fax: (65) 6835-2711

**OMRON ELECTRONICS LLC**

One Commerce Drive Schaumburg,  
IL 60173-5302 U.S.A.  
Tel: (1) 847-843-7900/Fax: (1) 847-843-7787

**OMRON (CHINA) CO., LTD.**

Room 2211, Bank of China Tower,  
200 Yin Cheng Zhong Road,  
PuDong New Area, Shanghai, 200120, China  
Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200

**Authorized Distributor:**

© OMRON Corporation 1999 All Rights Reserved.  
In the interest of product improvement,  
specifications are subject to change without notice.

**Cat. No. W345-E1-12**

Printed in Japan  
1010